

DITL Logic Workbench - Status Report v28

Sakop: **127 logic sheets** (hindi kasama ang COVER 0A-0D, LEGEND 00, 16, 17, 119). Lahat ay **READY** ayon sa structural check: walang kulang na pin, walang loose end, at bawat input row ay may nakakabit.

Dati sa v19: 77 READY at 409 loose ends. Ngayon: **127 READY at 0 loose end**. Kabuuang gates na nabasa: **2555**.

Ang READY ay hindi pa patunay na tama ang takbo kumpara sa PDF. Ang nakumpara mo pa lang ay ang DITL-06 (at dati ang DITL-56, 62, 69, 81).

Buod ayon sa category

Category	Sheets	Gates	Timers	Analog in	Field out	Test sw
LOGIC	12	197	37	11	6	4
SOLENOID VALVE (new)	17	260	59	7	10	0
MOV	2	33	7	0	0	2
MOV (new)	31	709	100	8	24	0
MOTOR start/stop	29	709	169	15	63	34
INTERFACE	2	13	5	0	0	0
MOTOR start/stop (new)	6	167	45	15	14	7
SEQUENCE	14	282	56	1	0	0
PASS-THROUGH	1	0	0	0	0	0
FIELD WIRING	1	7	2	0	6	2
SOLENOID VALVE	9	153	32	2	12	0
ANNUNCIATOR I/O	3	25	0	3	0	0

Ang natitira (hindi loose end)

- **12 net na papunta sa ibang sheet** (bilang na may numero na iisa lang sa sheet) at 3 sa gilid ng cell: naka-hold hanggang sabihin mong "go linking".
- **5 net na may gumagamit pero walang pinagmumulan:** DITL-18 (1), DITL-21C (2), DITL-29A (1), DITL-38 (1).
- **DITL-03G:** ang output ng OR at ang seal-in na balik ng AND ay nagtatagpo sa isang dot (wired-OR sa drawing, hindi mali).
- **DITL-18 row 24** (ENERGIZE IGNITER A TRANS.): skip muna, ayon sa utos mo.
- **DITL-61A row 8:** 2 units lang ang wire sa drawing (PUMP B TRIP, galing 61A-67), walang kumokonsumo sa sheet na iyon.
- **DITL-21A reverse:** jog (tumatakbo habang hawak ang LOCAL REVERSE PB) dahil walang seal-in na iginuhit. Pakikumpirma sa PDF.

Mga bagong nasa app (v24 hanggang v28)

- Mga wire na bahagyang kiling (DITL-06 reset bus) ay nababasa na.
- Ang dash-dot na analog wire (03F, 03H, 23A, 44) ay bahagi na ng wiring.
- Hi/lo comparator na may numeric input (value sa panel at badge sa row), pati comparator na ang limit ay ibang analog (DITL-60 >=AB0383).
- Field output: lamp, SV coil at tuldok na lumiliwanag; TEST SWITCH para sa mga field input.
- DITL-21A: ang row 5 ay sumusunod sa connector (4) mula sa row 26.
- Nare-save ang mga binago mong value (timer, analog, MOV travel, motor delay) kada sheet.
- Left pane na may pangalan ng bawat sheet mula sa DXF, may search.

Katalogo ng 127 sheets

LOGIC (12)

Sheet	Content	G	In	Out	Notes
03C	MASTER FUEL TRIP (3)	10	7	15	
03D	MASTER FUEL TRIP (4)	11	8	19	
03E	MASTER FUEL TRIP (5)	25	18	15	
03F	MASTER FUEL TRIP (6)	15	18	15	
03G	MASTER FUEL TRIP (7)	9	16	16	3 analog
03H	MASTER FUEL TRIP (8)	22	10	16	8 analog
36	ALARM (1)	36	12	6	
37	ALARM (2)	36	12	6	
39	DEBRIS FILTER SYSTEM	5	7	5	6 field out, 4 test sw
02	FURNACE PURGE	18	9	7	
03A	MASTER FUEL TRIP (1)	8	21	8	
03B	MASTER FUEL TRIP (2)	2	5	16	

SOLENOID VALVE (new) (17)

Sheet	Content	G	In	Out	Notes
81	HOT REHEAT STEAM SYSTEM HRH DRN POT DP-HR02 DRN VLV XV-HR1022	15	8	5	SV, 1 field out
83	HOT REHEAT STEAM SYSTEM LP TURBINE BYPASS VALVE WARMING VLV XV-HR1010-	10	8	5	SV
86	INDUSTRIAL WATER SYSTEM PLUMBING WATER TANK INLET SV SV-IW0113	11	8	6	SV
88	MAIN STEAM SYSTEM DRN POT DP-MS01 DRN VLV XV-MS1011	15	8	5	SV, 1 field out
89	MAIN STEAM SYSTEM DRN POT DP-MS02 DRN VLV XV-MS1023	24	9	6	SV, 1 field out
92	TURBINE BUILDING POTABLE WATER TANK INLET SV SV-PW0114	17	6	9	SV, 1 analog
93	WT PLANT CONTROL BUILDING POTABLE WATER TANK INLET SV SV-IW0721	15	6	5	SV, 1 analog
121	CRH DRN POT DP-CR03 DRN VLV XV-CR1013	13	7	5	SV, 1 field out
62	CONDENSATE SYSTEM CONDENSER CURTAIN SPRAY VALVE XV-CD1006	15	5	4	SV
63	CONDENSATE SYSTEM FLASH CHAMBER SPRAY VALVES XV-CD1004 & XV-CD1005	28	14	10	SV, 1 analog
66	CONDENSATE SYSTEM LP TURBINE BYPASS DESUPERHEATING SPRAY WTR BLOCK VLV	16	5	4	SV, 1 analog, 1 field out
67	CONDENSATE SYSTEM AUX. STM DESUPERHEATING SPRAY WTR BLOCK VLV XV-CD112	16	5	4	SV, 1 analog, 1 field out
68	CONDENSATE SYSTEM GLAND STM DESUPERHEATING SPRAY WTR BLOCK VLV XV-CD11	16	5	4	SV, 1 analog, 1 field out
72	CONDENSATE YSTEM DEAER. EMERGENCY DRN VLV XV-CD1104-2	4	2	2	SV

Sheet	Content	G	In	Out	Notes
74	COLD REHEAT STEAM SYSTEM CRH DRN POT DP-CR02 DRN VLV XV-CR1012	15	8	5	SV, 1 field out
79	FEEDWATER SYSTEM HP TURBINE BYPASS DESUPERHEATING SPRAY WTR BLOCK VLV	15	5	3	SV, 1 analog, 1 field out
80	HOT REHEAT STEAM SYSTEM HRH DRN POT DP-HR01 DRN VLV XV-HR1021	15	8	5	SV, 1 field out

MOV (2)

Sheet	Content	G	In	Out	Notes
87	INDUSTRIAL WATER SYSTEM TO FIRE WATER TANK MV-IW0391	19	10	8	MOV
38	MOTOR CONTROL VALVE	14	7	8	MOV, 2 test sw

MOV (new) (31)

Sheet	Content	G	In	Out	Notes
94	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.1 SHUT-OFF MOV MV-TS1001	34	18	8	MOV, 1 analog, 1 field out
95	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.2 SHUT-OFF MOV MV-TS1002	35	17	8	MOV, 1 analog
96	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.3 SHUT-OFF MOV MV-TS1003	35	18	8	MOV, 1 analog, 1 field out
97	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.4 SHUT-OFF MOV MV-TS1004	34	17	8	MOV, 1 analog, 1 field out
98	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.5 SHUT-OFF MOV MV-TS1005	35	16	8	MOV, 1 analog, 2 field out
99	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.1 DRN VLV MOV MV-TS1391	26	16	8	MOV, 1 field out
100	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.1 DRN VLV MOV MV-TS1397	26	16	8	MOV
101	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.2 DRN VLV MOV MV-TS1392	26	16	8	MOV, 2 field out
102	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.2 DRN VLV MOV MV-TS1396	26	16	8	MOV, 1 field out
103	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.3 DRN VLV MOV MV-TS1393	26	16	8	MOV
104	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.3 DRN VLV MOV MV-TS1399	26	16	8	MOV
105	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.3 DRN VLV MOV MV-TS1398	26	16	8	MOV
106	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.4 DRN VLV MOV MV-TS1394	26	16	8	MOV, 1 field out
107	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.4 DRN VLV MOV MV-TS1390	26	16	8	MOV, 1 field out
108	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.5 DRN VLV MOV MV-TS1395	26	16	8	MOV, 1 field out

Sheet	Content	G	In	Out	Notes
109	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.5 DRN VLV MOV MV-TS1389	26	16	8	MOV
110	EXTRACTION STEAM SYSTEM EXTRACTION STM NO.3 DRN VLV MOV MV-TS1400	26	16	8	MOV
116	AUXILIARY STEAM SYSTEM TURBINE GLAND STM LINE DRAIN MOV MV-AS1397	19	12	8	MOV, 1 field out
51	AUXILIARY STEAM SYSTEM MAIN STM TO AUX STM HEADER SHUT-OFF MOV MV-AS13	14	10	6	MOV, 1 field out
52	AUXILIARY STEAM SYSTEM MAIN STEAM HEADER DRAIN MOV MV-AS1392	19	13	8	MOV, 1 field out
53	AUXILIARY STEAM SYSTEM GLAND STM DRAIN SEPARATOR DRAIN MOV MV-AS1393	19	12	8	MOV, 1 field out
54	AUXILIARY STEAM SYSTEM START-UP EJECTOR STEAM INLET SHUT-OFF MOV MV-AS	17	8	6	MOV
55	AUXILIARY STEAM SYSTEM STEAM JET AIR EJECTOR STEAM INLET SHUT-OFF MOV	22	11	8	MOV, 1 field out
56	MISCELLANEOUS VENT AND DRAIN SYSTEM COND VACUUM BREAKER MOV MV-AV1391	14	8	6	MOV
60	CONDENSATE STSEM MAKE-UP WTR TO COND SHUT-OFF MOV MV-MU1001	15	9	6	MOV, 2 analog
64	CONDENSATE SYSTEM CONDENSER POLISHER INLET MOV MV-CD1007	16	12	8	MOV, 1 analog
65	CONDENSATE SYSTEM CONDENSER POLISHER OUTLET MOV MV-CD1008	15	10	7	MOV
69	CONDENSATE SYSTEM LP HTR #1 INLET COND. SHUT OFF MOV MV-CD1001	15	6	8	MOV, 2 field out
70	CONDENSATE SYSTEM LP HTR #1 OUTLET COND. SHUT-OFF MOV MV-CD1002	10	5	6	MOV, 2 field out
71	CONDENSATE SYSTEM LP HTR #1 COND. BYPASS SHUT-OFF MOV MV-CD1003	10	6	6	MOV, 2 field out
75	COLD REHEAT STEAM SYSTEM HP TURBINE WARMING LINE DRN MOV MV-AS1394	19	13	8	MOV, 1 field out

MOTOR start/stop (29)

Sheet	Content	G	In	Out	Notes
111	INDUSTRIAL WATER PUMP A	38	15	6	2 analog, 4 field out, 1 test sw
112	MAKE-UP WATER PUMP A	45	25	11	3 analog, 2 field out, 1 test sw
113	INSTRUMENT AIR COMPRESSOR A/B/C	20	10	4	3 analog
114	PLANT AIR COMPRESSOR A/B/C	20	10	4	3 analog
120	WASTE WATER PUMP A	2	2	3	2 test sw
19	COAL FEEDER A START/STOP	17	18	19	motor, 1 field out, 12 test sw
21A	BOTTOM ASH SCREW COOLER A START/STOP	42	26	19	motor, 4 analog, 6 field out, 1 test sw
21B	BOTTOM ASH SCREW COOLER AUTO SEQUENCE (1)	13	11	5	
21C	BOTTOM ASH SCREW COOLER AUTO SEQUENCE (2)	37	17	9	2 field out

Sheet	Content	G	In	Out	Notes
21D	BOTTOM ASH SCREW COOLER AUTO SEQUENCE (3)	28	15	10	
21E	BOTTOM ASH SCREW COOLER AUTO SEQUENCE (4)	39	16	8	
22	BFWP A AUX. LUB. OIL PUMP	27	10	4	4 field out, 1 test sw
23A	BOILER FEED WATER PUMP A (1)	35	22	8	4 field out, 1 test sw
23B	BOILER FEED WATER PUMP A (2)	11	25	13	
24	PAF LUB. OIL PUMP A	32	13	8	4 field out, 1 test sw
25A	INDUCED DRAFT FAN (1)	31	26	8	4 field out, 1 test sw
25B	INDUCED DRAFT FAN (2)	17	23	18	
26A	PRIMARY AIR FAN (1)	31	27	8	4 field out, 1 test sw
26B	PRIMARY AIR FAN (2)	11	21	15	1 field out
27A	SECONDARY AIR FAN (1)	29	23	8	4 field out, 1 test sw
27B	SECONDARY AIR FAN (2)	6	11	8	
28A	FA BLOWER A (1)	38	26	7	4 field out, 1 test sw
28B	FA BLOWER A (2)	7	14	9	
29A	SEAWATER PUMP A (1)	31	17	5	4 field out, 1 test sw
29B	SEAWATER PUMP A (2)	5	7	4	
30	SEAWATER BOOSTER PUMP A	36	16	4	4 field out, 1 test sw
31	DIESEL OIL PUMP A	35	14	7	4 field out, 1 test sw
43	AIR PREHEATER	16	10	15	3 field out, 7 test sw
45	PLANT/INSTRUMENT AIR DRYER-A	10	10	6	motor, 4 field out

INTERFACE (2)

Sheet	Content	G	In	Out	Notes
115	TURBINE SYSTEM INTERFACE SIGNALS	4	18	17	
50	FUNCTION BLOCK FOR DEVICE OVERTIME ALARM	9	0	3	

MOTOR start/stop (new) (6)

Sheet	Content	G	In	Out	Notes
117	BOTTOM ASH SCREW COLLER A INLET VALVE (1)	24	13	5	
118	BOTTOM ASH SCREW COLLER A INLET VALVE (2)	17	8	1	1 field out
61A	CONDENSATE SYSTEM CONDENSATE PUMPS A/B(1) P-1116A/B	38	20	8	2 analog, 5 field out, 3 test sw
61B	CONDENSATE SYSTEM CONDENSATE PUMPS A/B(2) P-1116A/B	12	9	2	9 analog
76	AUX. COOLING WATER SYSTEM AUX. COOLING WATER PUMP-A P-1108A	40	23	12	3 analog, 4 field out, 2 test sw
77	AUX. COOLING WATER SYSTEM AUX. COOLING WATER PUMP-B P-1108B	36	21	10	1 analog, 4 field out, 2 test sw

SEQUENCE (14)

Sheet	Content	G	In	Out	Notes
05	BOILER TRIP SIGNAL (1)	18	10	9	
06	BOILER TRIP SIGNAL (2)	21	12	11	
07	PERMISSION TO BURNER (1)	10	11	9	1 analog
09	BURNER A COMMAND	21	10	7	

Sheet	Content	G	In	Out	Notes
10	IGNITER A LIGHT OFF SEQUENCE	24	14	8	
11	IGNITER A SHUTDOWN SEQUENCE	9	9	6	
12	BURNER A LIGHT OFF SEQUENCE (1)	26	14	9	
12A	BURNER B LIGHT OFF SEQUENCE (1)	27	17	8	
12B	BURNER C LIGHT OFF SEQUENCE (1)	20	13	7	
12C	BURNER D LIGHT OFF SEQUENCE (1)	26	16	8	
13	BURNER A LIGHT OFF SEQUENCE (2)	15	11	5	
14	BURNER A SHUTDOWN SEQUENCE (1)	21	16	6	
15	BURNER A SHUTDOWN SEQUENCE (2)	31	16	14	
01	FURNACE PURGE CONDITION	13	28	8	

PASS-THROUGH (1)

Sheet	Content	G	In	Out	Notes
08	PERMISSION TO BURNER (2)	0	2	2	

FIELD WIRING (1)

Sheet	Content	G	In	Out	Notes
18	BURNER A INPUT/OUTPUT (3)	7	7	4	6 field out, 2 test sw

SOLENOID VALVE (9)

Sheet	Content	G	In	Out	Notes
20	COAL FEEDER A OUTLET DISCHARGE VALVE	5	4	3	SV, 2 field out
28C	FA BLOWER A (3)	35	11	6	SV, 2 field out
32	FIRST STAGE SPRAY WATER SHUT OFF VALVE(1)	18	10	5	SV, 1 field out
33	SEC. STAGE SPRAY WATER SHUT OFF VALVE(1)	18	10	5	SV, 1 field out
35	REHEATER INLET DESUPERHEATER SPRAY WATER SHUT OFF VALVE	12	9	3	SV, 1 field out
44	AIR PREHEATER AIR MOTOR SOLENOID VALVE	16	7	0	SV, 1 field out
57	MISCELLANEOUS VENT AND DRAIN SYSTEM FLASH PIPE DRN VLV XV-FS1005	12	7	4	SV, 1 field out
73	COLD REHEAT STEAM SYSTEM CRH DRN POT DP-CR01 DRN VLV XV-CR1011	23	11	6	SV, 1 analog, 2 field out
78	AUX. COOLING WATER SYSTEM MAKE-UP WTR TO EXPANSION TANK ON / OFF VLV X	14	6	4	SV, 1 analog, 1 field out

ANNUNCIATOR I/O (3)

Sheet	Content	G	In	Out	Notes
40	ANNUNCIATOR INPUT / OUTPUT(1)	5	25	21	
41	ANNUNCIATOR INPUT / OUTPUT(2)	14	23	13	3 analog
42	ANNUNCIATOR INPUT / OUTPUT(3)	6	8	8	