

DCS FORM 2 — PID, MAN, SUMA faceplate parameters

Station / DCS: _____ Engineer: _____ Date: _____

How to use. Open the faceplate of each tag in the DCS (the **MNO** is the module number: MNO = 14 → S1-MDL014; the station number 101 = S1). Write the value exactly as the faceplate shows it, in the unit shown (the unit row under each column). A "=" means the same as the column before. Tick OK when the row is done. The rows are sorted by station and MNO, so you can go down the list in the DCS in the same order. Page order: A = PID (incl. PIDV), B = MAN, C = SUMA.

Type	Column	Faceplate name — meaning (assistant's reading: tell me if wrong)	Unit	Used by the simulator now?
PID	PH	PV high (range / alarm limit: write what it shows)	PV unit	yes
PID	PL	PV low (range / alarm limit: write what it shows)	PV unit	yes
PID	SH	SV limit high	PV unit	not yet (recorded to be used)
PID	SL	SV limit low	PV unit	not yet (recorded to be used)
PID	MH	MV limit high	%	yes
PID	ML	MV limit low	%	yes
PID	dMVH	MV rate limit	%	not yet (recorded to be used)
PID	P	Proportional band (gain = 100 / P)	%	yes
PID	I	Integral time	sec	yes
PID	D	Derivative time	sec	yes
PID	DTI	Calculation interval	sec	not yet (recorded to be used)
PID	TF	Input filter time	sec	not yet (recorded to be used)
PID	GAP	Gap (no action inside)	%	not yet (recorded to be used)
PID	BND	Output band	%	not yet (recorded to be used)
PID	CUT	Low cut-off	%	not yet (recorded to be used)
PID	DH	Deviation limit (alarm)	%	not yet (recorded to be used)
PID	PHONDT	PV high on-delay time	sec	not yet (recorded to be used)
PID	PLONDT	PV low on-delay time	sec	not yet (recorded to be used)
MAN	PH	PV high (range / alarm limit: write what it shows)	PV unit	yes
MAN	PL	PV low (range / alarm limit: write what it shows)	PV unit	yes
MAN	SH	SV limit high	PV unit	not yet (recorded to be used)
MAN	SL	SV limit low	PV unit	not yet (recorded to be used)
MAN	MH	MV limit high	%	yes
MAN	ML	MV limit low	%	yes
MAN	DH	Deviation limit (alarm)	%	not yet (recorded to be used)
MAN	DT	Calculation interval	sec	not yet (recorded to be used)
MAN	TF	Input filter time	sec	not yet (recorded to be used)
MAN	FSC	Full stroke time	min	not yet (recorded to be used)
MAN	CUT	Low cut-off	%	not yet (recorded to be used)
MAN	PHONDT	PV high on-delay time	sec	not yet (recorded to be used)
MAN	PLONDT	PV low on-delay time	sec	not yet (recorded to be used)
SUMA	PH	PV high (limit: write what it shows)	PV unit	not yet (recorded to be used)
SUMA	PL	PV low (limit: write what it shows)	PV unit	not yet (recorded to be used)
SUMA	RSTS	Reset / limit value of the total	total unit	not yet (recorded to be used)
SUMA	K	K (scale factor of the total)	-	not yet (recorded to be used)

Type	Column	Faceplate name — meaning (assistant's reading: tell me if wrong)	Unit	Used by the simulator now?
SUMA	DT	Calculation interval	sec	not yet (recorded to be used)
SUMA	TF	Input filter time	sec	not yet (recorded to be used)
SUMA	CUT	Low cut-off	%	not yet (recorded to be used)
SUMA	PHONDT	PV high on-delay time	sec	not yet (recorded to be used)
SUMA	PLONDT	PV low on-delay time	sec	not yet (recorded to be used)
SUMA	SUM unit	Unit of the total (T, kg, m3 ...)	text	not yet (recorded to be used)

A. PID / PIDV (68)

Faceplate TYPE=PID. PH / PL / SH / SL are in the PV unit shown in the PV unit column; MH / ML / dMVH / DH / GAP / BND / CUT in %; P in %; I, D, DTI, TF, PHONDT, PLONDT in seconds.

#	Sheet	Tag	MNO	Description / PV address	PV unit	PH	PL	SH	SL	MH	ML	dMVH	P	I	D	DTI	TF	GAP	BND	CUT	DH	PHONDT	PLONDT	OK
						unit	unit	unit	unit	%	%	%	%	sec	sec	sec	sec	%	%	%	%	sec	sec	
Station 101 (S1)																								
1	ABC-001C	PIC-COBM	6	#1 Boiler finishing superheater outlet main steam pressure AI0131 [PT-MS1002]	Kg/cm2																			
2	ABC-012	TICMS1004	9	#1 Boiler finishing S/H outlet main steam temp. (1) AI0612 [TT-MS1004-1] AI0644 [TT-MS1004-2]	°C																			
3	ABC-002	AICFG112	10	COMBUSTION AIR CONTROL	%																			
4	ABC-004A	FIC-CF	14	#1 Coal feeder-A feedrate AI0480 [MIF-CL1061-A]	%																			
5	ABC-004A	FIC-CM	15	#1 Coal feeder-A feedrate AI0480 [MIF-CL1061-A]	T/H																			
6	ABC-011	TICBR1130	16	#1 Superheater NO.2 inlet header steam temperature (1) AI0609 [TT-BR1130-1] AI0641 [TT-BR1130-2]	°C																			
7	ABC-011	TICBR1140	17	#1 Superheater NO.2 outlet header steam temperature (1) AI0610 [TT-BR1140-1] AI0642 [TT-BR1140-2]	°C																			
8	ABC-012	TICBR1150	18	#1 Finishing S/H inlet header steam temperature (1) AI0611 [TT-BR1150-1] AI0643 [TT-BR1150-2]	°C																			
9	ABC-029	PICDO1008	19	#1 Boiler start up burner diesel oil circulation line oil pressure AI0514 [PT-DO1008]	kg/cm2																			
10	ABC-010	LICBR1001	20	#1 Boiler drum level (1) AI0130 [LT-BR1001-1] AI0128 [PT-BR1001-1]	mm																			
11	ABC-010	LICBR1001A	21	#1 Boiler drum level (1) AI0130 [LT-BR1001-1] AI0128 [PT-BR1001-1]	mm																			
12	ABC-010	FICFW1007	22	DRUM LEVEL CONTROL (FEED WATER FLOW CONTROL)	T/H																			
13	ABC-007	FICFA1071	23	PAF/SAF AIR FLOW CONTROL	T/H																			
14	ABC-007	FICFA1081	24	PAF/SAF AIR FLOW CONTROL	T/H																			
15	ABC-014	FICFA1055A	25	FLUIDIZING AIR FLOW CONTROL	T/H																			
16	ABC-014	FICFA1055B	26	FLUIDIZING AIR FLOW CONTROL	T/H																			
17	ABC-003A	FICFA1043A	27	#1 Boiler start up burner-A hot secondary air inlet flow AI0164 [FT-FA1043-A] AI0515 [FT-DO1043-A]	T/H																			
18	ABC-003B	FICFA1043B	28	#1 Boiler start up burner-B hot secondary air inlet flow AI0290 [FT-FA1043-B] AI0546 [FT-DO1043-B]	T/H																			
19	ABC-008	PICFG108A	29	FURNACE PRESSURE CONTROL	mmH2O																			
20	ABC-013	PICMS1002	30	MAIN STEAM PRESSURE CONTROL (BLOW-OFF)	kg/cm2																			

#	Sheet	Tag	MNO	Description / PV address	PV unit	PH	PL	SH	SL	MH	ML	dMVH	P	I	D	DTI	TF	GAP	BND	CUT	DH	PHONDT	PLONDT	OK	
						unit	unit	unit	unit	%	%	%	%	sec	sec	sec	sec	%	%	%	%	sec	sec		
21	ABC-009A	DPICFG108	31	#1 Furnace plenum/upper layer diff. pressure (A) AI0134 [DPT-FG1081] AI0262 [DPT-FG1082]	mmH2O																				
22	ABC-009A	PIC-BASC	32	#1 Furnace plenum/upper layer diff. pressure (A) AI0134 [DPT-FG1081] AI0262 [DPT-FG1082]	%																				
23	ABC-003A	FICDO1043A	33	#1 Boiler start up burner-A supply line oil flow AI0515 [FT-DO1043-A]	T/H																				
24	ABC-003B	FICDO1043B	34	#1 Boiler start up burner-B supply line oil flow AI0546 [FT-DO1043-B]	T/H																				
25	ABC-003C	FICDO1043C	35	#1 Boiler start up burner-C supply line oil flow AI0517 [FT-DO1043-C]	T/H																				
26	ABC-008	PICFG108	36	FURNACE PRESSURE CONTROL	mmH2O																				
27	ABC-005	AICFG10571	37	#1 Stack outlet flue gas SOx value AI0466 [AT-FG1057-1]	ppm																				
28	ABC-003D	FICDO1043D	38	#1 Boiler start up burner-D supply line oil flow AI0548 [FT-DO1043-D]	T/H																				
29	ABC-054	PICHR1391	46	#1 Hot reheat steam blow-off motor valve position AI0737 [ZT-HR1391]	kg/cm2																				
30	ABC-010	LICBR1001B	49	#1 Boiler drum level (1) AI0130 [LT-BR1001-1] AI0128 [PT-BR1001-1]	mm																				
31	ABC-004A	HS-COAL	51	COAL MASTER CONTROL & A-COAL FEEDER CONTROL																					
32	ABC-003A	PICDO1043A	62	#1 Boiler start up burner-A diesel oil supply line oil pressure AI0293 [PT-DO1043-A2]	kg/cm2																				
33	ABC-003B	PICDO1043B	63	#1 Boiler start up burner-B diesel oil supply line oil pressure AI0439 [PT-DO1043-B2]	kg/cm2																				
34	ABC-003C	PICDO1043C	64	#1 Boiler start up burner-C diesel oil supply line oil pressure AI0596 [PT-DO1043-C2]	kg/cm2																				
35	ABC-003D	PICDO1043D	65	#1 Boiler start up burner-D diesel oil supply line oil pressure AI0771 [PT-DO1043-D2]	kg/cm2																				
36	ABC-055	HICBR1391	71	#1 S/H NO.1 outlet header to reheater motor valve position AI0181 [ZT-BR1391]	%																				
37	ABC-003E	FIC-OM	164	OIL MASTER CONTROL																					
38	ABC-003C	FICFA1043C	197	#1 Boiler start up burner-C hot secondary air inlet flow AI0403 [FT-FA1043-C] AI0517 [FT-DO1043-C]	T/H																				
39	ABC-003D	FICFA1043D	198	#1 Boiler start up burner-D hot secondary air inlet flow AI0597 [FT-FA1043-D] AI0548 [FT-DO1043-D]	T/H																				
Station 102 (S2)																									
40	ABC-017	PICSB1052	1	#1 Boiler sootblower header steam pressure AI0533 [PT-SB1052]	kg/cm2																				
41	ABC-050	PICMS1006	2	#1 Turbine main steam pressure(1) AI0416 [PT-MS1006-1] AI0512 [PT-MS1006-2]	kg/cm2																				

#	Sheet	Tag	MNO	Description / PV address	PV unit	PH	PL	SH	SL	MH	ML	dMVH	P	I	D	DTI	TF	GAP	BND	CUT	DH	PHONDT	PLONDT	OK
						unit	unit	unit	unit	%	%	%	%	sec	sec	sec	sec	%	%	%	%	sec	sec	
42	ABC-051	TICMS1022	3	#1 HP turbine bypass outlet temperature (1) AI0865 [TT-MS1022-1] AI0897 [TT-MS1022-2]	°C																			
43	ABC-031	LICCD1104	4	COND. DUMPING TO RAW PIT / COND. MAKE-UP WATER / DEAERATOR LEVEL CONTROL	mm																			
44	ABC-019	TICHR1002	5	#1 Reheater outlet header temperature (1) AI0867 [TT-HR1002-1] AI0899 [TT-HR1002-2]	°C																			
45	ABC-020	TICHR1002A	6	REHEATER/SUPERHEATER FLUE GAS DAMPER CONTROL	°C																			
46	ABC-030	PICAS1004	7	#1 Main steam pipe to aux. steam supply pressure AI0514 [PT-AS1004] AI0515 [PT-AS1005]	kg/cm2																			
47	ABC-030	PICAS1005	8	#1 Cold reheat to aux. steam supply pressure AI0515 [PT-AS1005] AI0514 [PT-AS1004]	kg/cm2																			
48	ABC-056	PICCD1104	9	#1 Boiler deaerator pressure AI0417 [PT-CD1104]	kg/cm2																			
49	ABC-031	LICCD1110A	10	#1 Condenser hot well water level AI0640 [LT-CD1110]	mm																			
50	ABC-031	LICCD1110B	11	#1 Condenser hot well water level AI0640 [LT-CD1110]	mm																			
51	ABC-032	FICCD1120	12	#1 Condensate water flow AI0437 [FT-CD1120]	T/H																			
52	ABC-032	FICCD1121	13	#1 Condensate polisher inlet water flow AI0436 [FT-CD1121] AI0437 [FT-CD1120]	T/H																			
53	ABC-033	TICAS1001	14	#1 Main steam to aux. steam desuperheater temperature AI0641 [TT-AS1001]	°C																			
54	ABC-034	TICAS1017	15	#1 Gland steam turbine side temperature AI0902 [TT-AS1017]	°C																			
55	ABC-035	LICHHD11051	16	#1 NO.1 HPH level (1) AI0676 [LT-HD1105-1] AI0852 [LT-HD1105-2]	mm																			
56	ABC-035	LICHHD11052	17	#1 NO.1 HPH level (2) AI0852 [LT-HD1105-2] AI0676 [LT-HD1105-1]	mm																			
57	ABC-036	LICHHD11061	18	#1 NO.2 HPH level (1) AI0677 [LT-HD1106-1] AI0853 [LT-HD1106-2]	mm																			
58	ABC-036	LICHHD11062	19	#1 NO.2 HPH level (2) AI0853 [LT-HD1106-2] AI0677 [LT-HD1106-1]	mm																			
59	ABC-037	LICHHD11011	20	#1 NO.1 LPH level (1) AI0673 [LT-HD1101-1] AI0849 [LT-HD1101-2]	mm																			
60	ABC-037	LICHHD11012	21	#1 NO.1 LPH level (2) AI0849 [LT-HD1101-2] AI0673 [LT-HD1101-1]	mm																			
61	ABC-038	LICHHD11021	22	#1 NO.2 LPH level (1) AI0674 [LT-HD1102-1] AI0850 [LT-HD1102-2]	mm																			
62	ABC-038	LICHHD11022	23	#1 NO.2 LPH level (2) AI0850 [LT-HD1102-2] AI0674 [LT-HD1102-1]	mm																			

#	Sheet	Tag	MNO	Description / PV address	PV unit	PH	PL	SH	SL	MH	ML	dMVH	P	I	D	DTI	TF	GAP	BND	CUT	DH	PHONDT	PLONDT	OK	
						unit	unit	unit	unit	%	%	%	%	sec	sec	sec	sec	%	%	%	%	sec	sec		
63	ABC-039	LICHD11031	24	#1 NO.3 LPH level (1) AI0675 [LT-HD1103-1] AI0851 [LT-HD1103-2]	mm																				
64	ABC-039	LICHD11032	25	#1 NO.3 LPH level (2) AI0851 [LT-HD1103-2] AI0675 [LT-HD1103-1]	mm																				
65	ABC-052	PICHR1003	26	#1 HP turbine first stage steam pressure (A) AI0883 [PT-ST1001-1] AI0884 [PT-ST1001-2]	kg/cm2																				
66	ABC-052	TICHR1012	27	#1 LP turbine bypass outlet temperature (1) AI0864 [TT-HR1012-1] AI0896 [TT-HR1012-2]	°C																				
67	ABC-053	TICLO1002	28	#1 Turbine rated speed AI0534 [TCS-AI1004] AI0452 [TE-LO1002-1]	°C																				
Station 105 (S5)																									
68	ABC-028	PICDO0005	1	Diesel oil pump outlet to start-up burner oil pressure AI0181 [PT-DO0005]	kg/cm2																				

B. MAN (manual station) (58)

Faceplate TYPE=MAN. FSC in minutes, DT and TF in seconds.

#	Sheet	Tag	MNO	Description / PV address	PV unit	PH	PL	SH	SL	MH	ML	DH	DT	TF	FSC	CUT	PHONDT	PLONDT	OK
						unit	unit	unit	unit	%	%	%	sec	sec	min	%	sec	sec	
Station 101 (S1)																			
1	ABC-001A	HIC-ULD	2	COORDINATED CONTROL SYSTEM	MW														
2	ABC-001A	HIC-MWHL	3	COORDINATED CONTROL SYSTEM	MW														
3	ABC-001A	HIC-MWLL	4	COORDINATED CONTROL SYSTEM	MW														
4	ABC-001B	HIC-MWRL	5	COORDINATED CONTROL SYSTEM	MW/MIN														
5	ABC-001C	HIC-BM	7	#1 Boiler finishing superheater outlet main steam pressure AI0131 [PT-MS1002]	%														
6	ABC-001C	EIC-TM	8	#1 Boiler finishing superheater outlet main steam pressure AI0131 [PT-MS1002]	MW														
7	ABC-004A	FICCL1061A	11	#1 Coal feeder-A feedrate AI0480 [MIF-CL1061-A]	T/H														
8	ABC-004B	FICCL1061B	12	#1 Coal feeder-B feedrate AI0512 [MIF-CL1061-B]	T/H														
9	ABC-004C	FICCL1061C	13	#1 Coal feeder-C feedrate AI0544 [MIF-CL1061-C]	T/H														
10	ABC-009A	HICL1060A	39	FURNACE DIFF. PRESSURE CONTROL (A/B/C-BOTTOM ASH SCREW COOLER)	rpm														
11	ABC-009A	HICL1060B	40	FURNACE DIFF. PRESSURE CONTROL (A/B/C-BOTTOM ASH SCREW COOLER)	rpm														
12	ABC-009A	HICL1060C	41	FURNACE DIFF. PRESSURE CONTROL (A/B/C-BOTTOM ASH SCREW COOLER)	rpm														
13	ABC-009B	HICL1060D	42	D-BOTTOM ASH SCREW COOLER CONTROL	rpm														
14	ABC-002	HS-OIL	43	COMBUSTION AIR CONTROL	Kcal / Kg														
15	ABC-003A	HIC-AFAR	44	A-START UP BURNER CONTROL (FUEL / AIR)															
16	ABC-003B	HIC-BFAR	45	B-START UP BURNER CONTROL (FUEL / AIR)															
17	ABC-002	HS-O2	48	COMBUSTION AIR CONTROL	%														
18	ABC-002	HIC-TADBS	50	COMBUSTION AIR CONTROL	T/H														
19	ABC-004A	A-BIAS	52	COAL MASTER CONTROL & A-COAL FEEDER CONTROL	T/H														
20	ABC-004B	B-BIAS	53	B-COAL FEEDER CONTROL	T/H														

#	Sheet	Tag	MNO	Description / PV address	PV unit	PH	PL	SH	SL	MH	ML	DH	DT	TF	FSC	CUT	PHONDT	PLONDT	OK
						unit	unit	unit	unit	%	%	%	sec	sec	min	%	sec	sec	
21	ABC-004C	C-BIAS	54	C-COAL FEEDER CONTROL	T/H														
22	ABC-009A	SICL1060A	55	#1 Bottom ash cooler-A converter speed AI0150 [ST-L1060A]	rpm														
23	ABC-009A	SICL1060B	56	#1 Bottom ash cooler-B converter speed AI0279 [ST-L1060B]	rpm														
24	ABC-009A	SICL1060C	57	#1 Bottom ash cooler-C converter speed AI0407 [ST-L1060C]	rpm														
25	ABC-009B	SICL1060D	58	#1 Bottom ash cooler-D converter speed AI0769 [ST-L1060D]	rpm														
26	ABC-003C	HIC-CFAR	59	C-START UP BURNER CONTROL (FUEL / AIR)															
27	ABC-003D	HIC-DFAR	60	D-START UP BURNER CONTROL (FUEL / AIR)															
28	ABC-029	HICDO1012	61	#1 Diesel oil pump to burner pressure control valve position AI0276 [ZT-DO1012]	%														
29	ABC-003A	HIC-SADBSA	158	A-START UP BURNER CONTROL (FUEL / AIR)	T/H														
30	ABC-003B	HIC-SADBSB	159	B-START UP BURNER CONTROL (FUEL / AIR)	T/H														
31	ABC-003C	HIC-SADBSC	160	C-START UP BURNER CONTROL (FUEL / AIR)	T/H														
32	ABC-003D	HIC-SADBSD	161	D-START UP BURNER CONTROL (FUEL / AIR)	T/H														
Station 102 (S2)																			
33	ABC-020	HICHR1002A	31	REHEATER/SUPERHEATER FLUE GAS DAMPER CONTROL	%														
34	ABC-020	HICHR1002B	32	REHEATER/SUPERHEATER FLUE GAS DAMPER CONTROL	%														
Station 103 (S3)																			
35	ABC-015	HICFA1005	1	#1 Furnace temp. front wall motor control damper FA1005 position AI0544 [ZT-FA1005]	%														
36	ABC-015	HICFA1006	2	#1 Furnace temp. front wall motor control damper FA1006 position AI0545 [ZT-FA1006]	%														
37	ABC-015	HICFA1007	3	#1 Furnace temp. front wall motor control damper FA1007 position AI0546 [ZT-FA1007]	%														
38	ABC-015	HICFA1008	4	#1 Furnace temp. front wall motor control damper FA1008 position AI0547 [ZT-FA1008]	%														
39	ABC-015	HICFA1009	5	#1 Furnace temp. front wall motor control damper FA1009 position AI0548 [ZT-FA1009]	%														
40	ABC-015	HICFA1010	6	#1 Furnace temp. front wall motor control damper FA1010 position AI0549 [ZT-FA1010]	%														

#	Sheet	Tag	MNO	Description / PV address	PV unit	PH	PL	SH	SL	MH	ML	DH	DT	TF	FSC	CUT	PHONDT	PLONDT	OK
						unit	unit	unit	unit	%	%	%	sec	sec	min	%	sec	sec	
41	ABC-015	HICFA1011	7	#1 Furnace temp. front wall motor control damper FA1011 position AI0550 [ZT-FA1011]	%														
42	ABC-015	HICFA1012	8	#1 Furnace temp. front wall motor control damper FA1012 position AI0560 [ZT-FA1012]	%														
43	ABC-015	HICFA1013	9	#1 Furnace temp. front wall motor control damper FA1013 position AI0561 [ZT-FA1013]	%														
44	ABC-015	HICFA1014	10	#1 Furnace temp. front wall motor control damper FA1014 position AI0562 [ZT-FA1014]	%														
45	ABC-015	HICFA1015	11	#1 Furnace temp. front wall motor control damper FA1015 position AI0563 [ZT-FA1015]	%														
46	ABC-015	HICFA1016	12	#1 Furnace temp. front wall motor control damper FA1016 position AI0564 [ZT-FA1016]	%														
47	ABC-016	HICFA1017	13	#1 Furnace temp. front wall motor control damper FA1017 position AI0565 [ZT-FA1017]	%														
48	ABC-016	HICFA1018	14	#1 Furnace temp. front wall motor control damper FA1018 position AI0566 [ZT-FA1018]	%														
49	ABC-016	HICFA1019	15	#1 Furnace temp. rear wall motor control damper FA1019 position AI0416 [ZT-FA1019]	%														
50	ABC-016	HICFA1020	16	#1 Furnace temp. rear wall motor control damper FA1020 position AI0417 [ZT-FA1020]	%														
51	ABC-016	HICFA1021	17	#1 Furnace temp. rear wall motor control damper FA1021 position AI0418 [ZT-FA1021]	%														
52	ABC-016	HICFA1022	18	#1 Furnace temp. rear wall motor control damper FA1022 position AI0419 [ZT-FA1022]	%														
53	ABC-016	HICFA1023	19	#1 Furnace temp. rear wall motor control damper FA1023 position AI0420 [ZT-FA1023]	%														
54	ABC-016	HICFA1024	20	#1 Furnace temp. rear wall motor control damper FA1024 position AI0421 [ZT-FA1024]	%														
55	ABC-016	HICFA1025	21	#1 Furnace temp. rear wall motor control damper FA1025 position AI0422 [ZT-FA1025]	%														
56	ABC-016	HICFA1026	22	#1 Furnace temp. rear wall motor control damper FA1026 position AI0423 [ZT-FA1026]	%														
57	ABC-057	HICFABIASU	23	FURNACE TEMPERATURE (3)	%														
58	ABC-057	HICFABIASL	24	FURNACE TEMPERATURE (3)	%														

C. SUMA (totalizer) (10)

Faceplate TYPE=SUMA. RSTS = the reset / limit value of the total (for example 99999999.9 T); also write the unit of the total.

#	Sheet	Tag	MNO	Description / PV address	PV unit	PH	PL	RSTS	K	DT	TF	CUT	PHONDT	PLONDT	SUM unit	OK
						unit	unit	total unit	-	sec	sec	%	sec	sec	text	
Station 101 (S1)																
1	ABC-003A	FIQDO1043A	173	#1 Boiler start up burner-A supply line oil flow AI0515 [FT-DO1043-A]	T/H											
2	ABC-003B	FIQDO1043B	174	#1 Boiler start up burner-B supply line oil flow AI0546 [FT-DO1043-B]	T/H											
3	ABC-003C	FIQDO1043C	175	#1 Boiler start up burner-C supply line oil flow AI0517 [FT-DO1043-C]	T/H											
4	ABC-003D	FIQDO1043D	176	#1 Boiler start up burner-D supply line oil flow AI0548 [FT-DO1043-D]	T/H											
5	ABC-010	FIQFW10071	181	#1 Boiler feed water flow (1) AI0256 [FT-FW1007-1] AI0592 [TT-FW1160]	T/H											
6	ABC-010	FIQFW10072	182	#1 Boiler feed water flow (2) AI0384 [FT-FW1007-2] AI0592 [TT-FW1160]	T/H											
7	ABC-001C	FIQMS1031	184	#1 Boiler main steam flow AI0129 [FT-MS1031] AI0131 [PT-MS1002]	T/H											
8	ABC-005	LIME-SUM	196	#1 Limestone feeder speed AI0151 [ST-M1311]	%											
Station 102 (S2)																
9	ABC-032	FIQCD1121	86	#1 Condensate polisher inlet water flow AI0436 [FT-CD1121]	T/H											
10	ABC-032	FIQCD1120	87	#1 Condensate water flow AI0437 [FT-CD1120]	T/H											