DCS Logic Simulator v3.2.1 release report

Release date: 2026-11-10. Previous Stable: 3.2.0 (2026-11-03). Last Beta: 3.2.1-beta.281.

What is new

- Plant model: one water inventory, heat balance, alarm limits, bed temperature and inventory, air preheater and oxygen, fans, ash, and part load behaviour.
- Turbine and generator: trip logic as simulated sheets, turbine control page, automatic synchronizing, generator model, bearings and vibration.
- Training: normal shutdown, bottle-up, turbine trip and hot restart, Warm and Hot starting states, and practice faults.
- Save and load of the whole plant, and a trend recorder with CSV export.
- New layout (layout C): two bars, Details column, start screen, unit flow overview, Engineer mode, Instructor console, search, confirmation dialogs, and sizes that follow the screen. The old layout stays available.

How it was tested

- Automatic: Checks and Simulation tests pass on 3.2.1-beta.281.
- Live on the Beta site, Worker on, at 1024x768, 1366x768 and 1920x1080: start screen, Operator, plant pages, PLANT menu dialogs (Cancel path), Instructor console, Engineer tabs, Details tabs, Search, View and Run, Sheet tools, faceplate control actions, Curves and Loop check actions, Training Show, turbine Target MW and Criteria bypass, old layout.
- Final live pass on build 94e98cb: no open fault.
- Automatic, on the 3.2.1 release build: regression tests 11 of 11; switches 438 cases, 0 wrong; logic blocks 51 sheets, 12021 checks, 0 wrong, with the plant model off and on; screen audit 27 screens, 0 page errors. The 28 audit notes are all the Search label, which is hidden on purpose.

Not tested live

- Saving a real file: Export CSV, Download JSON, Recorder CSV. The content was checked, the file save was not.
- Editing a Curves table.
- The Yes path of the PLANT menu dialogs in the final pass (Cancel only).
- Real tablet touch and phone.
- A complete run from Cold to 150 MW, the Warm and Hot practices, and load down to 120 MW on the release build.
- The apk and the Windows exe on a real device.
- The automatic controller test (generic tester) gave no usable result: it reports the same number of failures per controller on v3.2.0 and on v3.2.1 (8 controllers, 3 sheets compared, stopped there), because the operator values it sends do not reach the controller. The tester itself is to be repaired. Faceplate control actions were checked live.

Known small items

- Enter in Search does not open a result; the buttons do.
- At 1024 px the Engineer tabs become one dropdown, the sheet tool bar takes two rows, and a logic sheet opens at 193 % until Fit.
- At 1024 px a plant page at Fit is small; Readable size zooms in.

Carried to the plant plan

- Load moves between about 147 and 151 MW right after a 150 MW start before it settles.
- Main steam temperature overshoot, hotwell level on a feedwater surge, reheat temperature at 90 MW, and the other open items of the plant plan.