

Genset Inspection Checklist

1. Site Information

Item	Details
Site Code	JEN1_0863
Site Name	LADANG IKATAN KAYANGAN
Location	PAITAN
Date	15 JULY 2026
Time	1453 p.m
Technician Name and Signature	Fazlan
Genset Model	HH-30GFS
Serial Number	WSL24051215NF
Running Hours	1208.7

2. Inspection Checklist

No	Item to Check	Status (✓ / X)
1	Generator physically clean	✓
2	No oil / fuel / coolant leaks	✓
3	Mounting bolts tight	✓
4	Enclosure / canopy condition	✓
5	Air vents not blocked	✓
6	Engine oil level	✓
7	Engine oil condition	✓
8	Coolant level	✓
9	Radiator cleanliness	✓
10	Fan belt tension	✓
11	Fuel level	✓
12	Fuel filter condition	✓
13	Fuel line leakage	✓
14	Battery voltage	✓
15	Battery terminals condition	✓

No	Item to Check	Status (✓ / X)
16	Battery charger working	✓
17	Control panel functioning	✓
18	Output voltage stable	✓
19	Frequency stable (50 Hz)	✓
20	Circuit breaker condition	✓
21	Earthing connection secure	✓
22	Grounding resistance checked	✓
23	Exhaust pipe condition	✓
24	Excessive smoke from exhaust	✓
25	Generator start test	✓
26	Generator running noise normal	✓
27	Body Voltage Leakage	✓
28	Alternator in good condition	✓

3. Operational Readings

Parameter	Reading
3 phase Output Voltage (V)	R-Y = 415 Y-B = 415 R-B = 415
Phase to Neutral Voltage (V)	R-N = 240 Y-N = 240 B-N = 240
Frequency (Hz)	50
Battery Voltage (V)	Genset Off = 13.7 Genset On = 14.2

4. Remarks

Refill diesel 600litre & pm genset