

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION	(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0016658	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 07/31/2024
---	---	--	--

NAME OF PROVIDER OR SUPPLIER CLIENTS CHOICE LLC	STREET ADDRESS, CITY, STATE, ZIP CODE W11749 COUNTY LINE ROAD STANLEY, WI 54768
---	---

(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 000	INITIAL COMMENTS On 07/31/2024, the department conducted a licensure survey at Clients Choice LLC. One deficiency was identified. Census: 4	M 000		
M 282	88.05(3)(d) ANNUAL WELL WATER INSPECTIONS Where a public water supply is not available water samples shall be taken from the well and tested at the state laboratory of hygiene or other laboratory approved under ch. HSS 165 at least annually. This Rule is not met as evidenced by: Based on record review and interview, the provider did not ensure water samples were taken from the well and tested at a state laboratory of hygiene or another approved laboratory at least annually. Findings include: The adult family home is licensed to serve up to 4 residents within the client groups of developmentally disabled, emotionally disturbed/mental illness, traumatic brain injury, and alcohol/drug dependent. The facility is in a rural area with a private well for water. On 7/31/2024 at approximately 10:30 AM, Surveyor reviewed the provider's well water inspections. The last well water inspection was dated 2021. The records did not include a well	M 282		

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Wisconsin Department of Health Services

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 0016658	(X2) MULTIPLE CONSTRUCTION A. BUILDING: _____ B. WING: _____	(X3) DATE SURVEY COMPLETED C 07/31/2024
NAME OF PROVIDER OR SUPPLIER CLIENTS CHOICE LLC		STREET ADDRESS, CITY, STATE, ZIP CODE W11749 COUNTY LINE ROAD STANLEY, WI 54768		
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)	ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)	(X5) COMPLETE DATE
M 282	Continued From page 1 water inspection for 2022 or 2023. On 7/31/2024 at approximately 11:00 AM, Surveyor interviewed House Manager (HM) A. Surveyor asked if there were any additional well water inspections. HM A thought the requirement was to test the well water every 3 years. HM A texted the licensee, who also stated s/he thought the requirement was every 3 years. HM A acknowledged that the last documented well water test was in 2021, and would be getting the well water inspection done as soon as possible. The provider did not ensure the private well water was tested at least annually.	M 282		