

Office of the District Fire Officer
Karnataka State Fire
and Emergency Services
Khanapur Road, Belagavi-590001



Phone : 0831-2429441
E-Mail : dfobgv@gmail.com

C.NO/152/FSR/DFO/BELAGAVI/2025

Date : 24-09-2025

To,
The Principal,
C.S. Tubachi Education Society's,
Shri Kadasiddeshwar Public School,
Hukkeri, Hukkeri Taluk, Belagavi District.

Sir,

Sub: Issue of "Fire Safety Recommendation" to C.S. Tubachi Education Society's,
Shri Kadasiddeshwar Public School, Hukkeri, Hukkeri Taluk, Belagavi District.

Ref:- C.No:09/FSR/FSO/Hukkeri/2025 Date: 22-09-2025.

*_*_*_*_*_*_*_*_*_*

With reference to the subject above cited, the premises of C.S. Tubachi Education Society's, Shri Kadasiddeshwar Public School, building consisting with Ground & 1st floor situated at Hukkeri, Hukkeri Taluk, Belagavi District was inspected by Fire Station Officer Hukkeri on 22-09-2025 with respect to fire Prevention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

ANNEXURE-1

(Up to 14.99 mtrs. In height) GROUP-B Educational Buildings

NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings Sub division B1 & B2
(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

A. Details of the Building/Premises.

01	Name and Address of the Applicant	The Principal, C.S. Tubachi Education Society's, Shri Kadasiddeshwar Public School, Hukkeri, Hukkeri Taluk, Belagavi District.
02	Name and Address of the Premises	C.S. Tubachi Education Society's, Shri Kadasiddeshwar Public School, Hukkeri, Hukkeri Taluk, Belagavi District.
03.	Name and Address of the Building Owner	The Chariman C.S. Tubachi Education Society's, Shri Kadasiddeshwar Public School, Hukkeri, Hukkeri Taluk, Belagavi District.
04.	Number of Building	01
05.	Number of Floors	Ground & 1 st Floor
06.	Floor-wise details of Occupancy:-	
	Ground Floor	Class Room-12, Auditorium Room-01, Office-01, Medical Room-01 & Mid Day Meal Room-01.
	1 st floor	Class Room-12, Science Laboratory-01, Computer Room-01, Library-01, Teachers Room-01 & Sports Room-01.
07.	U-Dise No.	29300714301
08.	Height of the building	07.90 Mtr

PRINCIPAL
SHRI KADASHIDDESHWAR PUBLIC
SCHOOL, HUKKERI.
Dist: Belagavi. KARNATAKA-591309.

MANAGER
SHRI KADASHIDDESHWAR PUBLIC
SCHOOL HUKKERI
Dist BELAGAVI KARNATAKA 591309

24/9/25

09.	Site area	1 Acre 35 Gunta
10.	Built-up area of each floor:-	
	Ground Floor	1243.10 Sq Mtr.
	1 st Floor	1243.10 Sq Mtr.
11.	Total Built-up area	2486.20 Sq Mtr.
12.	Surrounding properties:-	
	East	Degree College
	West	Road & then Complex
	North	Sankeshwar to Gokak Main Road
	South	Government Hospital
13.	Open Space all around the building	
	East	175.00 Mtr
	West	13.95 Mtr
	North	02.00 Mtr
	South	09.60 Mtr
Allowed Setbacks (open space) should be maintained free from further obstruction/construction.		

B. On the inspection of this School/College premises, the following Fire Prevention, Fire Fighting and Evacuation Measures recommended are considered absolutely essential from fire safety point of view:-

SLN o (01)	Details (02)	Existing (03)		Recommendations (04)
01.	Accessibility to the premises	The premises is accessible from Northern & Western side road		--
02.	Number of Entrances	02 Nos. each of 04.30 mtr wide on Northern 7 Western side.		--
03.	Number of Staircase	No of staircase	02 nos.	The staircase must be free from Obstruction all the time. And height of the hand drill should be 1.00 mtr.
		Width of the staircase	02.45 mtr	
		Width of threads	0.30 mtr	
		Height of risers	0.13 mtr	
		No of risers per flight	21	
		Height of the hand drill.	0.85 mtr	

PRINCIPAL
SHRI KADASHIDDESHWAR PUBLIC
SCHOOL, HUKKERI.
Dist: Belagavi, KARNATAKA-591309

MANAGER
SHRI KADASHIDDESHWAR PUBLIC
SCHOOL HUKKERI
Dist: BELAGAVI KARNATAKA 591309


04.	Portable Extinguishers	Not Provided	A. One water mist extinguisher of 09 ltrs capacity should be kept near each staircase landing. B. One mechanical foam extinguisher of 09 ltr capacity & one ABC type extinguisher of 06 kgs capacity should be provided near the diesel generator. C. One CO2 type fire extinguisher of 4.5 kgs capacity should be provided near each electrical panel board & electrical room. D. One ABC type fire extinguisher of 06 Kgs capacity should be located as to be available within 15 mtrs. Radius.
05.	Hose reel hose system	Not Provided	One Hose reel hose near the staircase (One hose reel hose system for every 1000 sq.mtrs) . The hose reel hose of min 19 mm size and of 30 mtrs length shall be provided to reach the farthest point of each floor and shut off branch having a nozzle of 05 mm size. The hose reel hose should be connected at each landing.
06.	At the terrace tank level with minimum pressure of 3.5 kg/cm2	Not Provided	The system should be connected to an booster pump of 450 LPM or of 5 HP capacity. Further the system should be connected to an alternative source of power supply.
07.	Diesel Generator	Not Provided	Diesel generator of 15 KVA capacity should be provided to supply alternative power supply.
08.	Terrace Tank	01 no. of 3000 Ltrs capacity overhead tank & U/G tank of 6000 Ltrs capacity provided.	The system should be connected to an over head tank of 5000 ltrs capacity further if basement is provided the tank capacity shall be increased to 10,000ltrs capacity. (The water tank should be kept exclusively for fire fighting purpose.) Note: if the existing building is not capable of sustaining the weight of 5,000/10,000 ltrs tank capacity provision shall be made to provide water tank on the side of the building with support from ground level by providing RCC column structure or MS column structure. If there is no option to provide even the above mentioned overhead tank provision shall be made to provide underground water tank of capacity with submersible pump of 5-7 HP capacity.
09.	Escape routes	Not Marked	Direction in which the students have to move in the event of an emergency should be displayed in the corridor on each floor during evacuation.
10.	Fire Order (Fire safety plans)	Not Displayed	A notice board indicating the action to be taken by the employees in case of any emergency should be displayed with the

[Signature]
24/10/25

			telephone numbers of Hukkeri fire station i.e 8310935806, 101 & 080-22971550, 22971500, 22971600 and the telephone no's nearest ambulance services and police station.
11.	No Smoking board	Not Displayed	COPTA Sec-4 direction of No Smoking area, smoking here is an offence board should be written in English & Kannada both languages shall be prominently displayed at inside the entry/exit of the each floor.
12.	Fire Siren	Not Installed	A Fire Siren shall be installed in the premises to inform the inmates in case of a fire emergency and evacuate the area.
13.	Nominate One Fire Nodal Officer	Not Nominated	A Fire Nodal Officer shall be nominated either from teaching or non teaching staff.
14.	Fire Fighting Training	Not Imparted	At least 40% of the Teaching and non Teaching staff should be got trained in basic fire fighting at R.A.Mundkur Fire & Emergency Services Academy, Bannerughatta Road, Bangalore or Regional training centre Hubballi.
15.	<u>Fire Precautionary Measures</u> A :- Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory and electrical sun panel premises. B:- Accumulation of combustible waste in and around the premises should be avoided. C:- The Exit ways shall be always kept clear without any obstruction. D:- Liquefied petroleum gas should not be stored in the building. E:- The doors shall not be kept locked/ latched during working hours and shall be free from obstruction. F:- During the class hours the class room door shall not be locked from inside to out side. G:- As per Honorable Supreme Court order all teachers and staff shall be trained to handle safety equipments, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14 th of every year by conducting Fire Safety drills with co-ordination with the fire services department.		

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Recommendation" to C.S. Tubachi Education Society's, Shri Kadasiddeshwar Public School, Hukkeri, Hukkeri Taluk, Belagavi District, subjected to condition and compliance of the above recommendations in column-4 of serial-B within 03 months and compliance to the undersigned.

This "Fire Safety Recommendation" is valid for only one year from the date of issue and is renewable.

Yours Faithfully

District Fire Officer 24/9/25
Karnataka State Fire And Emergency Services
Belagavi-01.

Copy to,
Fire Station Officer, Hukkeri.

PRINCIPAL
SHRI KADASHIDDESHWAR PUBLIC
SCHOOL, HUKKERI,
Dist: Belagavi KARNATAKA-591309

4

MANAGER
SHRI KADASHIDDESHWAR PUBLIC
SCHOOL HUKKERI
Dist BELAGAVI KARNATAKA 591309