

City of Greensboro — Planning & Development

300 W. Washington St., Greensboro, NC 27401

Date: March 10, 2026

Project: Riverside Mixed-Use Development

Permit #: SP-2026-0142

Review Round: 1st Review

SITE PLAN REVIEW COMMENTS — 1st Review

Applicant: Triad Development Group, LLC

Site Address: 2400 Riverside Dr, Greensboro, NC 27405

Reviewer: Sarah Mitchell, AICP — Senior Planner

ZONING COMMENTS

Z-1 [CRITICAL]: The proposed building setback of 12 feet on the eastern property line does not meet the minimum 20-foot setback required under Section 30-8-11.2 of the Land Development Ordinance for the CD-CU (Conditional District - Commercial Use) zoning classification. Revise site plan to show compliant setbacks or submit a variance request.

Z-2 [MAJOR]: Parking calculation sheet shows 245 spaces provided but the use mix (42,000 SF retail + 18 residential units) requires a minimum of 268 spaces per Table 30-8-12.1. Provide revised parking calculations or reduce commercial square footage.

Z-3 [MINOR]: Dumpster enclosure detail on Sheet C-4 does not show required 6-foot masonry screening wall per Section 30-8-14.3. Revise to include masonry enclosure with solid gate.

STORMWATER COMMENTS

SW-1 [CRITICAL]: Stormwater management plan does not address post-construction runoff requirements per the City of Greensboro Stormwater Management Manual Chapter 7. A BMP (Best Management Practice) design with calculations demonstrating compliance with nitrogen and phosphorus removal rates is required before approval.

SW-2 [MAJOR]: The proposed bioretention cell in the northwest corner of the site appears undersized. Provide drainage area calculations and demonstrate that the facility can handle the 1-year, 24-hour storm event per NCDEQ requirements.

SW-3 [MINOR]: Storm drain profile on Sheet C-6 shows a pipe slope of 0.3% for the 18-inch RCP connecting to the existing system. Minimum slope for this pipe diameter is 0.5%. Revise profile.

TRANSPORTATION COMMENTS

T-1 [MAJOR]: Traffic Impact Analysis (TIA) does not include the recently approved Wendover Commons project (approximately 350 trips in PM peak) within the study area. Revise TIA to include cumulative traffic impacts per NCDOT and City of Greensboro TIA guidelines.

T-2 [MINOR]: Proposed driveway on Riverside Dr is within 150 feet of the existing signalized intersection at Riverside/Elm. NCDOT driveway permit will require a minimum 200-foot separation. Relocate driveway or provide justification for reduced spacing.

Please address all comments and resubmit revised plans within 30 days.

Sarah Mitchell, AICP

Senior Planner, City of Greensboro