

City of Greensboro — Inspections Division

300 W. Washington St., Greensboro, NC 27401

Date: March 12, 2026

Project: Riverside Mixed-Use Development

Permit #: BP-2026-0089

Review Round: 1st Review

BUILDING PERMIT REVIEW COMMENTS

Reviewer: James Patterson, PE — Plans Examiner

Building Code: NC Building Code 2024 (based on IBC 2021)

BC-1 [CRITICAL]: Proposed Type V-A construction does not support the 4-story mixed-use occupancy as designed. Per NC Building Code Table 504.4, Type V-A construction is limited to 3 stories for Group M (mercantile) occupancies. Revise construction type to Type III-A minimum or reduce building height.

BC-2 [CRITICAL]: Fire-resistance rating for the floor/ceiling assembly separating residential (Group R-2) from commercial (Group M) occupancies must be 2-hour per Section 508.4. Construction documents show 1-hour assembly. Provide UL-listed 2-hour assembly details.

BC-3 [MAJOR]: Accessible route from public sidewalk to building entrance does not meet ADA slope requirements (max 1:20 for accessible route, 1:12 for ramps). Sheet A-2 shows a grade change of 30 inches over 20 feet (1:8 slope). Provide compliant accessible route with ramp and handrails per Section 1010.

BC-4 [MAJOR]: Egress calculations on Sheet A-5 do not account for the second-floor mezzanine occupant load. Recalculate total occupant load including mezzanine area and verify exit capacity meets Section 1005.1.

BC-5 [MINOR]: Structural calculations reference ASCE 7-16 for wind loads. NC Building Code 2024 requires ASCE 7-22. Revise wind load calculations to current standard. Note: Ground snow load for Guilford County is 10 psf per Fig. 7.2-1.

BC-6 [MINOR]: Mechanical room on Sheet M-1 does not show required clearances around electrical panels (36 inches per NEC 110.26). Verify clearances and dimension on revised plans.

James Patterson, PE

Plans Examiner, City of Greensboro Inspections