

City of Raleigh — Fire Prevention Bureau

222 W. Hargett St., Raleigh, NC 27601

Date: March 15, 2026

Project: Capital Blvd Commerce Center

Permit #: FP-2026-0231

Review Round: 2nd Review

FIRE PREVENTION REVIEW COMMENTS — 2nd Review

Reviewer: Lt. Maria Gonzalez — Fire Plans Examiner

Code: NC Fire Code 2024 / NFPA Standards

FP-1 [CRITICAL]: PREVIOUS COMMENT NOT ADDRESSED. Fire apparatus access road on the south side of Building B still shows a 16-foot travel width. NC Fire Code Section 503.2.1 requires minimum 20-foot unobstructed width. This was noted in 1st review comment FP-2. Revise immediately.

FP-2 [MAJOR]: Fire sprinkler hydraulic calculations for the 3rd floor warehouse area (NFPA 13, Ordinary Hazard Group 2) show a residual pressure of 18 psi at the base of the riser. Minimum required is 25 psi. Coordinate with water utility for flow test data and revise system design.

FP-3 [MAJOR]: Knox Box location shown on Sheet FP-1 is on the east elevation but the primary fire department connection (FDC) is on the west elevation. Relocate Knox Box to within 10 feet of the FDC per Raleigh Fire Department Policy 2024-03.

FP-4 [MINOR]: Emergency vehicle preemption signal at the Capital Blvd entrance is not shown on the civil plans. Coordinate with Raleigh Transportation for Opticom installation per site plan condition #7.

Note: Comment FP-1 is a repeat from 1st review. Per City policy, a third resubmission with unresolved critical comments may trigger a mandatory pre-submittal meeting.

Lt. Maria Gonzalez

Fire Plans Examiner, City of Raleigh