

# City of Greensboro — Stormwater & Environmental Services

300 W. Washington St., Greensboro, NC 27401

Date: March 8, 2026

Project: Lawndale Acres Subdivision

Permit #: ENV-2026-0067

Review Round: 1st Review

## ENVIRONMENTAL COMPLIANCE REVIEW

Reviewer: Dr. Kevin Zhao — Environmental Specialist

Site: 45.2 acres, Horsepen Creek watershed

**E-1 [CRITICAL]:** Phase I Environmental Site Assessment (ESA) identifies a Recognized Environmental Condition (REC) associated with the former dry cleaning operation at the northeast corner of the property. A Phase II ESA with soil and groundwater sampling is required before site plan approval per NCDEQ Brownfields Program guidelines.

**E-2 [CRITICAL]:** The proposed grading plan shows land disturbance within the 50-foot riparian buffer of Horsepen Creek. Per the Greensboro Watershed Protection Ordinance Section 30-6-7, no disturbance is permitted within Zone 1 (0-30 feet) and limited activity in Zone 2 (30-50 feet). Revise grading plan to eliminate buffer impacts or apply for a buffer variance through NCDEQ.

**E-3 [MAJOR]:** Erosion and sediment control plan does not include a construction sequence narrative as required by the NCDEQ Land Quality Section. Provide a phasing plan showing how sediment basins will be installed before mass grading begins.

**E-4 [MAJOR]:** Tree conservation analysis shows removal of 78% of existing canopy. Greensboro Tree Conservation Ordinance (Section 30-8-16) requires minimum 15% canopy preservation for commercial developments. Current plan preserves approximately 8%. Revise landscape plan or provide tree replacement calculations per the ordinance.

**E-5 [MINOR]:** Wetland delineation report is dated August 2023 — more than 2 years old. Per USACE guidance, a new delineation or written confirmation from the Corps that the previous delineation remains valid is required.

**Dr. Kevin Zhao**

Environmental Specialist, City of Greensboro