



TEST REPORT

ULR No.: **TC794426000000897F**

Page No. 1/2

Test Report No.	VC SPL/ENV/250326/007	Test Report Issue Date	10/04/2026
Date of sample Receipt	25/03/2026	Sample ID	VC SPL/ENV/250326/007
Name & Address of the Customer	M/s Jindal Stainless Limited Kalinga Nagar, Industrial Complex, Jajpur-755026, Odisha		
Sampling plan ref.No./ W.O No.	6200012932 Date : 07/08/2024		
Sample Details			
Sample Name	Stack Emission	Date of Sampling	23/03/2026
Sampling Location	Comboline DG (1050 KVA)		
Sample Description	Comboline DG		
Sample Source	Comboline DG		
Coordinates	Not Applicable		
Environment Condition During Sampling	30°C		
Sample Supplied/Collected by	VC SPL Representative		
Instrument used for Sampling	Stack kit, Flue gas Analyser		
Sampling Method/ Procedure	VC SPL/F-SOP/002		
Sample Condition	Sealed		
Sample Quantity	1 Nos		
Test started On	25/03/2026	Test Completed On	26/03/2026
1. General Information			
Emission Due to			
Material of Construction of Stack	Mild Steel		
Shape of Stack	Circular		
Whether Stack is Provide with Permanent Platform & Ladder	Yes		
2. Physical Characteristics of Stack			
Height of Stack from Ground Level	30.0 Mtr		
Diameter of Stack at Sampling Point	0.3 Mtr		
Height of the Sampling Point from Ground Level	10.0 Mtr		
Area of Stack			
3. Characteristic of Stack			
Fuel Used	Disel		
Fuel Consumption	25/hr		
4. Pollution			
Details of Pollution Control Device Attached with the Stack	--		

TEST RESULTS

Group Name		Atmospheric Pollution		Discipline	Chemical	
S.No.	Test Parameter	Units	Test Method	Standards "As Per CTO"		Result
1	Particulate Matter (as PM)	mg/Nm³	IS 11255 (Part - 1) : 1985	100		26.6
2	Oxides of Nitrogen (as NO2.)	mg/m³	USEPA Method -7E : 2017	-		17.0
3	Sulphur Dioxide (as SO2.)	mg/m³	USEPA Method -6C : 2017	-		16.0
4	Carbon Dioxide (as CO2)	%	USEPA Method -3A : 2017	-		2.5



TEST REPORT

ULR No.: **TC794426000000897F**

Page No. 2/2


Test Report No.	VC SPL/ENV/250326/007	Test Report Issue Date	10/04/2026
Date of sample Receipt	25/03/2026	Sample ID	VC SPL/ENV/250326/007

TEST RESULTS

Group Name		Atmospheric Pollution		Discipline	Chemical	
S.No.	Test Parameter	Units	Test Method	Standards "As Per CTO"		Result
5	Oxygen (as O2)	%	USEPA Method -3A : 2017	-		17.5
6	Temperature	° C	IS 11255 (Part - 3) : 2008	-		128
7	Velocity	m/sec	IS 11255 (Part - 3) : 2008	-		16.63
8	Flow Rate	Nm³/hr	IS 11255 (Part - 3) : 2008	-		3068.5

BLQ= Below Limit of Quantification.

Remarks :



Koushik Nag
Technical Manager

Review by



Priyanka Pati
Dy. Technical Manager (Env)
Authorized Signatory

Terms and Conditions:-

1. The Test result is relevant only to the item tested.
2. This report shall not be reproduced in full or part without written approval of Visiontek consultancy services(P) Ltd.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory's responsibility under this report is limited to; proven willful negligence.
6. Decision rule applied whenever the requirements/specification provided by customers/standard requirement.
7. The data and information (i.e. 1 to 4) identified and provided by the customer, the laboratory did not provide the data & information required for the test report.

Disclaimer : In the case of samples provided by the customer, the results apply to the sample as received.

End of Report



TEST REPORT

ULR No.: TC794426000000902F

Page No. 1/2

Test Report No.	VC SPL/ENV/250326/012	Test Report Issue Date	10/04/2026
Date of sample Receipt	25/03/2026	Sample ID	VC SPL/ENV/250326/012
Name & Address of the Customer	M/s Jindal Stainless Limited Kalinga Nagar, Industrial Complex, Jajpur-755026, Odisha		
Sampling plan ref.No./ W.O No.	6200012932 Date : 07/08/2024		
Sample Details			
Sample Name	Stack Emission	Date of Sampling	24/03/2026
Sampling Location	HAPL DG (1050 KVA)		
Sample Description	HAPL DG		
Sample Source	HAPL DG		
Coordinates	Not Applicable		
Environment Condition During Sampling	30°C		
Sample Supplied/Collected by	VC SPL Representative		
Instrument used for Sampling	Stack kit, Flue gas Analyser		
Sampling Method/ Procedure	VC SPL/F-SOP/002		
Sample Condition	Sealed		
Sample Quantity	1 Nos		
Test started On	25/03/2026	Test Completed On	26/03/2026
1. General Information			
Emission Due to	Burning Of diesel		
Material of Construction of Stack	Mild Steel		
Shape of Stack	Circular		
Whether Stack is Provide with Permanent Platform & Ladder	Yes		
2. Physical Characteristics of Stack			
Height of Stack from Ground Level	30 Mtr		
Diameter of Stack at Sampling Point	0.4 Mtr		
Height of the Sampling Point from Ground Level	15 Mtr		
Area of Stack	--		
3. Characteristic of Stack			
Fuel Used	diesel		
Fuel Consumption	24 L/hr		
4. Pollution			
Details of Pollution Control Device Attached with the Stack	--		

TEST RESULTS

Group Name	Atmospheric Pollution		Discipline	Chemical	
S.No.	Test Parameter	Units	Test Method	Standards "As Per CTO"	Result
1	Particulate Matter (as PM)	mg/Nm ³	IS 11255 (Part - 1) : 1985	100	27.3
2	Oxides of Nitrogen (as NO ₂ .)	mg/m ³	USEPA Method -7E : 2017	-	74
3	Sulphur Dioxide (as SO ₂ .)	mg/m ³	USEPA Method -6C : 2017	-	18
4	Carbon Dioxide (as CO ₂)	%	USEPA Method -3A : 2017	-	4.5



TEST REPORT

ULR No.: **TC794426000000902F**

Page No. 2/2


Test Report No.	VC SPL/ENV/250326/012	Test Report Issue Date	10/04/2026
Date of sample Receipt	25/03/2026	Sample ID	VC SPL/ENV/250326/012

TEST RESULTS

Group Name		Atmospheric Pollution		Discipline	Chemical	
S.No.	Test Parameter	Units	Test Method	Standards "As Per CTO"		Result
5	Oxygen (as O2)	%	USEPA Method -3A : 2017	-		16.1
6	Temperature	° C	IS 11255 (Part - 3) : 2008	-		125
7	Velocity	m/sec	IS 11255 (Part - 3) : 2008	-		19.05
8	Flow Rate	Nm³/hr	IS 11255 (Part - 3) : 2008	-		3597

BLQ= Below Limit of Quantification.

Remarks :



Koushik Nag
Technical Manager

Review by



Priyanka Pati
Dy. Technical Manager (Env)
Authorized Signatory

Terms and Conditions:-

1. The Test result is relevant only to the item tested.
2. This report shall not be reproduced in full or part without written approval of Visiontek consultancy services(P) Ltd.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory's responsibility under this report is limited to; proven willful negligence.
6. Decision rule applied whenever the requirements/specification provided by customers/standard requirement.
7. The data and information (i.e. 1 to 4) identified and provided by the customer, the laboratory did not provide the data & information required for the test report.

Disclaimer : In the case of samples provided by the customer, the results apply to the sample as received.

End of Report



TEST REPORT

ULR No.: TC794426000000903F

Page No. 1/2

Test Report No.	VC SPL/ENV/250326/013	Test Report Issue Date	10/04/2026
Date of sample Receipt	25/03/2026	Sample ID	VC SPL/ENV/250326/013
Name & Address of the Customer	M/s Jindal Stainless Limited Kalinga Nagar, Industrial Complex, Jajpur-755026, Odisha		
Sampling plan ref.No./ W.O No.	6200012932 Date : 07/08/2024		
Sample Details			
Sample Name	Stack Emission	Date of Sampling	24/03/2026
Sampling Location	CAPL DG (1050 KVA)		
Sample Description	CAPL DG		
Sample Source	CAPL DG		
Coordinates	Not Applicable		
Environment Condition During Sampling	30°C		
Sample Supplied/Collected by	VC SPL Representative		
Instrument used for Sampling	Stack kit, Flue gas Analyser		
Sampling Method/ Procedure	VC SPL/F-SOP/002		
Sample Condition	Sealed		
Sample Quantity	1 Nos		
Test started On	25/03/2026	Test Completed On	26/03/2026
1. General Information			
Emission Due to	Buirning Of diesel		
Material of Construction of Stack	Mild Steel		
Shape of Stack	Circular		
Whether Stack is Provide with Permanent Platform & Ladder	Yes		
2. Physical Characteristics of Stack			
Height of Stack from Ground Level	30 Mtr		
Diameter of Stack at Sampling Point	0.4 Mtr		
Height of the Sampling Point from Ground Level	15 Mtr		
Area of Stack	--		
3. Characteristic of Stack			
Fuel Used	diesel		
Fuel Consumption	24 L/hr		
4. Pollution			
Details of Pollution Control Device Attached with the Stack	--		

TEST RESULTS

Group Name		Atmospheric Pollution		Discipline	Chemical	
S.No.	Test Parameter	Units	Test Method	Standards "As Per CTO"		Result
1	Particulate Matter (as PM)	mg/Nm³	IS 11255 (Part - 1) : 1985	100		23.7
2	Oxides of Nitrogen (as (NO2.)	mg/m³	USEPA Method -7E : 2017	-		24
3	Sulphur Dioxide (as SO2.)	mg/m³	USEPA Method -6C : 2017	-		10
4	Carbon Dioxide (as CO2)	%	USEPA Method -3A : 2017	-		2.6



TEST REPORT

ULR No.: TC794426000000903F

Page No. 2/2


Test Report No.	VCSP/ENV/250326/013	Test Report Issue Date	10/04/2026
Date of sample Receipt	25/03/2026	Sample ID	VCSP/ENV/250326/013

TEST RESULTS

Group Name		Atmospheric Pollution		Discipline	Chemical	
S.No.	Test Parameter	Units	Test Method	Standards "As Per CTO"		Result
5	Oxygen (as O2)	%	USEPA Method -3A : 2017	-		17.8
6	Temperature	° C	IS 11255 (Part - 3) : 2008	-		115
7	Velocity	m/sec	IS 11255 (Part - 3) : 2008	-		7.34
8	Flow Rate	Nm³/hr	IS 11255 (Part - 3) : 2008	-		1420.8

BLQ= Below Limit of Quantification.

Remarks :



Koushik Nag
Technical Manager

Review by



Priyanka Pati
Dy. Technical Manager (Env)
Authorized Signatory

Terms and Conditions:-

1. The Test result is relevant only to the item tested.
2. This report shall not be reproduced in full or part without written approval of Visiontek consultancy services(P) Ltd.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory's responsibility under this report is limited to; proven willful negligence.
6. Decision rule applied whenever the requirements/specification provided by customers/standard requirement.
7. The data and information (i.e. 1 to 4) identified and provided by the customer, the laboratory did not provide the data & information required for the test report.

Disclaimer : In the case of samples provided by the customer, the results apply to the sample as received.

End of Report



TEST REPORT


ULR No.: **TC794426000000834F**

Page No. 1/1

Test Report No.	VC SPL/ENV/300326/028	Test Report Issue Date	04/04/2026
Date of sample Receipt	25/03/2026	Sample ID	VC SPL/ENV/300326/028
Name & Address of the Customer	M/s Jindal Stainless Limited Kalinga Nagar, Industrial Complex, Jajpur-755026, Odisha		
Sampling plan ref.No./ W.O No.	6200012932, Date : 07/08/2024		
Sample Details			
Sample Name	Source Noise	Date of Sampling	23/03/2026
Sampling Location	DG Set - 1050 KVA		
Sample Description	CRM - Comboline		
Sample Source	DG Set - CRM Comboline		
Coordinates	Not Applicable		
Environment Condition During Sampling	28°C, RH-40%		
Sample Supplied/Collected by	VC SPL Representative		
Instrument used for Sampling	Sound Level Meter		
Sampling Method/ Procedure	VC SPL/F-SOP/005		
Sample Condition	Sealed		
Sample Quantity	1 Nos		
Test started On	25/03/2026	Test Completed On	27/03/2026

TEST RESULTS

Group Name		Atmospheric Pollution		Discipline	Chemical	
S.No.	Test Parameters	Units	Testing Methods	Specification given as per CPCB Protocol for Noise Monitoring: 2000		Results
1	Noise Level (Leq.)	dB (A)	IS 4758 : 1968	--		81.6



Koushik Nag
Technical Manager
Review by



Priyanka Pati
Dy. Technical Manager (Env)
Authorized Signatory

Terms and Conditions:-

1. The Test result is relevant only to the item tested.
2. This report shall not be reproduced in full or part without written approval of Visiontek consultancy services(P) Ltd.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory's responsibility under this report is limited to; proven willful negligence.
6. Decision rule applied whenever the requirements/specification provided by customers/standard requirement.

Disclaimer : In the case of samples provided by the customer, the results apply to the sample as received.

End of Report



TEST REPORT


ULR No.: **TC794426000000838F**

Page No. 1/1

Test Report No.	VCSPL/ENV/300326/032		Test Report Issue Date	04/04/2026
Date of sample Receipt	26/03/2026		Sample ID	VCSPL/ENV/300326/032
Name & Address of the Customer	M/s Jindal Stainless Limited Kalinga Nagar, Industrial Complex, Jajpur-755026, Odisha			
Sampling plan ref.No./ W.O No.	6200012932, Date : 07/08/2024			
Sample Details				
Sample Name	Source Noise		Date of Sampling	24/03/2026
Sampling Location	DG Set - 1050 KVA			
Sample Description	CRM - CAPL			
Sample Source	DG Set - CRM			
Coordinates	Not Applicable			
Environment Condition During Sampling		28°C, RH-40%		
Sample Supplied/Collected by		VCSPL Representative		
Instrument used for Sampling		Sound Level Meter		
Sampling Method/ Procedure		VCSPL/F-SOP/005		
Sample Condition		Sealed		
Sample Quantity		1 Nos		
Test started On		26/03/2026	Test Completed On	28/03/2026

TEST RESULTS

Group Name		Atmospheric Pollution		Discipline	Chemical	
S.No.	Test Parameters	Units	Testing Methods	Specification given as per CPCB Protocol for Noise Monitoring: 2000		Results
1	Noise Level (Leq.)	dB (A)	IS 4758 : 1968	--		83.5



Koushik Nag
Technical Manager
Review by



Priyanka Pati
Dy. Technical Manager (Env)
Authorized Signatory

Terms and Conditions:-

1. The Test result is relevant only to the item tested.
2. This report shall not be reproduced in full or part without written approval of Visiontek consultancy services(P) Ltd.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory's responsibility under this report is limited to; proven willful negligence.
6. Decision rule applied whenever the requirements/specification provided by customers/standard requirement.

Disclaimer : In the case of samples provided by the customer, the results apply to the sample as received.

End of Report



TEST REPORT


ULR No.: **TC794426000000837F**

Page No. 1/1

Test Report No.	VCSPL/ENV/300326/031	Test Report Issue Date	04/04/2026
Date of sample Receipt	26/03/2026	Sample ID	VCSPL/ENV/300326/031
Name & Address of the Customer	M/s Jindal Stainless Limited Kalinga Nagar, Industrial Complex, Jajpur-755026, Odisha		
Sampling plan ref.No./ W.O No.	6200012932, Date : 07/08/2024		
Sample Details			
Sample Name	Source Noise	Date of Sampling	24/03/2026
Sampling Location	DG Set - 1050 KVA		
Sample Description	CRM - HAPL		
Sample Source	DG Set - CRM		
Coordinates	Not Applicable		
Environment Condition During Sampling	28°C, RH-40%		
Sample Supplied/Collected by	VCSPL Representative		
Instrument used for Sampling	Sound Level Meter		
Sampling Method/ Procedure	VCSPL/F-SOP/005		
Sample Condition	Sealed		
Sample Quantity	1 Nos		
Test started On	26/03/2026	Test Completed On	28/03/2026

TEST RESULTS

Group Name		Atmospheric Pollution		Discipline	Chemical	
S.No.	Test Parameters	Units	Testing Methods	Specification given as per CPCB Protocol for Noise Monitoring: 2000		Results
1	Noise Level (Leq.)	dB (A)	IS 4758 : 1968	--		82.8



Koushik Nag
Technical Manager
Review by



Priyanka Pati
Dy. Technical Manager (Env)
Authorized Signatory

Terms and Conditions:-

1. The Test result is relevant only to the item tested.
2. This report shall not be reproduced in full or part without written approval of Visiontek consultancy services(P) Ltd.
3. The laboratory is not responsible for the authenticity of photocopied test report.
4. The test item will not be retained for more than 15 days from the date of issue of test report except in case as required by applicable regulations.
5. The laboratory's responsibility under this report is limited to; proven willful negligence.
6. Decision rule applied whenever the requirements/specification provided by customers/standard requirement.

Disclaimer : In the case of samples provided by the customer, the results apply to the sample as received.

End of Report