



To,
ICICI Lombard General Insurance Company LTD
ICICI LOMBARD HOUSE, 414, Veer Savarkar Marg, Near
Siddhi Vinayak Temple, Prabhadevi, Mumbai 400 025
Our Ref No.: 15210/ICICI/1920

Kind Attn: Mr. K K Chaithanya

Date: 18th December 2019

IMMEDIATE LOSS ADVICE

DATE OF LOSS	:	15 th December 2019 as informed
DATE OF INSTRUCTION FROM INSURER	:	16 th December 2019
DATE OF VISIT	:	17 th December 2019
LOCATION OF LOSS, WITH PIN CODE	:	Office No A 203 Teerth Technospace Near Mercedes Showroom Pune, Pune, Maharashtra Pin- 411045
PERSON CONTACTED	:	Mrs. Sayali Kedar 7774078672
NAME OF POLICY	:	Standard Fire And Special Perils Insurance
POLICY NO	:	1001/186842890/00/000
CLAIM NO	:	FIR008095195
NAME OF INSURED	:	Canwill Technologies Pvt Ltd
AFFECTED ITEM	:	Furniture, Fixtures and Fittings Electrical Fittings :
CIRCUMSTANCE OF LOSS	:	During our visit on 17 th December 2019 Ms. Sayali Kedar conducted us narrated the fire incident which took place on 15 th Dec 2019 abrround 09:15 pm. As reported Office was closed due to Sunday (Weekly Holiday). Insured Ms. Sayali Kedar received a call from their neighbor office M/s. VDA solution pvt. ltd regarding fire and immediately insured rushed to office. Fire brigade was also called by security to extinguish the fire. After opening the shutter, it was completely full of soot everywhere and sprinkler system was activated automatically. Fire brigade inspect the premises and it was confirmed that the fire got extinguished by the sprinklers. The water supply to sprinklers was OFF. Simultaneously other three directors of the firms were also reached at the

		premises. FIR lodged with the concern area police station. Due to sprinkler system water spreaded all over the premises on work places as wel as on the equipments and floor. The water inundation level was around 3 inches.
NATURE AND EXTENT OF DAMAGE	:	Furniture, Fixtures and Fittings: 1) Chairs and wrokdesk, Sofa sets, Cabin partition heat & soot affected and partially burnt. Electrical Fittings : 2) Electrical wiring and sockets below work desk, Server,Light fittings damaged and water affected.
SUPPOSED CAUSE	:	Probably due to short circuit near UPS
RESERVE	:	Rs. 4,00,000/-
BASIS OF RESERVE	:	As per our inspection at premises.
DOES LOSS NEEDS FURTHER DISCUSSION WITH INSURER	:	Not required
STATUS		Insured advised to submit the required documents and proof of evidences such as CCTV footage as per the mail.

Kamleshgani



K R BIYANI

License No. SLA 34365 valid till 27.11.2022







