



To,  
ICICI Lombard General Insurance Company LTD  
ICICI LOMBARD HOUSE, 414, Veer Savarkar Marg, Near  
Siddhi Vinayak Temple, Prabhadevi, Mumbai 400 025  
**Our Ref No.:** 15207/ICICI/1920

**Kind Attn:** Mr. K K Chaitanya

**Date:** 18<sup>th</sup> December 2019

**IMMEDIATE LOSS ADVICE**

<b>DATE OF LOSS</b>	:	15 <sup>th</sup> December 2019 as informed
<b>DATE OF INSTRUCTION FROM INSURER</b>	:	16 <sup>th</sup> December 2019
<b>DATE OF VISIT</b>	:	17 <sup>th</sup> December 2019
<b>LOCATION OF LOSS, WITH PIN CODE</b>	:	Office No A 203 Teerth Technospace Near Mercedes Showroom Pune, Pune, Maharashtra Pin- 411045
<b>PERSON CONTACTED</b>	:	Ms. Sayali Kedar 7774078672
<b>NAME OF POLICY</b>	:	Standard Fire And Special Perils Insurance
<b>POLICY NO</b>	:	1001/158084335/01/000
<b>CLAIM NO</b>	:	FIR008096201
<b>NAME OF INSURED</b>	:	Niveza India Pvt Ltd
<b>AFFECTED ITEM</b>	:	<b>Building:.</b> <b>Furniture, Fixtures and Fittings:</b> <b>Electrical Fittings :</b>
<b>CIRCUMSTANCE OF LOSS</b>	:	During our visit on 17 <sup>th</sup> December 2019 Ms. Sayali Kedar conducted us narrated the fire incident which took place on 15 <sup>th</sup> Dec 2019 around 09:15 pm. As reported Office was closed due to Sunday (Weekly Holiday). Insured Ms. Sayali Kedar received a call from their neighbor office M/s. VDA solution pvt. Ltd regarding fire and immediately insured rushed to office. Fire brigade was also called by security to extinguish the fire. After opening the shutter, it was completely full of soot everywhere and sprinkler system was activated automatically. Fire brigade inspect the premises and it was confirmed that the fire got extinguished by the sprinklers. The water supply to sprinklers was OFF. Simultaneously other three

		directors of the firms were also reached at the premises. FIR lodged with the concern area police station. Due to sprinkler system water spreaded all over the premises on work places as wel as on the equipments and floor. The water inundation level was around 3 inches.
<b>NATURE AND EXTENT OF DAMAGE</b>	:	<b>Building:</b> 1) Internal wall Painting, Windows glass panels,False ceiling affected due to Soot. <b>Furniture, Fixtures and Fittings:</b> 2) Chairs and wrokdesk, Sofa sets, Cabin partition heat & soot affected and partially burnt. <b>Electrical Fittings :</b> 3) Electrical wiring and sockets below work desk, Server damaged and water affected.
<b>SUPPOSED CAUSE</b>	:	Probably due to short circuit near UPS
<b>RESERVE</b>	:	Rs. 4,00,000/-
<b>BASIS OF RESERVE</b>	:	As per our inspection at premises.
<b>DOES LOSS NEEDS FURTHER DISCUSSION WITH INSURER</b>	:	Not required
<b>STATUS</b>		Insured advised to submit the required documents and proof of evidences such as CCTV footage as per the mail.

*Karimallyani*



**K R BIYANI**

License No. SLA 34365 valid till 27.11.2022











