

**nathanf@live.com**

---

**From:** nathanf <nathanf@live.com>  
**Sent:** Friday, October 03, 2014 1:51 PM  
**To:** nathanf@live.com  
**Subject:** SEND: FW: TECH: COMPLEX: Rules and PLC protocol he was coming up with dynamically. PRINT: FW: OnCommSuccess?  
**Attachments:** config.csv  
**Importance:** High

---

**From:** Fritsche, Nathan [mailto:nathan.fritsche@digi.com]  
**Sent:** Sunday, March 30, 2014 4:54 PM  
**To:** nathanf@live.com  
**Subject:** TECH: COMPLEX: Rules and PLC protocol he was coming up with dynamically. PRINT: FW: OnCommSuccess?  
**Importance:** High

---

**From:** Fritsche, Nathan  
**Sent:** Thursday, May 23, 2013 6:55 PM  
**To:** [REDACTED]  
**Subject:** RE: OnCommSuccess?

Hello Mike. I have left everything like it was (no additions or changes made to the CSV made).

I hope you didn't already change the spec! (Note: Attaching a copy of the "config.csv" file that I'm using.)

---

**From:** [REDACTED]  
**Sent:** Thursday, May 23, 2013 3:13 PM  
**To:** Fritsche, Nathan  
**Subject:** Re: OnCommSuccess?

Sounds good....run with it!

mike

---

**From:** "Fritsche, Nathan" <nathan.fritsche@digi.com>  
**To:** [REDACTED]  
**Sent:** Thursday, May 23, 2013 1:59 PM  
**Subject:** RE: OnCommSuccess?

Hello Mike.

I think we should use the keyword 'any'. It adds a descriptive value to the action taken after comparing plc responses ( vs another scenario where an empty string may really mean, an empty string.)

I also agree and think we should change onCommSuccess to 'next'. My code handles it either way, so it's just a matter of changing the config file. (Which i will do on my device as well).

FWIW, i think you did a great job coming up with the ideas for this application!

Nathan Fritsche  
iDigi Systems Engineer  
Digi International  
1-877-912-3444

---

From: [REDACTED]  
Sent: 5/23/2013 1:01 PM  
To: Fritsche, Nathan  
Subject: Re: OnCommSuccess?

A code rule to follow is that if onSuccessVAL is not defined , , then any value other than the onNullVAL & onErrorVAL are valid.

Another code rule to follow is that if the value returned from the PLC does not = onNullVAL, onErrorVAL or onSuccessVAL then do whatever onCommSuccess says to do.

So, there should be no comparison when onSuccessVAL = "" ....null, nil, nada, string.empty()  
Same holds true for onNullVAL & onErrorVAL, i.e. do not compare returned PLC value when a comparison property (onNullVAL, onErrorVAL, onSuccessVAL) is equal "" ....null, nil, nada, string.empty(), or in other words is NOT DEFINED.

Would your logic work better if we used the keyword "Any", so that we would proactively (set in our config file) onSuccessVAL = "Any" ....which would mean ANY returned val is acceptable (as long as it does not = onNullVAL or onErrorVAL) .....essentially that is what is meant by an UNDEFINED entry, i.e. no comparison required.

So an entry like:

LOGDFN, 11, 000103F8, 0, end, 9999, end, , , end, end, onEveryScan, , , .....Would become:  
LOGDFN, 11, 000103F8, 0, end, 9999, end, Any, next, end, end, onEveryScan, , ,

.....oohhh, perhaps the problem is that I have defined (in the rule above) that onCommSuccess = end? So, perhaps the rules above need to change onCommSuccess = next  
So, the entries would need to change as shown below:

So an entry like:

LOGDFN, 11, 000103F8, 0, end, 9999, end, , , next, end, onEveryScan, , , .....Would become:  
LOGDFN, 11, 000103F8, 0, end, 9999, end, Any, next, next, end, onEveryScan, , ,

So, yes there could be a logic error (in my head) there! That's what happens when you code, compile & run....tests how straight you head was turned on when writing the spec...

Let me know which methodology will work best with the code logic....and I will update the doc(s).

mike

---

From: [REDACTED] >  
To: [REDACTED]

Co [REDACTED]  
Sent: Thursday, May 23, 2013 9:40 AM  
Subject: RE: OnCommSuccess?

Thanks Mike.

This is how I originally had the script designed.

However, regarding LOGDFN, the spec states that if "onSuccessVAL" == "", I am to append to the filename the value read in from the PLC register.

This part is working just fine.

However, once I read in that value and compare it to "", it will fail that comparison, even though I have a valid reading (for instance, "34" from the PLC.)

Perhaps I need to rethink my logic here, but what I was seeing is that it would fail the "onSuccessVAL" comparison and default to the "onCommSuccess" rule, which tells it to go to 'end', ignoring the value read from the PLC.

The result is that when I use "onCommSuccess" as specified, my filename does not include the value read from the PLC. Using the Modbus simulator and programming registers accordingly, I am getting the desired output, but that is only when I take out the check for "onSuccessVAL".

Filename="3FS\_3251-31;32;33;34.csv"

Thoughts? Call anytime,  
Thanks.

Nathan Fritsche  
Digi International  
[REDACTED]

From [REDACTED]  
Sent: Thursday, May 23, 2013 10:09 AM  
To: Fritsche, Nathan  
Subject: Re: OnCommSuccess?

Great....glad to hear!

Defined in "Control Dynamics Specification Overview.docx"  
Another code rule to follow is that if the value returned from the PLC does not = onNullVAL, onErrorVAL or onSuccessVAL then do whatever onCommSuccess says to do.

Mainly used when we do a "Write" to the PLC, i.e. when executing a LOGDFNE rule.

From: [REDACTED]  
To: [REDACTED]

  
Sent: Thursday, May 23, 2013 8:19 AM  
Subject: OnCommSuccess?

Mike, thanks for sending that information.

Shortly after you sent me the license, I was able to query the PLC and use that information to set up my Modbus slave.

I have a question regarding “onCommSuccess”.

Will this be needed since technically, “onCommSuccess” will be “True” anytime I get response from the serial port, in which case I’ll already be comparing to onNullVAL, onErrorVAL and onSuccessVAL?

I can see using “onCommError”, but wondering what your thoughts were for using the “onCommSuccess” class member.

(Let’s say I get back “9999”, which compares to “onNullVAL”. Since serial communication was successful, which rule would I execute?)

Thanks!  
Nathan Fritsche  
Device Cloud Systems Engineer  
Digi International  
877.912.3444