


- NOTES
1. ALL LINES TO FREE DRAIN WITH NO POCKETS, AND A MINIMUM SLOPE OF 1:100
  2. BLOC/DE INJECTION POINT
  3. DELETED
  4. FLUSHING CONNECTION
  5. VALVE NOT TO BE USED WHILE CLOSED DRAINS SYSTEM IS IN OPERATION
  6. DELETED
  7. DELETED
  8. REDUNDANT SECTION OF LINE
  9. FUTURE TIE-IN FOR GAS IMPORT FACILITIES


ONLY ACTIVATED TRACE HEATING IS SHOWN ON P & ID, ALL OTHER INSTALLED TRACE HEATING IS NOT ACTIVATED AND NOT SHOWN ON P & ID.

REFERENCE DRAWINGS									
DRG.No.	REV	TITLE							
			16	AS BUILT PER SEQ1507	24/08/11	AC	AW	AW	NW
			15	AS BUILT UNDER S1227	28/11/14	MG	GM	GM	IMB
			29	AS BUILT FOR SMOC2025	21/03/20	LM	LM	JL	JL
			28	AS BUILT FOR SMOC2025	01/14/20	JL	JL	LM	JL
			27	AS-BUILT FOR SMOC1952	13/01/20	IMS	JL	JL	TF
			26	AS-BUILT FOR SMOC1952	27/05/19	LM	LM	LM	JL
			REV	REASON FOR ISSUE	DATE	DRN.	CKD.	BY ENG	ENG CKD.

25	AS-BUILT FOR SMOC1860	01/11/17	DD	LM	LM	SB	SB	TR
Z4	AS-BUILT FOR SMOC1860	20/03/17	DD	LM	LM	JL	JL	TR
Z3	AS-BUILT FOR SMOC1860	19/02/16	DD	LM	LM	AH	AH	TR
Z2	AS-BUILT FOR SMOC1860	21/10/16	ppLM	LM	LM	AH	AH	TR
Z1	AS-BUILT FOR SEQ1470	22/10/15	DD	LM	LM	PP JL	PP JL	PA
17	AS BUILT PER SEQ1470 (CS-WP-11)	06/02/14	KD	SAW		AB		TR
REV	REASON FOR ISSUE	DATE	DRN.	CKD.	BY ENG	ENG CKD.	L.E. APPD	CNOOC APPD



THIS IS A C.A.D PRODUCED DRAWING AND SHOULD NOT BE MANUALLY MODIFIED

<b>SCOTT</b>											
TITLE		PIPING & INSTRUMENT DIAGRAM CLOSED DRAINS COLLECTION HEADERS DP									
DRAWING No.		SCOTT-FW-0000-PR-PD-0119-02								Z9	NTS
PROJECT	ORG	AREA/MOD	DISC	TYPE	SEQ. No.	SHT.	REV	SCALE			