



| P - 8312A DIAPHRAGM PUMP | | P - 8320A DIAPHRAGM PUMP | |
|-----------------------------|---------------------|-----------------------------|---------------------|
| Manufacturer | : PROMINENT | Manufacturer | : PROMINENT |
| Type | : EXBBG1601NS30A701 | Type | : EXBBG1601PP10A701 |
| Dimensions | : 391x144x229 mm | Dimensions | : 391x144x229 |
| Work Press. | : 5 Barg | Work Press. | : 5 Barg |
| Material | : PVC | Material | : PP |
| Design pressure | : 16 Barg | Design pressure | : 16 Barg |
| Design temp. | : 50°C | Design temp. | : 50°C |
| Capacity | : 1.1 l/hr | Capacity | : 1.1 l/hr |

| Nexen Petroleum (U.K.) Limited | | | | | |
|--|----------|-----------------------|------------------|------|-------------|
| VENDOR : HATENBOER-WATER (WORLEY PARSONS) | | | | | |
| EQUIPMENT TITLE : FRESH WATER MAKER PACKAGE | | | | | |
| EQUIPMENT TAG NO(S) : X-8301 | | | | | |
| Vendor Document Number | | | | | |
| Purchase Order No | | Doc Type Code | Seq. Sheet No | Rev. | DATE |
| 168397 - 200 - PO - 3372 - MC2 - 001 - 04 | | | | Z1 | 18/10/18 |
| SUPPLIER DOCUMENT REVIEW | | | | | |
| Rejected (Assai Code - REJ) - Quality and content is out of conformity with Company requirements. Document shall be revised by Supplier to incorporate the necessary changes and subsequently re-submitted. | | | | | |
| Accepted With Comments (Assai Code - AWC) - Generally acceptable but elements require to be addressed. Document shall be revised by Supplier to incorporate the necessary changes and subsequently re-submitted. | | | | | |
| Accepted As Final (Assai Code - FIN) - Documents are considered acceptable, do not re-submit. | | | | | |
| Accepted For Information (Assai Code - AFI) - No further action required, do not re-submit. | | | | | |
| Review of Vendor documents does not relieve Vendor of the responsibility for correctness under the Purchase Order. Permission to proceed does not constitute acceptance of design, detail and calculations, test methods or materials developed or selected by the Vendor and does not relieve the Vendor from full compliance with the Purchase Order or any other obligations, nor detract from any of the Purchaser's rights. | | | | | |
| Z1 | 18/10/18 | AS-BUILT FOR GMCC0331 | | WAT | AK |
| REV | DATE | DESCRIPTION | | DRN | CHK APP CLT |

Nexen Petroleum U.K. Limited
Golden Eagle Area Development

Vendor: Hatenboer-Water BV
Equipment title: Fresh Water Maker Package
Equipment tag NO(S): X-8301

GEAD Document Number

| PO Number | Doc Type Code | Seq. No | Rev. | Date |
|--------------------|---------------|---------|------|------------|
| 168397-200-PO-3372 | MC2 | 001 | 10 | 13/10/2018 |

INCLUDES DOC CODES: TOTAL SHEETS: 16

| F | Final (accepted) - Manufacturing may proceed. | |
|---|---|--|
| A | Qualified Release - review and re-submit. Manufacturing may proceed subject to incorporation of comments. | |
| R | Rejected - review and re-submit. Manufacturing may not proceed. | |
| I | Accepted for information only. | |

Review of Vendor documents does not relieve Vendor of the responsibility for correctness under the Purchase Order. Permission to proceed does not constitute acceptance of design, detail and calculations, test methods or materials developed or selected by the Vendor and does not relieve the Vendor from full compliance with the Purchase Order or any other obligations, nor detract from any of the Purchaser's rights.

Engineer: _____ Date: _____

NOTES

Note 1: X-8312A = Canister chemicals not to be diluted
Note 2: X-8320A = Canister chemicals not to be diluted
Note 3: P 8312A and P 8320A contains an integrated PSV
Note 4: Cartridgefilter to be vented with screwcap at top

| REV | DATE | DESCRIPTION | DRN | CHK | APP | CLT |
|-----|----------|----------------|-----|-----|-----|-----|
| 9 | 27-06-13 | ASBUILD | PR | LDG | PJ | |
| 8 | 06-05-13 | ASBUILD | PR | LDG | PJ | |
| 7 | 06-02-13 | ASBUILD | PR | LDG | PJ | |
| 6 | 14-11-12 | ASBUILD | PR | LDG | PJ | |
| 5 | 24-10-12 | AFTER COMMENTS | PR | LDG | PJ | |
| 4 | 06-07-12 | AFTER COMMENTS | MdV | RU | LdG | |
| 3 | 05-03-12 | AFTER COMMENTS | MdV | RU | LdG | |
| 2 | 18-01-12 | AFTER COMMENTS | AO | RU | LDG | |
| 1 | 16-11-11 | REV 1 | RM | RU | LDG | |
| 0 | 14-09-11 | FIRST ISSUE | AK | RU | LDG | |

DRAWING INFORMATION:
P&ID: 4
Description: Chemical Dosing RO-A
Drawn by: renmic
Date: 27/09/2018

HATENBOER-WATER

PROJECT INFORMATION:
Project: 458058
Client: Nexen
Client Ref: Package Golden Eagle
Description: PO 3372

Drawing number: _____ Sheet: 4/16 Rev: 9