


Dryer X-5502				
TP no.	Size	Connection	Service	
TP1	4"	150# ANSI B16.5 RF	Inlet wet air	
TP2	4"	150# ANSI B16.5 RF	Outlet dried air	
TP3	4"	150# ANSI B16.5 RF	Outlet regeneration air	
TP4	4"	150# ANSI B16.5 RF	Outlet regeneration air	
TP5	1 1/2"	150# ANSI B16.5 RF	Outlet drain prefilterers	

SCOPE OF SUPPLY



Notes

- 1 Actuated ball valves (XV) shall be provided with open (XZSO) and closed (XZSC) limit switches
- 2 Provided with weep hole Ø8mm
- 3 Vent to discharge locally within package limits
- 4 Lockable globe valves; for commissioning
- 5 Instrument airline fitted with proportional relief valve set @ 7 bar(g)

REFERENCED DRAWINGS

168397-200-PO-3367-MC2-001 : P&ID MAIN AIR SYSTEM
(AC Drg No: 9701 2376 001-1)

168397-200-PO-3367-MB1-003 : GENERAL ARRANGEMENT MAIN DRYER
(AC Drg No: 9701 2376 041-1)

Nexen Petroleum (U.K.) Limited Golden Eagle Area Development			
VENDOR : ATLAS COPCO LTD			
EQUIPMENT TITLE : MAIN AIR DRYER PACKAGE			
EQUIPMENT TAG NO(S) : X-5502A/B/C/D			
GEAD Vendor Document Number			
Purchase Order Number	Doc Type	Seq. No.	Rev.
168397-200-PO-3367	MC2	003	6
DATE			12/11/12
INCLUDES DOCUMENT CODES : TOTAL SHEETS : 1			
F Final (accepted) - manufacturing may proceed.			
A Qualified Release - revise and re-submit. Manufacturing may proceed subject to incorporation of comments.			
R Rejected - revise and re-submit. Manufacturing may not proceed.			
I Accepted for information only.			
Review of Vendor documents does not relieve Vendor of the responsibility for correctness under the Purchase Order. Permission to proceed does not constitute acceptance of design, detail and calculations, test methods or materials developed or selected by the Vendor and does not relieve the Vendor from full compliance with the Purchase Order or any other obligations, nor detract from any of the Purchaser's rights.			
Engineer : <i>Mohamed</i>			Date : 28/11/12

CLIENT CB&I NEXEN - GOLDEN EAGLE

TITLE X-5502 MAIN DRYER P&ID

A.C. ORDER No.	SHOP ORDER	Dept	ES	Drawn	S.J.H	Chkd	T.J.H	Appd	RS
168397-200-PO-3367	855604	Scale	-	Date	09.01.12	Date	09.01.12	Date	09.01.12
CLIENT ORDER No.	CLIENT DRG No.	168397-200-PO-3367	168397-200-PO-3367-MC2-003-01	A1	855604-CBM NEXEN	Based on			
USED ON	A.C. DRG No.	9701 2376 042-1							

7		12-1112	W.C.	H
6		23-10-12	W.C.	
5		13-9-12	W.C.	H
4		6-8-12	W.C.	M
3	client feedback	23-5-12	W.C.	M
2	client feedback	17-2-12	W.C.	M
1	-	6-1-12	DvA	T
0	-	21-12-11	DvA	T
PNO11042 - 002		MODEL: CDE-0918D		
All EC Contracts Comply with Pressure Equipment Directive According to PED97/23/EC				

All rights of the drawing and any data contained herein are the property of Atlas Copco Compressors Ltd. Any reproduction or use of this drawing without the written permission of Atlas Copco Compressors Ltd. is strictly prohibited.

Issue	Name	Date	Notes	Chkd	Appd
G	S.H	12.11.12	MODIFIED TO CLIENT COMMENTS - DOCN 4993	T.J.H	RS
F	S.H	23.10.12	MODIFIED TO CLIENT COMMENTS - DOCN 4993	T.J.H	RS
E	S.H	13.09.12	MODIFIED TO CLIENT COMMENTS - DOCN 4993	T.J.H	RS
D	S.H	06.08.12	MODIFIED TO CLIENT COMMENTS - DOCN 4993	T.J.H	RS
C	S.H	23.05.12	MODIFIED TO CLIENT COMMENTS - DOCN 4993	T.J.H	RS
B	S.H	28.02.12	MODIFIED TO CLIENT COMMENTS - DOCN 4993	T.J.H	RS
A	S.H	09.01.12	FIRST ISSUE	T.J.H	RS