

DRAWING No
WO.912551/D01/015

FRANGIBLE BULB HEAT DETECTORS FIRE AREA P03

FRANGIBLE BULB HEAT DETECTORS FIRE AREA P10

DELUGE NOZZLES
FIRE AREA P03

DELUGE NOZZLES
FIRE AREA P10

LEGEND

- FIREWATER SUPPLY LINE
- INSTRUMENTATION TRIM
- PNEUMATIC LINES
- ELECTRIC CABLE

INTERFACE & CONNECTION TABLE

REF	SIZE	DESCRIPTION	SPECIFICATION
TP2	10"	FIREWATER INLET	ANSI B16.5 CLASS 150lb FLANGE
TP3	10"	BYPASS INLET	ANSI B16.5 CLASS 150lb FLANGE
TP4	10"	FIREWATER OUTLET (P03)	ANSI B16.5 CLASS 150lb FLANGE
TP5	8"	FIREWATER OUTLET (P10)	ANSI B16.5 CLASS 150lb FLANGE
TP6	2"	DRAIN / TEST OUTLET	ANSI B16.5 CLASS 150lb FLANGE
TP7	1"	AFFF INLET	ANSI B16.5 CLASS 150lb FLANGE
TP8	1"	INSTRUMENT AIR INLET	ANSI B16.5 CLASS 150lb FLANGE
TP9	1"	INSTRUMENT AIR OUTLET (P03)	ANSI B16.5 CLASS 150lb FLANGE
TP10	1"	INSTRUMENT AIR OUTLET (P10)	ANSI B16.5 CLASS 150lb FLANGE

AMERADA HESS LIMITED
Scott Field Development

RETURN CODE 8

THIS DOCUMENT HAS
BEEN ACCEPTED BY
COMPANY AS
"AS SUPPLIED"
WITHOUT ENGINEERING
REVIEW

AS SUPPLIED

Seller shall complete both Sections A & B, sign & date
A All Company comments on previous submission have been fully incorporated
☒ Yes ☐ No ☐ Not Applicable
B There are no design changes, other than incorporation of Company comments, from previous submission
☒ Yes ☐ No
Seller's Verifying Statement:
This document accurately represents the "As Supplied" condition of the Work
Sellers Signature: *[Signature]* Date: 1/15/02

INSTRUMENT AIR SUPPLY

DRAIN & TEST TP6

OTHERS
WORMALD

NOTES

- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH -
GENERAL ARRANGEMENT - WO.912551/C03/015
FABRICATION DETAIL - WO.912551/C04/015
ELECTRICAL TERMINATION DETAIL - WO.912551/F04/008
- PROJECT PIPING SPECIFICATION - SCOTT FW 0000 PI SP 0001
- LOCAL MANUAL RELEASE VALVE (ITEMS 15 & 50) TO BE MOUNTED AT FRONT OF SKID WITH EXTENDED LEVER TO BE OPERATED FROM OUTSIDE SKID

COMPANY RETURN CODES	
<input type="checkbox"/> 1. Accepted "As Supplied"	
<input type="checkbox"/> 2. Accepted - No Comments	
<input type="checkbox"/> 3. Qualified Acceptance - Minor Comments. Revise & Resubmit as "As Supplied" Work May Proceed	
<input type="checkbox"/> 4. Qualified Acceptance - Minor Comments. Revise & Resubmit To Obtain Code 2 Work May Proceed	
<input type="checkbox"/> 5. Qualified Acceptance - Major Comments. Revise & Resubmit To Obtain Code 2 Work May Proceed	
<input type="checkbox"/> 6. Rejected - Revise & Resubmit immediately Work May Not Proceed in the Affected Areas	
<input type="checkbox"/> 7. Review Not Required	
Company's Signature: _____ Date: _____	

AMERADA HESS LIMITED SCOTT FIELD DEVELOPMENT		
Package Desc	DELUGE & SPRINKLER CONTROL SKIDS	
Equip Nos	LD-3210A	
SDRS Codes	D01	
Module	P12	Sheet 1 of 1
Purchase Order No	PO 160	Document No
	D	01011505

WORMALD
ENGINEERING & CONTRACTING DIVISION

PROJECT SCOTT FIELD DEVELOPMENT

W.E. JOB N° WO912551 ITEM N° CLIENT AMERADA HESS LIMITED

DRAWN BY P.BUCKLEY DATE JAN 91

CLIENTS ORDER N° T000 LC RM 0012 PO 160

TITLE
PIPING AND INSTRUMENT DIAGRAM
FOR 8" & 10" DELUGE/FOAM SKID
EQUIPMENT No LD-3210A

DRAWING NUMBER WO.912551/D01/015

ISSUE 01 02 03 04 05

CAD DRG REF D01-015

REVISIONS

ISSUE	DATE	BY	CHKD	APPD	REVISION
05	MAY 92	AW	SL	SL	AS SUPPLIED
04	JUL 91	G.B.	SL	SL	CLIENTS COMMENTS INCORPORATED
					RE-ISSUED FOR APPROVAL
03	MAY 91	W.G.	SL	SL	CLIENTS COMMENTS INCORPORATED
					RE-ISSUED FOR APPROVAL
02	MAR 91	GR	SL	SL	CLIENTS COMMENTS INCORPORATED
					RE-ISSUED FOR APPROVAL
01	JAN 91	PRB	SL	SL	ISSUED FOR APPROVAL