



NOTES

1. Key:
- Hydraulic line
 - Pneumatic line
 - Electric line
 - Back panel mounted components
 - Front panel mounted components
 - From Shutdown System
 - To Shutdown System
- Bulkhead connection
- Junction point
- NC Normally closed
- SP Sample point
- Main Control Room Distributed Control System (DCS)
- Interlock

2. All tubing to be 316 STAINLESS STEEL to ASTM A269
3. Tube fittings to be twin ferrule compression type 316 STAINLESS STEEL PARKER 'A'-LOK
4. These alarms plus POWER FAILURE ALARM (WCP) are repeated to DCS as "WELLHEAD PANEL GROUP ALARM" (Tag No.XA-01179).
5. POWER FAILURE ALARM from HPU.
6. HYDRAULIC SKID ALARM on Master section (Tag No.XA-01181B) and repeated to DCS (Tag No.XA-01181A).
7. SSSV EQUALISATION OVERRIDE ALARM repeated to DCS.
8. FLOWLINE VENTING OVERRIDE ALARM repeated to DCS.
9. COMMON MALFUNCTION ALARM showing that a WELL has been shutdown by a LOW LOW or a HIGH HIGH pilot initiated from DCS

TO
WELL CONTROL
MODULES
DRG. 3341/302

AS SUPPLIED

Seller shall complete both Sections A & B, sign & date

A] All Company comments on previous submission have been fully incorporated

Yes ☒ No ☐ Not Applicable ☐

B] There are no design changes, other than incorporation of Company comments, from previous submission

Yes ☒ No ☐

Seller's Verifying Statement:

This document accurately represents the "As Supplied" condition of the Work

Seller's Authorised Signature: *[Signature]* Date: *2-4-92*

COMPANY RETURN CODES		AMERADA HESS LIMITED	
<input checked="" type="checkbox"/> 1. Accepted "As Supplied"		SCOTT FIELD DEVELOPMENT	
<input checked="" type="checkbox"/> 2. Accepted-No Comments		Package Desc	WELLHEAD SHUTDOWN AND CONTROL SYSTEM
<input checked="" type="checkbox"/> 3. Qualified Acceptance-Minor Comments Revise & Resubmit as "As Supplied" Work May Proceed		Equip Nos	JP0101
<input checked="" type="checkbox"/> 4. Qualified Acceptance-Minor Comments Revise & Resubmit To Obtain Code 2 Work May Proceed		SDRS Codes	D01
<input checked="" type="checkbox"/> 5. Qualified Acceptance-Minor Comments Revise & Resubmit To Obtain Code 2 Work May Proceed		Module	P11
<input checked="" type="checkbox"/> 6. Rejected-Revise & Resubmit Immediately Work May Not Proceed in The Affected Area		Purchase Order No	Document No
<input checked="" type="checkbox"/> 7. Review Not Required			Rev
Company Signature: <i>[Signature]</i> Date: <i>29/10/92</i>		P0176	D 0, 0, 0, 1 06

Rev	A	B	1	2	3	4
	ISSUED FOR APPROVAL.	REVISED WITH CLIENT COMMENTS. REISSUED FOR APPROVAL.	REVISED WITH CLIENT COMMENTS. ISSUED FOR MANUFACTURE.	REVISED TO CHANGE SHEET No. 118	REVISED TO CHANGE SHEET No. 208	REVISED TO CHANGE SHEET No. 224
Date By Chd App	14/2/91 DJ GH IO	16/4/91 DJ GH IO	14/06/91 AL GH IO	04/09/91 AL GH IO	30/11/92 MB GH IO	9/3/92 MB GH IO

IF IN DOUBT ASK

This document is confidential and copyright property of LINTOTT PLC © and must not be copied or lent without their written permission.

	Sig	Date	lintott	Jarrol Way, Bowthorpe Norwich, Norfolk NR5 9JD Telephone: (0603) 745621 Telex: 975246 LCE G Fax: (0603) 749118	
Drn	DJ	14/2/91			
Chd	GH	15/2/91			
App	IO	15/2/91			
Project			AMERADA HESS LTD SCOTT FIELD DEVELOPMENT WELLHEAD SHUTDOWN AND CONTROL SYSTEM		Project No. G3341
Drawing Title			PIPING & INSTRUMENT DIAGRAM COMMON SECTION WCP		Drg No 3341/301
					Rev 4