


GENERAL NOTES

- 1 DAMPER POSITION TRANSMITTER
- 2 DAMPER LINKAGE FAILURE ALARM

EQUIPMENT TAG NUMBERS

NP TAG n°	DESCRIPTION	CUSTOMER TAG n°	
		X-7001A	X-7001B
-	EXCHANGER	E-5710A	E-5710B
WHRU	WASTE HEAT RECOVERY UNIT	X-5701A	X-5701B
T-300	AIR BUFFER VESSEL	V-5703A	V-5703B

- 1 TEMPERATURE TRANSMITTER ON WATER SYSTEM CONTROL LOOP



Nexen Petroleum (U.K.) Limited			
VENDOR : GE Nuova Pignone (AMEC FW)			
EQUIPMENT TITLE : PIPING & INSTRUMENT DIAGRAMS			
EQUIPMENT TAG NO(S) : X-7001A/B, X-5701A/B			
Vendor Document Number			
Purchase Order No	Doc Type	Seq. Sheet No	Rev. DATE
168397 - 200 - PO - 3270 - MC2 - 001 - 18	Z1	26/10/16	
SUPPLIER DOCUMENT REVIEW			
Rejected (Assai Code - REJ) - Quality and content is out of conformity with Company requirements. Document shall be revised by Supplier to incorporate the necessary changes and subsequently re-submitted.			
Accepted With Comments (Assai Code - AWC) - Generally acceptable but elements require to be addressed. Document shall be revised by Supplier to incorporate the necessary changes and subsequently re-submitted.			
Accepted As Final (Assai Code - FIN) - Documents are considered acceptable, do not re-submit.			
Accepted For Information (Assai Code - AFI) - No further action required, do not re-submit.			
Review of Vendor documents does not relieve Vendor of the responsibility for correctness under the Purchase Order. Permission to proceed does not constitute acceptance of design, detail and calculations, test methods or materials developed or selected by the Vendor and does not relieve the Vendor from full compliance with the Purchase Order or any other obligations, not detract from any of the Purchaser's rights.			
Z1	26/10/16	AD-HOC AS-BUILT	
REV	DATE	DESCRIPTION	DRN CHK APP CLT

GE Oil & Gas	TITLE WHRU SYSTEM P&I DIAGRAM	DOCUMENT CODE SOM5081932	REVISION 11
REVISION DESCRIPTION NO REVISION IS INTRODUCED IN THIS SHEET		PAGE MARKER N/A	SECURITY CODE N
ORIGINAL JOB 1703636-37		SIZE 1	LANGUAGE A
THIS DOCUMENT IS AND CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF Nuova Pignone S.r.l. WHICH SHALL NOT BE USED OR DISCLOSED TO OTHERS EXCEPT WITH THE WRITTEN PERMISSION OF Nuova Pignone S.r.l. UNPUBLISHED WORK ©2016 Nuova Pignone S.r.l. ALL RIGHTS RESERVED		SHEET 18 of 21	

T-300  
SERVICE AIR RESERVOIR  
DESIGN PRESS & TEMP 13 bar G/-10-60 °C  
OPERATING PRESS & TEMP 5.5 bar G/10-40 °C  
MATERIALS OF CONSTR AISI316L  
VOLUME 350L  
WEIGHT 230 KG

REVISE WITH P&ID ONLY