



TERMINATION SCHEDULE				
TP No.	SIZE	CLASS	DESCRIPTION	PIPING CLASS
TP-03	2"NB	150# RF	HP FLARE	S1B
TP-05	1"NB	150# RF	LP FLARE	S1B

NOTES:

- PSV AND VENT/FLARE HEADERS PIPED TO 2"NB 150# SKID TP05 (LP FLARE) BY OGS. INTERNAL FLARE HEADER TO BE 1" NB.
- 2" NB X 1" NB REDUCING ADAPTER INSTALLED THROUGH SPLIT GLAND PLATE
- HEATED PCV's TO BE POWERED BY ANALYSER CUBICLE DISTRIBUTION BOARD.
- THESE PCV's ARE NOT HEATED.
- ALL TUBING TO BE METRIC.
- ALL TUBE + FITTINGS TO BE C276 (HASTELLOY).
- 1" N.B. ANSI B16.5 150LB R.F. FLANGE. GLAND PLATE INSTALLED AROUND PIPING AT TRANSIT.
- 1/4" NPT WELDOLETS TO FITTED TO HEADERS
- ALL SIGNALS CONNECTED TO METERING SUPERVISORY COMPUTER
- PSV's BLEEDS ARE NOT REQUIRED IN SMALL BORE-VOLUME ANALYSER SYSTEMS
- SS 316 COMPONENTS ARE LISTED AS FOLLOWS, (ALL NACE CERTIFIED)
 - COALESCING MEMBRANE FILTER
 - ANALYSER & FAST LOOP FLOW METERS
 - PRESSURE REGULATORS
 - PRESSURE GAUGES
 - SPOT SAMPLE CYLINDER
 - RELIEF VALVES
 - ISOLATION NEEDLE VALVES
 - TWO VALVE MANIFOLD (GAUGE)
 - RESTRICTION ORIFICE
 - 1" OD VENT HEADER
- CABINET VENT.

REV	DESCRIPTION	DATE	BY	CHKD	APPRD
09	I	14SEP12	AS BUILT		JWB
08	H	03APR12	REVISED TO CLIENT COMMENTS	CS	MSI
07	G	29FEB12	REVISED TO CLIENT COMMENTS	CS	MSI
06	F	11JAN12	REVISED TO CLIENT COMMENTS	TT	CNS
05	E	28NOV11	REVISED TO CLIENT COMMENTS	TT	BW
04	D	25NOV11	REVISED TO CLIENT COMMENTS	TT	BW
03	C	30SEP11	REVISED TO CLIENT COMMENTS	TT	BW
02	B	09SEP11	REVISED TO CLIENT COMMENTS	TT	DM
01	A	12AUG11	ISSUED FOR APPROVAL	TT	DM

CUSTOMER: OGS DATE: 12AUG11 DESCRIPTION OF REVISION: PREP: CHKD: APPRD:

OGS
OIL & GAS SYSTEMS LIMITED
GEMINI HOUSE THE BUSINESS PARK
ELY CAMBRIDGE CB1 4EA ENGLAND
Phone : 44 (0)1353 666640
Fax : 44 (0)1353 666650
Website : www.ogsll.com

SCALE: NTS
ORIGINAL SIZE: A1
SHEET: 01 (NEXT SHEET 02)

CONTRACT NO: C203 DOC CODE: D02 DOC NO: 002 SHEET: 001 REVISION: I

OGS SUB-SUPPLIER DETAILS:
SUB-SUPPLIER: -
DRAWING No.: -
REVISION No.: -

P&ID
SAMPLE CONDITIONING CABINET

Nexen Petroleum (U.K.) Limited
Golden Eagle Area Development
VENDOR: OGS
EQUIPMENT TITLE: Analyser Sampling System
EQUIPMENT TAG NO(S): Y-2408
GEAD Vendor Document Number
Purchase Order Number: 168397-200-PO-6008- MC2 - 002 Doc Type: Code: No: Rev: 09 DATE: 14.09.12
INCLUDES DOCUMENT CODES: *** TOTAL SHEETS: 2
DISTRIBUTION LIST:
CLIENT: 1E
TOTECH: 1E
Final (accepted) - manufacturing may proceed.
Qualified Release - revise and re-submit. Manufacturing may proceed subject to incorporation of comments.
Rejected - revise and re-submit. Manufacturing may not proceed.
Accepted for information only.
Review of Vendor documents does not relieve Vendor of the responsibility for correctness under the Purchase Order. Permission to proceed does not constitute acceptance of design, detail and calculations, test methods or materials developed or selected by the Vendor and does not relieve the Vendor from full compliance with the Purchase Order or any other obligations, nor detract from any of the Purchaser's rights.
Engineer: [Signature] Date: 27/09/12