



- NOTES**
- NOTE 1: HIGH PRESSURE ON BALANCING LINE DISCHARGE SIDE COMPARED WITH COMPRESSOR SUCTION PRESSURE
- NOTE 2: NORMAL FLARE BACK-PRESSURE 0.1 bar G  
MAXIMUM FLARE BACK-PRESSURE 0.3 bar G  
PIPING SLOPE TOWARD FLARE. CONNECTION TO BE ON THE TOP OF FLARE PIPE TO AVOID LIQUID FLOWBACK TO SEAL SYSTEM
- NOTE 3: MANUAL VALVES AND LINE SEQUENCES NUMBERS 215XX FOR TRAIN A AND 217XX FOR TRAIN B  
EX 2"-VT-21550-S1X AND 2"-VT-21750-S1X
- INSTRUMENTS AND EQUIPMENTS NUMBERS WITH A SUFFIX AND B SUFFIX  
EX PI21284A FOR TRAIN A AND PI21284B FOR TRAIN B
- NOTE 4: MAINTAIN TEMPERATURE 80 °C
- NOTE 5: NEXEN TO IMPLEMENT CSO DEVICE
- NOTE 6: ALL TRANSMITTERS ARE WITH LCD INDICATOR

Nexen Petroleum (U.K.) Limited				
VENDOR: THERMODYN (AMEC FW)				
EQUIPMENT TITLE: MP CENTRIFUGAL COMPRESSOR				
EQUIPMENT TAG NO(S): C-2103A/B				
Supplier Document Number				
Purchase Order No.	Doc Type	Seq. Sheet No.	Rev.	DATE
168397-200-PO-3271-MC2-004-05			Z1	26/10/10
SUPPLIER DOCUMENT REVIEW				
Rejected (Assai Code - REJ) - Quality and content is out of conformity with Company requirements. Document shall be revised by Supplier to incorporate the necessary changes and subsequently re-submitted.				
Accepted With Comments (Assai Code - AWC) - Generally acceptable but elements require to be addressed. Document shall be revised by Supplier to incorporate the necessary changes and subsequently re-submitted.				
Accepted As Final (Assai Code - FIN) - Documents are considered acceptable, do not re-submit.				
Accepted For Information (Assai Code - AFI) - No further action required, do not re-submit.				
Review of Vendor documents does not relieve Vendor of the responsibility for correctness under the Purchase Order. Permission to proceed does not constitute acceptance of design, detail and calculations, test methods or materials developed or selected by the Vendor and does not relieve the Vendor from full compliance with the Purchase Order or any other obligations, not detract from any of the Purchaser's rights.				
Z1	26/10/10	AD-HOC AS-BUILT	LM/AAH/AM	
REV	DATE	DESCRIPTION	DRN	CHK APP CLT

TITLE: SEAL GAS SYSTEM P&ID DIAGRAM		DOCUMENT CODE: IPLSH000799		REVISION: 9
REVISION DESCRIPTION: NO REVISION IS INTRODUCED IN THIS PAGE		PAGE MARKER: N/A		SECURITY CODE: N
ORIGINAL JOB: IN60062		SIZE: 1		LANGUAGE: A
SHEET: 5 of 6		SHEET: 5 of 6		

THIS DOCUMENT IS AND CONTAINS CONFIDENTIAL AND PROPRIETARY INFORMATION OF Thermodyns S.p.A. WHICH SHALL NOT BE USED OR DISCLOSED TO OTHERS EXCEPT WITH THE WRITTEN PERMISSION OF Thermodyns S.p.A. UNPUBLISHED WORK ©2010 Thermodyns S.p.A. ALL RIGHTS RESERVED

QUESTO DISEGNO È STATO ESEGUITO CON TECNICHE CAD - THIS DRAWING WAS MADE WITH CAD TECHNIQUES