



SPECIFICATION 420 D.E. FILTER-UNIT				
EQUIPMENT SPECIFICATION				
Item nr.	Description	Instrument Tag No. for V-8108A Unit	Instrument Tag No. for V-8108B Unit	Size
N1	Safety Valve (Flanged)	PSV81.671	PSV81.681	2" BSP
N2	Ball Valve			2" BSP
N3	Butterfly Valve With Pneumatic Control	XCV81.676	XCV81.686	4"
N4	Butterfly Valve With Pneumatic Control	XCV81.679	XCV81.689	4"
N5	Butterfly Valve With Pneumatic Control	XCV81.677	XCV81.687	4"
N6	Butterfly Valve With Pneumatic Control	XCV81.678	XCV81.688	4"
N7	Butterfly Valve With Handle			1 1/2"
N8	Flow Indicator	FI81.672 ④	FI81.682 ④	NW100
N9	Butterfly Valve With Pneumatic Control	XCV81.680	XCV81.690	3"
N10	Butterfly Valve With Handle			3"
N11	Check Valve			NW15
N12	Ball Valve			1/2" BSP
N13				
N14	Ball Valve			1/2" BSP
N15	Check Valve			NW15
N16	Butterfly Valve With Handle			3"
N17	Ball Valve			1/2" BSP
N18	Butterfly Valve With Handle			3"
N19	Ball Valve			2" BSP
N20	Butterfly Valve With Handle			3"
N21	Precoat-Pump Type M15 Wilden			
N22	Body Feed-Pump Type M4 Wilden			
N23	Pressure Indicator	PI81.673	PI81.683	1/2" BSP
N24	Pressure Indicator	PI81.674	PI81.684	1/2" BSP
N25	Pressure Regulator (PLANT AIR)			1/2" BSP
N26	Ball Valve			1/2" BSP

Manuf.: CROSBY
Style: JOS-15-G
Size: 2"xJx3"
Inlet: 2" ANSI 150lbs RF
Outlet: 3" ANSI 150lbs RF

AMERADA HESS LIMITED
Scott Field Development

RETURN CODE 8
THIS DOCUMENT HAS
BEEN ACCEPTED BY
COMPANY AS
"AS SUPPLIED"
WITHOUT ENGINEERING
REVIEW

AS SUPPLIED	
Seller shall complete both Sections A & B, sign & date	
A All Company comments on previous submission have been fully incorporated	
<input type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Not Applicable	
B There are no design changes other than incorporation of Company comments from previous submission	
<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Seller's Verifying Statement: This document accurately represents the "As Supplied" condition of the Work	
Sellers Authorized Signature: P. Wood Date: 25/3/92	

COMPANY RETURN CODES		AMERADA HESS LIMITED	
<input type="checkbox"/> 1. Accepted "As Supplied"		SCOTT FIELD DEVELOPMENT	
<input type="checkbox"/> 2. Accepted - No Comments.		Package Completion Fluid	
<input type="checkbox"/> 3. Qualified Acceptance - Minor Comments. Revise & Resubmit as "As Supplied" Work May Proceed		Desc Filter Package	
<input type="checkbox"/> 4. Qualified Acceptance - Minor Comments. Revise & Resubmit To Obtain Code 2 Work May Proceed		Equip Nos DF 8101 A/B	
<input type="checkbox"/> 5. Qualified Acceptance - Major Comments. Revise & Resubmit To Obtain Code 2 Work May Proceed		SDRS Codes D01	
<input type="checkbox"/> 6. Rejected - Revise & resubmit immediately Work May Not Proceed In The Affected Areas		Module	
<input type="checkbox"/> 7. Review Not Required		Sheet 1 of 1	
Company's Signature :		Purchase Order No	Document No
Date :		P0228	0000105

Customer: AMERADA HESS LIMITED		
Subject: PIPING AND INSTRUMENT DIAGRAM		
420 DE UNIT		
TWIN HOLLAND Kadoelenweg 176 1035 NL Amsterdam-Holland Tel.: 020-6312695 Telex.: 19336 Fax.: 020-6312934 All copyrights reserved ©		
Scale: ~		
Drawn by: SCH.ENG.		
Check by:		
Date: Mrt.'91		
Format: A1		
Nr.: 91071		
Page 04		

Issue	Date	Amendment
D	21-2-'92	As supplied
C	6-9-'91	Changed as indicated by ④
B	4-7-'91	Changed as indicated by ③
A	31-5-'91	Changed as indicated by ②