



NOTES

REFER TO LEGEND SHEETS 168397-100-PR-PI-0001 TO 0012 FOR DETAILS OF PIPING CLASS, INSULATION, EQUIPMENT TYPES, INSTRUMENT DETAILS, VALVES AND SPECIFIC HOOK-UP REQUIREMENTS.

1. CONNECTION FOR CRANE'S HOSE PIPE TO THE DIESEL DAY TANK.

2. DELETED.

3. VALVE MV-50014 TO BE LOCATED OUTSIDE FIRE PUMP ROOM.

4. DELETED.

5. REQUIREMENTS FOR FLANGE GUARDS (COALESCING TYPE) TO BE ADDED TO DIESEL LINES (DF) OPERATING AT 2 barg OR HIGHER ARE SHOWN IN 168397-400-SA-RP-0009.

6. LOCATED AT EAST END OF PLATFORM, LOCAL TO CRANE PEDESTAL.

7. LOCATED AT WEST END OF PLATFORM, LOCAL TO SOUTH END OF T-9201.

8. SP ITEM NUMBERS FOR FLANGE GUARDS:

1/2"	SP-1830
3/4"	SP-1831
1"	SP-1832
1 1/2"	SP-1833
2"	SP-1834
3"	SP-1835
4"	SP-1836
6"	SP-1837

9. CABINET CONSISTS OF A HOSE REEL WITH DISPENSER TO SUPPLY TEMPORARY USERS.

10. BOTTOM OF CABINET SHALL BE SEALED AND PROVIDED WITH SUFFICIENT CAPACITY TO HOLD THE FULL VOLUME OF THE HOSE IN THE EVENT OF HOSE LEAKAGE.

Z2	07/03/17	AS-BUILT FOR 20976447	SG	AH	AH	TR
Z1	25/07/2014	AS BUILT INC. RN 02 - 04	JPN	JG	JG SH	JM
2	30/03/2012	RFC	AA	DC	RJD IV	SA
1	26/10/2011	REVISED FOR CONSTRUCTION	AA	DC	RJD IV	SA
0	09/08/2011	AFC INC. RN 01	AA	DC	RJD IV	SA
Z3	13/12/22	AS-BUILT FOR GMOC0496	TPK	TF	TF	M
REV	DATE	DESCRIPTION	DRN	CHK	APP	CLT

TITLE:

PIPING & INSTRUMENT DIAGRAM
DIESEL DISTRIBUTION
WELLHEAD PLATFORM

SCALE (A1):

NTS

ASSAI No:

PR18PU0011

CONTRACT No:

168397

CLIENT CONTRACT No:

GEA-CT-CON-00808

DRAWING No.

168397 - 100 - PR - PY - 5031 - 01

REV

Z3