



31. PALL-PI1508 IS CONFIGURED AS ALARM THROUGH DCS.
32. PRESSURE INSTRUMENT TO BE CLOSE COUPLED.
33. DB-01010 TO BE CLOSED DURING MUD/KILL OPERATION AS TEMPERATURE COULD EXCEED PT-11504 DESIGN TEMPERATURE OF 121°C. EXCEEDING INSTRUMENT DESIGN TEMPERATURE WILL NOT RESULT IN LOSS OF CONTAINMENT BUT WILL IMPAIR FUTURE USE.



SCOTT



DRAWING No.	SCOTT-WG-0000-PR-PD-0395.15	Z4	NONE
-------------	-----------------------------	----	------

	PROJECT	ORIG	AREA/MOD	DISC	TYPE	SEQ. No.	SHT.		REV	SCALE
--	---------	------	----------	------	------	----------	------	--	-----	-------