



TERMINAL POINT SCHEDULE SPRINKLER VALVE SKID K-6515			
Location	Description	Size	Type
TP1	Firewater supply	3"	150# RF Flanged spec. E1D
TP2	Bypass Firewater Supply	3"	150# RF Flanged spec. E1D
TP3	Sprinkler Skid Discharge	3"	150# RF Flanged spec. E1D
TP4	Sprinkler Valve Test Line/Drain	1"	150# RF Flanged spec. E1D
TP5	Open Drain	10mm	Instrument Tubing

REFERENCE DOCUMENTS:

168397-200-PO-3761A-MB1-004
GA DRAWING SPRINKLER VALVE SKID 1833-500
168397-200-PO-3761A-MC3-001
BILL OF MATERIALS

NOTES:

- Complete Sprinkler Valve Assembly.
- The Cabinet will be Insulated.
- Light Permanently On.

MATERIALS:

Piping: Super Duplex.
Sprinkler Valve: Super Duplex
Seawater -Tubing: Hastelloy C276

Nexen Petroleum (U.K.) Limited Golden Eagle Area Development					
VENDOR : INMACO A/S					
EQUIPMENT TITLE : 3" SPRINKLER VALVE SKID					
EQUIPMENT TAG NO(S) : K-6515					
GEAD Vendor Document Number					
<u>Purchase Order Number</u>		<u>Doc Type Code</u>	<u>Seq. No</u>	<u>Rev.</u>	<u>DATE</u>
168397-200-PO-3761A - MC2 - 004				04	16.03.12
INCLUDES DOCUMENT CODES :			TOTAL SHEETS :		
<input checked="" type="checkbox"/>	F	Final (accepted) - manufacturing may proceed.			
<input type="checkbox"/>	A	Qualified Release - revise and re-submit. Manufacturing may proceed subject to incorporation of comments.			
<input type="checkbox"/>	R	Rejected - revise and re-submit. Manufacturing may not proceed.			
<input type="checkbox"/>	I	Accepted for information only.			
Review of Vendor documents does not relieve Vendor of the responsibility for correctness under the Purchase Order. Permission to proceed does not constitute acceptance of design, detail and calculations, test methods or materials developed or selected by the Vendor and does not relieve the Vendor from full compliance with the Purchase Order or any other obligations, nor detract from any of the Purchaser's rights.					
Engineer : C. Brance				Date : 13/4/12	

Rev.	Date	Description	Made by	Chk'd by	Disc Appr	Client Appr
04	16.03.12	For acceptance	MNO	TAN	RRE	
03	01.02.12	For acceptance	SHA	TAN	RRE	
02	05.01.12	For acceptance	SHA	TAN	RRE	
01	09.11.11	For acceptance	SHA	MNO	RRE	

Supplier:	INMACO	Supplier Drawing No:	1892-510
-----------	--------	----------------------	----------

INFORMATION IN THIS DOCUMENT RELATED TO TECHNOLOGY, LAYOUT, SOLUTIONS GENERAL IDEA AND COMMERCIAL ISSUES, REGARDLESS WHETHER SUCH TECHNOLOGY ETC. MAY BE PATENTED OR NOT, IS THE PROPRIETARY INFORMATION OF INMACO AS. SUCH INFORMATION MAY NOT BE DISCLOSED TO ANY THIRD PARTY, OR USED FOR ANY OTHER PURPOSE, THAN RELATED TO THE CONTRACT OF WHICH THIS DOCUMENT IS PART, WITHOUT THE EXPRESS PRIOR WRITTEN CONSENT OF INMACO AS.

Project:	Golden Eagle Area Development	Drawing Title:	P&ID 3" SPRINKLER VALVE SKID TAG No.: K-6515
----------	-------------------------------	----------------	--

Contract No.	NTS A3	Drawing No.	168397-200-PO-3761A-MC2-004	04
Scale	Size	Proj No	Area	System
		P.O. no.	Doc Type	Sequence No