



COARSE FILTER W-1702


SIZE : 711 mm O/D x 1385 T/E
FLOW : 211.7-249.8 M³/HR
DESIGN PRESSURE : 16 BAR G
DESIGN TEMPERATURE : -10°C TO 60°C
VOLUME : 0.64 M³



NOTES

- BACK FLUSH DRAIN LINE TO BE SELF DRAINING WITHOUT POCKETS.
- INSTRUMENTS & IMPULSE LINES TO BE DISCONNECTED AFTER WORKS TRIAL FIT AND TO BE INSTALLED IN MODULE FABRICATORS WORKS.
- FROST PROOFING CLASS F PER SPECIFICATION SCOTT FW 0000 CT SP 0005 00
- WINTERISATION SHALL CONSIST OF HEAT TRACING PER SPECIFICATION SCOTT FW 0000 EL SP 0018 00 TOGETHER WITH CLASS HE INSULATION PER SPECIFICATION SCOTT FW 0000 CT SP 0005 00

LEGEND



WINTERISATION (NOTE 1)

6	AS SUPPLIED.	24-2-92	TM	-	-	-	CLW
5	CLIENT COMMENT ADDED	19-6-91		RAW		DE	PS
4	WINTERISATION ADDED TO N4	13-6-91		RAW		DE	PS
3	NOTES REVISED	8-4-91		RAW		DE	PS
2	LINE NOS ADDED	7-2-91	S. GRAY	RAW		DE	PS
1	CLIENT COMMENT ADDED	2-1-91		RAW		DE	PS
0	AFD ISSUE	31-10-90	B ORDEVER	PWN	CS		PS
REV	DESCRIPTION	DATE	DRAWN	PROC	MECH	INST	P. MAN

THIS DRAWING IS THE PROPERTY OF
Baker Hughes Limited
AND MUST NOT BE USED OR COPIED WITHOUT THEIR WRITTEN PERMISSION

Plenty Metrol

Newbury Berkshire England
A Baker Hughes Company

TITLE
P. & I. DIAGRAM
ESSENTIAL SERVICES SEAWATER COARSE FILTER PACKAGE (1x100X)
ITEM No. : MY-1702

CLIENT
AMERADA HESS LIMITED
SCOTT FIELD DEVELOPMENT

SCALE	DRAWING	SECTION	NUMBER	SHEET	REV
NONE	96730_02_201	01	OF 01	6	

AS SUPPLIED

Seller shall complete both Sections A & B, sign & date

A All Company comments on previous submission have been fully incorporated
☐ Yes ☐ No ☒ Not Applicable

B There are no design changes, other than incorporation of Company comments, from previous submission
☐ Yes ☒ No

Seller's Verifying Statement:
This document accurately represents the "As Supplied" condition of the Work

Sellers Authorised Signature: *[Signature]* Date: 24-2-92

COMPANY RETURN CODES

☒ 1. Accepted "As Supplied"

☐ 2. Accepted - No Comments

☐ 3. Qualified Acceptance - Minor Comments Review & Resubmit as "As Supplied" Work May Proceed

☐ 4. Qualified Acceptance - Minor Comments Review & Resubmit To Obtain Code 2 Work May Proceed

☐ 5. Qualified Acceptance - Major Comments Review & Resubmit To Obtain Code 2 Work May Proceed

☐ 6. Rejected - Review & Resubmit Immediately Work May Not Proceed In The Affected Areas

☐ 7. Review Not Required

AMERADA HESS LIMITED
SCOTT FIELD DEVELOPMENT

Package Desc. ESSENTIAL SERVICES COARSE FILTER

Equip. No. MY 1702

SDRS Codes D01

Module UQ

Purchase Order No. P 0051 Document No. D 0004 Rev. 07

Company's Signature: *[Signature]* Date: 16/3/92