



- LOCAL INSTRUMENT
- LOCAL GAUGE BOARD
- UNIT CONTROL PANEL (UCP) IN LER
- CENTRALISED VDU DISPLAYED (DCS)
- TERMINAL POINT
- INSULATION, MINERAL WOOL WITH ST. ST. CLADDING

- NOTES :
- VENT CONNECTION WITH BREATHER
  - TEST CONNECTION
  - FOR COMMON TEMPERATURE ALARM SEE C065580A000
  - ALL SEAL GAS PIPING WITH A SURFACE TEMPERATURE ABOVE 55 °C WILL BE INSULATED WHERE PRACTICABLE OR GUARDED FOR PERSONNEL PROTECTION

**DELAVAL-STORK V.O.F.**

THIS DRAWING IS FOR:

- ☐ INFORMATION ONLY
- ☐ APPROVAL PRIOR TO MANUFACTURE OR PURCHASE OF MATERIAL. (REQUIRED BY TO ASSURE MAINTAINING PRESENT SCHEDULE.)
- ☐ RECORD APPROVAL ONLY
- ☐ FINAL DISTRIBUTION
- ☐ CERTIFIED FINAL DISTRIBUTION
- ☒ AS BUILT
- ☐

DATE: 31-03'93

SIGN:

END-USER : AMERADA HESS LTD.  
CONTRACTOR : FOSTER WHEELER LTD.  
LOCATION : SCOTT FIELD  
PURCHASER ORDER NO. : T200-ME-RM-0302-P002  
DLS ORDER NO. : LC0656

COMPANY RETURN CODES		AMERADA HESS LIMITED	
<input checked="" type="checkbox"/> 1 Accepted "As Supplied"		SCOTT FIELD DEVELOPMENT	
<input type="checkbox"/> 2 Accepted - No Comments		Package Desc	COMPRESSOR PACKAGES
<input type="checkbox"/> 3 Qualified Acceptance - Minor Comments		Equip Nos	HP CENTRIFUGAL
<input type="checkbox"/> 4 Qualified Acceptance - Minor Comments		SRMS Codes	001
<input type="checkbox"/> 5 Qualified Acceptance - Major Comments		Module	
<input type="checkbox"/> 6 Rejected - Review & Resubmit Immediately		Purchase Order No	Document No
<input type="checkbox"/> 7 Review Not Required		Rev	

2	ITEM 504 CHANGED	03-93	R.W.						
1	AS BUILT	12-91	DdeG	G.M.					
CHG ZONE	ALTERATIONS	DATE	BY	CHK	WHY	M/C			

SEE A7822.001 FOR DRAFTING SYSTEM USED  
SEE A0621.2 FOR TOL'S ETC. NOT SPECIFIED

DRAWN	AVK	8-91	REF. DWG.:	
CHK.	P.vdK.	19-9-91	SCALE:	-
ENGCHK.			SHEETNO.	1 OF 22
IDCHK.			PROJ. METHOD	
ISSUED			CAD DRAWING	SIZE A2

**DELAVAL STORK**

TITLE: LUBE OIL AND SEAL GAS SCHEMATIC HP COMPRESSOR 'B'

DRW NO. C065650G000

DELAVAL STORK HENGLO (OV) NETHERLANDS

**AS SUPPLIED**

Seller shall complete both Sections A & B, sign & date

☒ All Company comments on previous submission have been fully incorporated

☒ Yes ☐ No ☐ Not Applicable

☐ There are no design changes, other than incorporation of Company comments, from previous submission

☐ Yes ☒ No

Seller's Verifying Statement:  
This document accurately represents the "As Supplied" condition of the Work

Seller's Authorized Signature: [Signature]