



CD 100 - 609				
ISSUE	DESCRIPTION	N/E DATE	H/A DATE	P/A DATE
07	REDRAWN PDSH SWITCHES ADDED TO FILTERS. TSH ADDED PSV UPSTREAM OF OIL COOLER ADDED. TG ADDED TO TANK.	K.B. 13/5/91	AS 15.5.91	WR 15/5/91
08	PCV 47808 ETC ADDED, TAG NUMBERS ADDED. D1 RETURN TO TANK ALTERED.	K.B. 22.7.91	AS 1.8.91	WR 1.8.91
09	CONNECTION KG ADDED. CONNECTION G ALTERED. P1 WAS P2 SERVO PUMP DEPICTED. ORIFICE DOWNSTREAM OF PORT V ADDED.	K.B. 24.9.91	AS 25.9.91	WR 1/10/91

REFERENCE DRAWINGS
GENERAL ARRANGEMENT
INSTRUMENT INDEX
WIRING DIAGRAM
PARTS LIST

N.P.L.
DL800-350
CD100-692
CD100-687,8&9
DL800-778

PROJECT
C/0030 C/0057
D/0063
D/0063

- NOTES.
- NORSON POWER LIMIT OF SUPPLY
 - SEE HAGGLUND DENSON BULLETIN 1108-H FOR DETAILS OF PUMP ITEM 2.
 - THE CROSS PORT RELIEF FUNCTION IS INTEGRAL WITH THE PUMP AND IS NOT EXTERNALLY ADJUSTABLE. THE RELIEF PRESSURE IS AUTOMATICALLY MAINTAINED AT A FIXED DIFFERENTIAL ABOVE THE PUMP OVER-RIDE PRESSURE WHICH IS ADJUSTABLE AND REMOTELY CONTROLLED TO MAXIMUM, INTERMEDIATE AND ZERO LEVELS.

AMERADA HESS LIMITED
Scott Field Development

RETURN CODE 8

THIS DOCUMENT HAS BEEN ACCEPTED BY COMPANY AS "AS SUPPLIED" WITHOUT ENGINEERING REVIEW

AS SUPPLIED

Seller shall complete both Sections A & B, sign & date

A All Company comments on previous submission have been fully incorporated
☒ Yes ☐ No ☐ Not Applicable

B There are no design changes, other than incorporation of Company comments, from previous submission
☒ Yes ☐ No

Seller's Verifying Statement:
This document accurately represents the "As Supplied" condition of the Work

Sellers Authorised Signature: J.C.W. Date: 25/5/92

COMPANY RETURN CODES			AMERADA HESS LIMITED		
<input type="checkbox"/> 1. Accepted - "As Supplied"	<input type="checkbox"/> 2. Accepted - No Comments	<input type="checkbox"/> 3. Qualified Acceptance - Minor Comments. Review & Resubmit To Obtain Code 2 Work May Proceed	Package Desc:	MAIN POWER	MAIN POWER
<input type="checkbox"/> 4. Qualified Acceptance - Minor Comments. Review & Resubmit To Obtain Code 2 Work May Proceed	<input type="checkbox"/> 5. Qualified Acceptance - Major Comments. Review & Resubmit To Obtain Code 2 Work May Proceed	<input type="checkbox"/> 6. Rejected - Review & Resubmit Immediately. Work May Not Proceed In The Affected Areas	Equip Nos:	QY 4701 A/B/C	
<input type="checkbox"/> 7. Review Not Required			SDRS Codes:	DOI	
			Module:	U1	Sheet 1 of 1
			Purchase Order No:	P0001	
			Document No:	D 004606	
			Rev:		

ALL WELDS ____ FILLET CONT. U.O.S.		U.S. TOLERANCES ARE		© NORSON POWER LTD 1991		NORSON POWER LTD		STRATHCLYDE SCOTLAND		CODE	
QC PLAN, QAP 08-07-01/F1/ 4124 M		ANGULAR		THIS DRAWING IS THE PROPERTY OF NORSON POWER LTD. AND MAY NOT BE COPIED OR USED FOR ANY PURPOSE OTHER THAN WHICH IT IS SUPPLIED WITHOUT THE EXPRESS WRITTEN AUTHORITY OF NORSON POWER LTD.		DRAWN K.B. CHECKED AS		ANGLE PROJECTION		JOB N° 4124 (M)	
ESTIMATED WEIGHT = _____		ALL DIMENSIONS IN		DATE 13-5-91 / 5.5.91		APPROVED WR DATE 1/7/91		TITLE		SHEET No. 1 OF 1 SHEETS	
		F.A.B.		SCALE		MATERIAL		P & I.D. FOR POWER STARTER PACK.		DRG. No. CD100-609	
		GENERAL MTC								ISSUE No. 09	
		SURFACE TEXTURE C.L.A.									