



Terminal Point Schedule for Deluge Skid K-6514			
Location	Description	Size	Type
TP1	Firewater supply	10"	150# RF Flanged spec. E1D
TP2	Firewater supply	10"	150# RF Flanged spec. E1D
TP3	Firewater deluge discharge	10"	150# RF Flanged spec. E1D
TP4	Instrument air supply	1/2"	150# RF Flanged
TP5	Deluge valve test line/drain	2"	150# RF Flanged spec. E1D
TP6	Leakage/drain	10mm	Instrument Tubing
TP7	Open Drain	10mm	Instrument Tubing

REFERENCE DOCUMENTS:

168397-200-PO-3761A-MB1-003
GA DRAWING 10" DELUGE SKID 1833-400

168397-200-PO-3761A-MC3-001
BILL OF MATERIALS

NOTES:

- Manual release Valves, operable from outside the skid.
- The Cabinet will be Insulated.
- Complete Deluge Valve Assembly with downstream pressure control.
- Solenoid Valve is normally de-energized; energize to activate, and auto latching. (Local manual reset.)
- Light Permanently On.
- Open end/drain to outside the cabinet.

MATERIALS:

Piping: Super Duplex.
Deluge Valve: SUPER DUPLEX Trim: TITANIUM.
Seawater -Tubing: Hastelloy C276
Air -Tubing: 6Mo

Nexen Petroleum (U.K.) Limited Golden Eagle Area Development				
VENDOR : INMACO A/S				
EQUIPMENT TITLE : 10" DELUGE VALVE SKID				
EQUIPMENT TAG NO(S) : K-6514				
GEAD Vendor Document Number				
Purchase Order Number	Doc Type	Seq. No	Rev.	DATE
168397-200-PO-3761A - MC2 - 003			04	16.03.12
INCLUDES DOCUMENT CODES :			TOTAL SHEETS :	
<input checked="" type="checkbox"/>	F	Final (accepted) - manufacturing may proceed.		
<input type="checkbox"/>	A	Qualified Release - revise and re-submit. Manufacturing may proceed subject to incorporation of comments.		
<input type="checkbox"/>	R	Rejected - revise and re-submit. Manufacturing may not proceed.		
<input type="checkbox"/>	I	Accepted for information only.		
Review of Vendor documents does not relieve Vendor of the responsibility for correctness under the Purchase Order. Permission to proceed does not constitute acceptance of design, detail and calculations, test methods or materials developed or selected by the Vendor and does not relieve the Vendor from full compliance with the Purchase Order or any other obligations, nor detract from any of the Purchaser's rights.				
Engineer : C. Bevan			Date : 8/4/12	

Rev	Date	Description	Mode by	Ch'd by	Disc. Appr	Client Appr
04	16.03.12	For acceptance		MNO	TAN	RRE
03	01.02.12	For acceptance		SHA	TAN	RRE
02	20.12.11	For acceptance		SHA	MNO	RRE
01	09.11.11	For acceptance		SHA	MNO	RRE

Supplier	Supplier Drawing No.
INMACO	1892-410

INFORMATION IN THIS DOCUMENT RELATED TO TECHNOLOGY, LAYOUT, SOLUTIONS, GENERAL IDEA AND COMMERCIAL ISSUES, REGARDLESS WHETHER SUCH TECHNOLOGY ETC. MAY BE PATENTED OR NOT, IS THE PROPRIETARY INFORMATION OF INMACO AS. SUCH INFORMATION MAY NOT BE DISCLOSED TO ANY THIRD PARTY OR USED FOR ANY OTHER PURPOSE THAN RELATED TO THE CONTRACT OF WHICH THIS DOCUMENT IS PART WITHOUT THE EXPRESS PRIOR WRITTEN CONSENT OF INMACO AS.

Project	Drawing Title
Golden Eagle Area Development	P&ID 10" DELUGE SKID TAG No.: K-6514

Contract No.	Drawing No.
NTS A3	168397-200-PO-3761A-MC2-003 04
Scale	Proj. No. Area System
	P.D. no. Doc Type Sequence No. Rev