





[1	,	
PARAMETERS MONITORED	CONTROL PANEL INDICATOR SAND ALARMS FRONT REAR O.C.P. O.C.P.		
DRIVE SHAFT FLOW RATE / VOLUME	FI-826Ø1	FI-826Ø3	
TRANSMISSIONS FLUID PRESSURE LOCK-UP PRESSURE	PI-82622 PI-82625	PI-82631 PI-82634	
FLUID TEMPERATURE COMMOM TRANMISSION ALARM	PAH-82625 TI-82623 XA-82624	PAH-82634 TI-82632 XA-82633	
ENGINES RPM LUBE OIL PRESSURE COOLANT TEMPERATURE COMMON ENGINE ALARM	SI-82600 PI-82620 TI-82619 XA-82621	SI-826Ø3 PI-8263Ø TI-82629 XA-82631	
TRIPLEX PUMPS LUBE OIL PRESSURE LUBE OIL TEMPERATURE COMMON PUMP ALARM DISCHARGE PRESSURE	PI-82626 TI-82627 XA-82628 PI-82605	PI-82635 TI-82636 XA-82637 PI-82607	

	INSTRUMENTS	INSTRUMENTATION ABBREVIATION
	LOCAL FIELD MOUNTED	FE FLOW ELEMENT FI FLOW INDICATOR
	LOCATED IN OPERATOR CONTROL PANEL JC-8203	XA COMMON ALARM SI SPEED INDICATOR TI TEMPERATURE INDICATOR PI PRESSURE INDICATOR
-	INSTRUMENT LINES	PSH PRESSURE SWITCH HIGH PT PRESSURE TRANSMITTER
	ELECTRICAL LINE	PAH PRESSURE ALARM HIGH SE SPEED ELEMENT
	++++++++++++++++++++++++++++++++++++++	
	XXXXXXX CAPILLARY	

AS SUPPLIED

Sellers statement:
This document accurately represents the as supplied condition of the work. Setter's Authorised Signature : Date :

	Mat 7	oev	u	19-1	4
COMPANY RETURN CODES	AMERADA HESS LIMITED				
1. Accepted "As Supplied" 2. Accepted - No Comments	SCOTT PIELD DEVELOPEMENT				
3. Qualified Acceptance - Minor Comments. Revise & Resubmit as "As Supplied" Work May Proceed	Package Desc	• (EME	NT UI	NΤ
4. Qualified Acceptance - Minor Comments Revise & Resubmit To Obtain Code 2 Work May Proceed	Equip Nos	P-8203 A/B DE-8203 A/B			
5. Qualified Acceptance - Major Comments Revise & Resubmit To Obtain Code 2 Work May Proceed	SDRS Codes	D01			
6. Rejected - Revise & Resubmite Immediately Work May Not Proceed in The Affected	Module	Sheet 1 of 1			
Areas 7. Revieu Not Requiered	Purchase Or	der No	Docu	iment No	Rev
Company's Signature Date 22/4/97	P01	31		0.0.4	03

Signature Date 22/4/92 PUIDI DUUTIUS

CONFIDENTIEL: NE PAS REPRODUIRE NI COMMUNIQUER A UN TIERS - TOUT USAGE AUTRE QUE RELATIF A LA COMMANDE DE DS EST INTERDIT.

F 11-91 AS SUPPLIED
E 08-91 SEE FOLIO 1/4 & 3/4
D 06-91 SEE FOLIO 1/4 & 3/4
C 08-91 ADD TAG NO'S
B 02-91 UPDATED AS PER AHS INDICATIONS
USED ON AMERADA HESS SCOTT FIELD

abrication DOWELL SCHLUMBERGER
Z.I. Molina la Chezotte BP.90 42003 ST-ETIENNE CEDEX
FRANCE 77-32-64-23 Tolex 300095 (ORANGE)

B D JRBA.

L V JRBA. DRAWN CHKD APPRVD SCALE NONE FOLIO 4/4 REV

L V JPBOUDET ACHAUDIER JPBOUDET MHOOVER

03/01/91 03/01/91 0V91

1

1