Regulatory [R] and advisory [A] threshold screening

	N. Virginia	Tucson	C. Ohio	Memphis	Nordic	Saline
Title V Major Source — NOx [R]	F 4.2×	F 10.6×	F 3.2×	P	P	P
Title V Major Source — PM2.5 [R]	P	P	P	P	P	P
Hazardous Air Pollutant (HAP) Major Source [R]	P	P	P	P	P	P
Generator Non-Emergency Runtime Limit [R]	W 1.0×	W 0.80×	W 1.0×	F 1.1×	P	P
EPA GHG Reporting Program Threshold [R]	P	W 0.69×	P	P	P	P
NAAQS PM2.5 Annual Standard [R]	P	P	P	P	P	P
WHO Noise Guideline — Sustained Exposure [A]	F 1.4×	F 1.3×	F 1.3×	F 1.2×	F 1.2×	P
PUE Benchmark (ISO 30134-2) [A]	P	P	P	P	P	P
WUE Benchmark (The Green Grid) [A]	W 1.1×	P	P	P	P	P
WRI Aqueduct Water Stress [A]	P	F 1.5×	P	P	P	P
Grid Reserve Margin (NERC/PJM) [A]	P	P	P	P	P	W 0.46×
Transmission Utilization [A]	W 0.96×	W 0.88×	W 0.88×	W 0.92×	P	W 0.88×
Environmental Justice Screening [A]	–	–	–	W 0.98×	–	–
Monetized Health Damages [A]	P	P	P	P	P	P
Net Community Fiscal Impact [A]	W	P	F	P	P	P
Ratepayer Cost Shift [A]	P	P	P	P	W 0.94×	P
Food Supply Displacement [A]	P	P	P	P	P	P
Hardware Reuse/Recycle Rate [A]	P	W 0.83×	P	W 0.67×	P	P
Aquifer Depletion Risk [A]	–	P	–	P	–	P
Basin Water Stress Contribution [A]	F 2.0×	P	F 3.7×	W 0.27×	P	P
Local Temperature Impact [A]	P	P	P	P	P	P

P = pass W = warning F = fail (value/threshold shown) – = not assessed