

GEOMETRY		DESIGN CRITERIA		
Floor area	366.0 m ²		Heating	Cooling
Volume	1,464.0 m ³	Room set point	-50.0 °C	150.0 °C
Average height	4.00 m	Outdoor dry bulb	—	—
		Outdoor RH (coincident)	—	—
		ROOM HUMIDITY		
		Humidification set point		—
		lower RH limit		
		Dehumidification set point		—
		upper RH limit		

INTERNAL CONDITION

INTERNAL GAINS					
Gain	Profile			Specific	Total (W)
Occupancy sensible	Studio Occupancy			75 W/person	150
Occupancy latent	Studio Occupancy			55 W/person	110
Lighting	TM59 Default Lighting Schedule			2.0 W/m ²	732
Equipment sensible	Living Room/Kitchen Gains			—	450
Equipment latent	—			—	—
OCCUPANCY		LIGHTING		INFILTRATION	
People	2.0 persons	Design illuminance	—	Air change rate	0.15 ac/h
Area per person	—			Air flow	61 l/s
Occupied hours per year	8,760 h			Profile	Infiltration

VENTILATION		SYSTEMS	
Supply air	—	Heating system	TRH
Extract air	—	Cooling system	UC
Outside air	—	Heating riser	RH1
Supply air changes	—		
System	UV		
Supply unit	—		
Extract unit	—		

FABRIC / EXPOSURE			SIZING (TAS DESIGN LOADS)		
Element	External (m ²)	Internal (m ²)		Heating	Cooling
Walls	323.2	208.0	Design load	0 W	0 W
Windows (pane)	4.8	0.0	Design load per area	0.0 W/m ²	0.0 W/m ²
Roofs / ceilings	366.0	0.0	Sizing multiplier	not set	not set
Ground floors	366.0	0.0			
Not present (zero area): Windows (frame), Doors, Other floors			Design loads: from Tas sizing — date/currency not recorded		