

Studio 1_0

Level: Level 0 · Internal condition: Studio - Studio 1_0

GEOMETRY

Floor area	75.0 m ²
Volume	300.0 m ³
Average height	4.00 m

DESIGN CRITERIA

	Heating	Cooling
Room set point	-50.0 °C	150.0 °C
Outdoor dry bulb	—	—
Outdoor RH (coincident)	—	—

ROOM HUMIDITY

Humidification set point lower RH limit	—
Dehumidification set point upper RH limit	—

INTERNAL CONDITION

INTERNAL GAINS

Gain	Profile	Specific	Total (W)
Occupancy sensible	Studio Occupancy	75 W/person	150
Occupancy latent	Studio Occupancy	55 W/person	110
Lighting	TM59 Default Lighting Schedule	2.0 W/m ²	150
Equipment sensible	Living Room/Kitchen Gains	—	450
Equipment latent	—	—	—

OCCUPANCY

People	2.0 persons
Area per person	37.5 m ² /person
Occupied hours per year	8,760 h

LIGHTING

Design illuminance	—
--------------------	---

INFILTRATION

Air change rate	0.15 ac/h
Air flow	13 l/s
Profile	Infiltration

VENTILATION

Supply air	30 l/s
Extract air	22 l/s
Outside air	—
Supply air changes	0.36 ac/h
System	NV
Supply unit	—
Extract unit	—

SYSTEMS

Heating system	RAD
Cooling system	AHU
Heating riser	RH1

FABRIC / EXPOSURE

Element	External (m ²)	Internal (m ²)
Walls	62.0	80.0
Windows (pane)	18.0	0.0
Roofs / ceilings	75.0	0.0
Ground floors	75.0	0.0

Not present (zero area): Windows (frame), Doors, Other floors

SIZING (TAS DESIGN LOADS)

	Heating	Cooling
Design load	0 W	0 W
Design load per area	0.0 W/m ²	0.0 W/m ²
Sizing multiplier	not set	not set

Design loads: from Tas sizing — date/currency not recorded