

BHARAT REFINERIES LIMITED
MECHANICAL INSPECTION DEPARTMENT

IN-SERVICE INSPECTION REPORT

Report No. : IR-2026-0744
Date : 04 August 2026
Inspector : S. Mehta, Level II UT
Unit : Crude Distillation Unit 2

(SYNTHETIC DOCUMENT - created for system testing.)

1. EQUIPMENT PARTICULARS

Equipment Tag : E-301
Description : Overhead Condenser, Shell and Tube
Year of Commissioning : 2014
Nominal Thickness : 10.0 mm
Minimum Required Thick : 6.5 mm
Design Pressure : 14 bar g
Operating Pressure : 9 bar g

2. PREVIOUS INSPECTION

Previous Inspection Date: 02 August 2022
Thickness Recorded : 8.9 mm

3. THICKNESS SURVEY - CURRENT

Governing (minimum) reading: 8.1 mm at Shell inlet quadrant

4. FINDINGS

- 4.1 Tube bundle fouling moderate; cleaning recommended at next turnaround.
- 4.2 No through-wall leakage detected. Shell external coating intact.

5. INSPECTOR'S REMARKS

Equipment fit for continued service. No non-conformance identified.

Signed: S. Mehta