



SNEHA TEST HOUSE PRIVATE LIMITED

TEST REPORT

Report no:	STHPL/2026/10275		
Issued To:	Arundhathi Gurukulam NO. 2, PAMPAMAHAKAVI ROAD, SHANKARAPURAM, BASAVANAGUDI, BENGALURU, KARNATAKA.,KARNATAKA-560004		
Contact Person:	-	Contact Details:	9686052212
Sample Details (Customer Provided Details)			
Sample Name:	Drinking Water	Sample Quantity:	2ltr+500ml
Sample Package:	PE Bottle	Location:	Ground floor
Batch No/Any other information	--		
Laboratory Details			
Condition of Sample at Receipt:	Good	Sample Collected on:	25-07-2026
Sampling By:	Not Applicable	Sample Receipt Date:	25-07-2026
Sample Collected by:	Walk in	Analysis Started Date:	25-07-2026
Sampling Procedure:	Not Applicable	Analysis Completed Date:	31-07-2026
Report Issue Date:	31-07-2026	Page No:	1 of 2

Discipline: Chemical
Group: Water **Subgroup:** Drinking Water
Description: Colourless, odourless, transparent liquid.

SL. No	Parameter	Units	Results	Maximum Acceptable Limit as per IS:10500-2012	Maximum Permissible Limits In The Absence of Alternate Source as per IS:10500-2012	Test Method
1	Calcium (as Ca)	mg/l	3.63	75 Max	200 Max	IS 3025 (PART 40): 2024
2	Chloride (as Cl)	mg/l	12.0	250 Max	1000 Max	IS 3025 (PART 32) : A) ARGENTOMETRIC METHOD: 2025
3	Color	Hz	<2.0	5 Max	15 Max	IS 3025 (PART 4) , A) PLATINUM COBALT (VISUAL COMPARISON METHOD): 2021
4	Electrical Conductivity	µS/cm	50.0	-	-	IS 3025 (PART 14) : 2013
5	Fluoride (as F)	mg/l	<0.1	1 Max	1.5 Max	APHA 24TH EDITION 4500-F : : 2023
6	Free residual chlorine	mg/l	<0.1	0.2 Min	1 Min	IS 3025 (PART 26): 2021
7	Iron (as Fe)	mg/l	<0.1	0.3 Max	No relaxation	IS 3025 (PART 53) : A) 1,10 PHENANTHROLINE METHOD: 2021
8	Magnesium (as Mg)	mg/l	<2.0	30 Max	100 Max	IS 3025 (PART 46) : 2023
9	Nitrate (as NO3)	mg/l	<1.0	45 Max	No relaxation	IS 3025 (PART 34/SEC 1) : B) ULTRAVIOLET SPECTROPHOTOMETRIC SCREENING METHOD: 2023
10	pH value @ 25 Deg C	-	6.56	6.5-8.5	No relaxation	IS 3025 (PART 11) : 2022
11	Sulphate (as SO4)	mg/l	<1.0	200 Max	400 Max	IS 3025 (PART 24/SEC 1) : B) TURBIDITY METHOD: 2022



Authorised Signatory
HarshavardhanaH
Technical Manager



SNEHA TEST HOUSE PRIVATE LIMITED

TEST REPORT

Report no:	STHPL/2026/10275		
Issued To:	Arundhathi Gurukulam NO. 2, PAMPAMAHAKAVI ROAD, SHANKRAPURAM , BASAVANAGUDI, BENGALURU, KARNATAKA.,KARNATAKA-560004		
Contact Person:	-	Contact Details:	9686052212
Sample Details (Customer Provided Details)			
Sample Name:	Drinking Water	Sample Quantity:	2ltr+500ml
Sample Package:	PE Bottle	Location:	Ground floor
Batch No/Any other information	--		
Laboratory Details			
Condition of Sample at Receipt:	Good	Sample Collected on:	25-07-2026
Sampling By:	Not Applicable	Sample Receipt Date:	25-07-2026
Sample Collected by:	Walk in	Analysis Started Date:	25-07-2026
Sampling Procedure:	Not Applicable	Analysis Completed Date:	31-07-2026
Report Issue Date:	31-07-2026	Page No:	2 of 2

SL. No	Parameter	Units	Results	Maximum Acceptable Limit as per IS:10500-2012	Maximum Permissible Limits In The Absence of Alternate Source as per IS:10500-2012	Test Method
12	Total Alkalinity (as CaCO3)	mg/l	17.0	200 Max	600 Max	IS 3025 (PART 23) : 2023
13	Total dissolved solids	mg/l	33.0	500 Max	2000 Max	IS 3025 (PART 16) : 2023
14	Total Hardness (as CaCO3)	mg/l	16.0	200 Max	600 Max	IS 3025 (PART 21): 2009
15	Turbidity	NTU	<0.1	1 Max	5 Max	IS 3025 (PART 10) : 2023

Remarks: The above Tested Water Sample complies the acceptable limits as Per IS 10500:2012 for the above Tested parameters only.

Notes: The Test Residual free Chlorine is applicable only when water is chlorinated.

END OF THE REPORT

The results reported above pertains only to the tested sample and applicable parameters only. Samples which are perishable will be disposed immediately after testing ; non-perishable samples will be disposed after 10 days from the date of issue of test report unless otherwise specified , as required by the applicable regulation (Eg. Bureau of Indian Standards / Food Safety Standards Authority of India / etc.). Laboratory is not responsible for the authenticity of photocopied Test Reports . Total liability of our laboratory is limited to the invoiced amount . Any discrepancy in the Test Report should be notified to the Laboratory within 3 days. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the Court of Law and should not be used in any advertising media without prior written permission . Sampling is not done by us unless specified . To confirm the authenticity of Test Reports , please contact us through email on info@sthlab.com with an attachment of the scanned copy of Test Reports .



Authorised Signatory
HarshavardhanaH
Technical Manager



SNEHA TEST HOUSE PRIVATE LIMITED

TEST REPORT

Report no:	STHPL/2026/10275		
Issued To:	Arundhathi Gurukulam NO. 2, PAMPAMAHAKAVI ROAD, SHANKARAPURAM , BASAVANAGUDI, BENGALURU , KARNATAKA.,KARNATAKA-560004		
Contact Person:	-	Contact Details:	9686052212
Sample Details (Customer Provided Details)			
Sample Name:	Drinking Water	Sample Quantity:	2ltr+500ml
Sample Package:	PE Bottle	Location:	Ground floor
Sample Plan:	Given by Customer	Sampling Done By:	NA
Batch No/Any other information	--		
Laboratory Details			
Condition of Sample at Receipt:	Good	Sample Collected on:	25-07-2026
Sampling By:	Not Applicable	Sample Receipt Date:	25-07-2026
Sample Collected by:	Walk in	Analysis Started Date:	25-07-2026
Sampling Procedure:	Not Applicable	Analysis Completed Date:	31-07-2026
Report Issue Date:	31-07-2026	Page No:	1 of 1

Discipline: Biological
Group: Water **Subgroup:** Drinking Water
Description: Colourless, odourless, transparent liquid.

SL. No	Parameter	Units	Results	Limits as per IS 10500:2012	Test Method
1	Escherichia coli	/100ml	Absent	Absent	IS 15185: 2016
2	Total Coliforms	/100ml	Present	Absent	IS 15185: 2016

Remarks: The above tested water sample does not complies the acceptable limits as per IS 10500:2012 for the above tested parameters only.
Notes: NA

END OF THE REPORT

The results reported above pertains only to the tested sample and applicable parameters only. Samples which are perishable will be disposed immediately after testing ; non-perishable samples will be disposed after 10 days from the date of issue of test report unless otherwise specified , as required by the applicable regulation (Eg. Bureau of Indian Standards / Food Safety Standards Authority of India / etc.). Laboratory is not responsible for the authenticity of photocopied Test Reports. Total liability of our laboratory is limited to the invoiced amount . Any discrepancy in the Test Report should be notified to the Laboratory within 3 days. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the Court of Law and should not be used in any advertising media without prior written permission . Sampling is not done by us unless specified . To confirm the authenticity of Test Reports , please contact us through email on info@sthlab.com with an attachment of the scanned copy of Test Reports .



Authorised Signatory
SubhashiniB V
Technical Manager



SNEHA TEST HOUSE PRIVATE LIMITED

TEST REPORT

Report no:	STHPL/2026/10276		
Issued To:	Arundhathi Gurukulam NO. 2, PAMPAMAHAKAVI ROAD, SHANKARAPURAM , BASAVANAGUDI, BENGALURU , KARNATAKA.,KARNATAKA-560004		
Contact Person:	-	Contact Details:	9686052212
Sample Details (Customer Provided Details)			
Sample Name:	Drinking Water	Sample Quantity:	2ltr+500ml
Sample Package:	PE Bottle, Sterilized container	Location:	1st Floor
Batch No/Any other information	--		
Laboratory Details			
Condition of Sample at Receipt:	Good	Sample Collected on:	25-07-2026
Sampling By:	Not Applicable	Sample Receipt Date:	25-07-2026
Sample Collected by:	Walk in	Analysis Started Date:	25-07-2026
Sampling Procedure:	Not Applicable	Analysis Completed Date:	31-07-2026
Report Issue Date:	30-07-2026	Page No:	1 of 2

Discipline: Chemical
Group: Water **Subgroup:** Drinking Water
Description: Colourless, odourless, transparent liquid.

SL. No	Parameter	Units	Results	Maximum Acceptable Limit as per IS:10500-2012	Maximum Permissible Limits In The Absence of Alternate Source as per IS:10500-2012	Test Method
1	Calcium (as Ca)	mg/l	4.04	75 Max	200 Max	IS 3025 (PART 40): 2024
2	Chloride (as Cl)	mg/l	13.2	250 Max	1000 Max	IS 3025 (PART 32) : A) ARGENTOMETRIC METHOD: 2025
3	Color	Hz	<2.0	5 Max	15 Max	IS 3025 (PART 4) , A) PLATINUM COBALT (VISUAL COMPARISON METHOD): 2021
4	Electrical Conductivity	µS/cm	52	-	-	IS 3025 (PART 14) : 2013
5	Fluoride (as F)	mg/l	<0.1	1 Max	1.5 Max	APHA 24TH EDITION 4500-F : : 2023
6	Free residual chlorine	mg/l	<0.1	0.2 Min	1 Min	IS 3025 (PART 26): 2021
7	Iron (as Fe)	mg/l	<0.1	0.3 Max	No relaxation	IS 3025 (PART 53) : A) 1,10 PHENANTHROLINE METHOD: 2021
8	Magnesium (as Mg)	mg/l	<2.0	30 Max	100 Max	IS 3025 (PART 46) : 2023
9	Nitrate (as NO3)	mg/l	<1.0	45 Max	No relaxation	IS 3025 (PART 34/SEC 1) : B) ULTRAVIOLET SPECTROPHOTOMETRIC SCREENING METHOD: 2023
10	pH value @ 25 Deg C	-	6.52	6.5-8.5	No relaxation	IS 3025 (PART 11) : 2022
11	Sulphate (as SO4)	mg/l	<1.0	200 Max	400 Max	IS 3025 (PART 24/SEC 1) : B) TURBIDITY METHOD: 2022



Authorised Signatory
HarshavardhanaH
Technical Manager



SNEHA TEST HOUSE PRIVATE LIMITED

TEST REPORT

Report no:	STHPL/2026/10276		
Issued To:	Arundhathi Gurukulam NO. 2, PAMPAMAHAKAVI ROAD, SHANKARAPURAM , BASAVANAGUDI, BENGALURU , KARNATAKA.,KARNATAKA-560004		
Contact Person:	-	Contact Details:	9686052212
Sample Details (Customer Provided Details)			
Sample Name:	Drinking Water	Sample Quantity:	2ltr+500ml
Sample Package:	PE Bottle, Sterilized container	Location:	1st Floor
Batch No/Any other information	--		
Laboratory Details			
Condition of Sample at Receipt:	Good	Sample Collected on:	25-07-2026
Sampling By:	Not Applicable	Sample Receipt Date:	25-07-2026
Sample Collected by:	Walk in	Analysis Started Date:	25-07-2026
Sampling Procedure:	Not Applicable	Analysis Completed Date:	31-07-2026
Report Issue Date:	30-07-2026	Page No:	2 of 2

SL. No	Parameter	Units	Results	Maximum Acceptable Limit as per IS:10500-2012	Maximum Permissible Limits In The Absence of Alternate Source as per IS:10500-2012	Test Method
12	Total Alkalinity (as CaCO ₃)	mg/l	18.0	200 Max	600 Max	IS 3025 (PART 23) : 2023
13	Total dissolved solids	mg/l	34.0	500 Max	2000 Max	IS 3025 (PART 16) : 2023
14	Total Hardness (as CaCO ₃)	mg/l	17.0	200 Max	600 Max	IS 3025 (PART 21): 2009
15	Turbidity	NTU	<0.1	1 Max	5 Max	IS 3025 (PART 10) : 2023

Remarks: The above Tested Water Sample complies the acceptable limits as Per IS 10500:2012 for the above Tested parameters only.

Notes: The Test Residual free Chlorine is applicable only when water is chlorinated.

END OF THE REPORT

The results reported above pertains only to the tested sample and applicable parameters only. Samples which are perishable will be disposed immediately after testing ; non-perishable samples will be disposed after 10 days from the date of issue of test report unless otherwise specified , as required by the applicable regulation (Eg. Bureau of Indian Standards / Food Safety Standards Authority of India / etc.). Laboratory is not responsible for the authenticity of photocopied Test Reports . Total liability of our laboratory is limited to the invoiced amount . Any discrepancy in the Test Report should be notified to the Laboratory within 3 days. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the Court of Law and should not be used in any advertising media without prior written permission . Sampling is not done by us unless specified . To confirm the authenticity of Test Reports , please contact us through email on info@sthlab.com with an attachment of the scanned copy of Test Reports .



Authorised Signatory
HarshavardhanaH
Technical Manager



SNEHA TEST HOUSE PRIVATE LIMITED

TEST REPORT

Report no:	STHPL/2026/10276		
Issued To:	Arundhathi Gurukulam NO. 2, PAMPAMAHAKAVI ROAD, SHANKARAPURAM , BASAVANAGUDI, BENGALURU, KARNATAKA.,KARNATAKA-560004		
Contact Person:	-	Contact Details:	9686052212
Sample Details (Customer Provided Details)			
Sample Name:	Drinking Water	Sample Quantity:	2ltr+500ml
Sample Package:	PE Bottle, Sterilized container	Location:	1st Floor
Sample Plan:	Given by Customer	Sampling Done By:	NA
Batch No/Any other information	--		
Laboratory Details			
Condition of Sample at Receipt:	Good	Sample Collected on:	25-07-2026
Sampling By:	Not Applicable	Sample Receipt Date:	25-07-2026
Sample Collected by:	Walk in	Analysis Started Date:	25-07-2026
Sampling Procedure:	Not Applicable	Analysis Completed Date:	31-07-2026
Report Issue Date:	30-07-2026	Page No:	1 of 1

Discipline: Biological
Group: Water **Subgroup:** Drinking Water
Description: Colourless, odourless, transparent liquid.

SL. No	Parameter	Units	Results	Limits as per IS 10500:2012	Test Method
1	Escherichia coli	/100ml	Absent	Absent	IS 15185: 2016
2	Total Coliforms	/100ml	Absent	Absent	IS 15185: 2016

Remarks: The above tested water sample complies the acceptable limits as per IS 10500:2012 for the above tested parameters only.
Notes: NA

END OF THE REPORT

The results reported above pertains only to the tested sample and applicable parameters only. Samples which are perishable will be disposed immediately after testing ; non-perishable samples will be disposed after 10 days from the date of issue of test report unless otherwise specified , as required by the applicable regulation (Eg. Bureau of Indian Standards / Food Safety Standards Authority of India / etc.). Laboratory is not responsible for the authenticity of photocopied Test Reports. Total liability of our laboratory is limited to the invoiced amount . Any discrepancy in the Test Report should be notified to the Laboratory within 3 days. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the Court of Law and should not be used in any advertising media without prior written permission . Sampling is not done by us unless specified . To confirm the authenticity of Test Reports , please contact us through email on info@sthlab.com with an attachment of the scanned copy of Test Reports .



Authorised Signatory
SubhashiniB V
Technical Manager



SNEHA TEST HOUSE PRIVATE LIMITED

TEST REPORT

Report no:	STHPL/2026/10277		
Issued To:	Arundhathi Gurukulam NO. 2, PAMPAMAHAKAVI ROAD, SHANKARAPURAM , BASAVANAGUDI, BENGALURU , KARNATAKA.,KARNATAKA-560004		
Contact Person:	-	Contact Details:	9686052212
Sample Details (Customer Provided Details)			
Sample Name:	Drinking Water	Sample Quantity:	2ltr+500ml
Sample Package:	PE Bottle, Sterilized container	Location:	2nd Floor
Batch No/Any other information	--		
Laboratory Details			
Condition of Sample at Receipt:	Good	Sample Collected on:	25-07-2026
Sampling By:	Not Applicable	Sample Receipt Date:	25-07-2026
Sample Collected by:	Walk in	Analysis Started Date:	25-07-2026
Sampling Procedure:	Not Applicable	Analysis Completed Date:	31-07-2026
Report Issue Date:	30-07-2026	Page No:	1 of 2

Discipline: Chemical
Group: Water **Subgroup:** Drinking Water
Description: Colourless, odourless, transparent liquid.

SL. No	Parameter	Units	Results	Maximum Acceptable Limit as per IS:10500-2012	Maximum Permissible Limits In The Absence of Alternate Source as per IS:10500-2012	Test Method
1	Calcium (as Ca)	mg/l	4.84	75 Max	200 Max	IS 3025 (PART 40): 2024
2	Chloride (as Cl)	mg/l	14.0	250 Max	1000 Max	IS 3025 (PART 32) : A) ARGENTOMETRIC METHOD: 2025
3	Color	Hz	<2.0	5 Max	15 Max	IS 3025 (PART 4) , A) PLATINUM COBALT (VISUAL COMPARISON METHOD): 2021
4	Electrical Conductivity	µS/cm	60.0	-	-	IS 3025 (PART 14) : 2013
5	Fluoride (as F)	mg/l	<0.1	1 Max	1.5 Max	APHA 24TH EDITION 4500-F : : 2023
6	Free residual chlorine	mg/l	<0.1	0.2 Min	1 Min	IS 3025 (PART 26): 2021
7	Iron (as Fe)	mg/l	<0.1	0.3 Max	No relaxation	IS 3025 (PART 53) : A) 1,10 PHENANTHROLINE METHOD: 2021
8	Magnesium (as Mg)	mg/l	<2.0	30 Max	100 Max	IS 3025 (PART 46) : 2023
9	Nitrate (as NO3)	mg/l	<1.0	45 Max	No relaxation	IS 3025 (PART 34/SEC 1) : B) ULTRAVIOLET SPECTROPHOTOMETRIC SCREENING METHOD: 2023
10	pH value @ 25 Deg C	-	6.58	6.5-8.5	No relaxation	IS 3025 (PART 11) : 2022
11	Sulphate (as SO4)	mg/l	<1.0	200 Max	400 Max	IS 3025 (PART 24/SEC 1) : B) TURBIDITY METHOD: 2022



Authorised Signatory
HarshavardhanaH
Technical Manager



SNEHA TEST HOUSE PRIVATE LIMITED

TEST REPORT

Report no:	STHPL/2026/10277		
Issued To:	Arundhathi Gurukulam NO. 2, PAMPAMAHAKAVI ROAD, SHANKRAPURAM , BASAVANAGUDI, BENGALURU, KARNATAKA.,KARNATAKA-560004		
Contact Person:	-	Contact Details:	9686052212
Sample Details (Customer Provided Details)			
Sample Name:	Drinking Water	Sample Quantity:	2ltr+500ml
Sample Package:	PE Bottle, Sterilized container	Location:	2nd Floor
Batch No/Any other information	--		
Laboratory Details			
Condition of Sample at Receipt:	Good	Sample Collected on:	25-07-2026
Sampling By:	Not Applicable	Sample Receipt Date:	25-07-2026
Sample Collected by:	Walk in	Analysis Started Date:	25-07-2026
Sampling Procedure:	Not Applicable	Analysis Completed Date:	31-07-2026
Report Issue Date:	30-07-2026	Page No:	2 of 2

SL. No	Parameter	Units	Results	Maximum Acceptable Limit as per IS:10500-2012	Maximum Permissible Limits In The Absence of Alternate Source as per IS:10500-2012	Test Method
12	Total Alkalinity (as CaCO ₃)	mg/l	22.0	200 Max	600 Max	IS 3025 (PART 23) : 2023
13	Total dissolved solids	mg/l	40	500 Max	2000 Max	IS 3025 (PART 16) : 2023
14	Total Hardness (as CaCO ₃)	mg/l	21.0	200 Max	600 Max	IS 3025 (PART 21): 2009
15	Turbidity	NTU	<0.1	1 Max	5 Max	IS 3025 (PART 10) : 2023

Remarks: The above Tested Water Sample complies the acceptable limits as Per IS 10500:2012 for the above Tested parameters only.

Notes: The Test Residual free Chlorine is applicable only when water is chlorinated.

END OF THE REPORT

The results reported above pertains only to the tested sample and applicable parameters only. Samples which are perishable will be disposed immediately after testing ; non-perishable samples will be disposed after 10 days from the date of issue of test report unless otherwise specified , as required by the applicable regulation (Eg. Bureau of Indian Standards / Food Safety Standards Authority of India / etc.). Laboratory is not responsible for the authenticity of photocopied Test Reports . Total liability of our laboratory is limited to the invoiced amount . Any discrepancy in the Test Report should be notified to the Laboratory within 3 days. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the Court of Law and should not be used in any advertising media without prior written permission . Sampling is not done by us unless specified . To confirm the authenticity of Test Reports , please contact us through email on info@sthlab.com with an attachment of the scanned copy of Test Reports .



Authorised Signatory
HarshavardhanaH
Technical Manager



SNEHA TEST HOUSE PRIVATE LIMITED

TEST REPORT

Report no:	STHPL/2026/10277		
Issued To:	Arundhathi Gurukulam NO. 2, PAMPAMAHAKAVI ROAD, SHANKARAPURAM , BASAVANAGUDI, BENGALURU, KARNATAKA.,KARNATAKA-560004		
Contact Person:	-	Contact Details:	9686052212
Sample Details (Customer Provided Details)			
Sample Name:	Drinking Water	Sample Quantity:	2ltr+500ml
Sample Package:	PE Bottle, Sterilized container	Location:	2nd Floor
Sample Plan:	Given by Customer	Sampling Done By:	NA
Batch No/Any other information	--		
Laboratory Details			
Condition of Sample at Receipt:	Good	Sample Collected on:	25-07-2026
Sampling By:	Not Applicable	Sample Receipt Date:	25-07-2026
Sample Collected by:	Walk in	Analysis Started Date:	25-07-2026
Sampling Procedure:	Not Applicable	Analysis Completed Date:	31-07-2026
Report Issue Date:	30-07-2026	Page No:	1 of 1

Discipline: Biological
Group: Water **Subgroup:** Drinking Water
Description: Colourless, odourless, transparent liquid.

SL. No	Parameter	Units	Results	Limits as per IS 10500:2012	Test Method
1	Escherichia coli	/100ml	Absent	Absent	IS 15185: 2016
2	Total Coliforms	/100ml	Absent	Absent	IS 15185: 2016

Remarks: The above tested water sample complies the acceptable limits as per IS 10500:2012 for the above tested parameters only.
Notes: NA

END OF THE REPORT

The results reported above pertains only to the tested sample and applicable parameters only. Samples which are perishable will be disposed immediately after testing ; non-perishable samples will be disposed after 10 days from the date of issue of test report unless otherwise specified , as required by the applicable regulation (Eg. Bureau of Indian Standards / Food Safety Standards Authority of India / etc.). Laboratory is not responsible for the authenticity of photocopied Test Reports. Total liability of our laboratory is limited to the invoiced amount . Any discrepancy in the Test Report should be notified to the Laboratory within 3 days. This report is not to be reproduced either wholly or in part and cannot be used as an evidence in the Court of Law and should not be used in any advertising media without prior written permission . Sampling is not done by us unless specified . To confirm the authenticity of Test Reports , please contact us through email on info@sthlab.com with an attachment of the scanned copy of Test Reports .



Authorised Signatory
SubhashiniB V
Technical Manager