
a Heating peak
switch after 1 day
switch after 2 days (used)
no switch
17%
14%
31%
0
20
40
60
80
worst case, % worse than the best method


b Cooling peak
16%
20%
85%
0
20
40
60
80
worst case, % worse than the best method