
a Heating: only linear interpolation fails often
Stepwise, no switch
6%
Stepwise, patterns first
6%
ERA5 only
7%
Stepwise
7%
Four-week average
7%
Linear interpolation only
38%
0
20
40
60
80
% of months outside ±5% of the reference
b Cooling: one month in five fails at one week
Stepwise, no switch
16%
Stepwise, patterns first
16%
ERA5 only
20%
Stepwise
20%
Four-week average
20%
Linear interpolation only
60%
0
20
40
60
80
% of months outside ±5% of the reference
48-hour gaps
one-week gaps (number)