

AALBORG UNIVERSITY

Optimal Control for Water Distribution

Electronic & IT:
Control & Automation

Group:
CA-830

STUDENT REPORT

March 1, 2017



Fourth year of study

Electronic and IT

Fredrik Bajers Vej 7

DK-9220 Aalborg East, Denmark

<http://www.es.aau.dk>

AALBORG UNIVERSITY
STUDENT REPORT

Topic:

Optimal Control for Water Distribution

Synopsis:



Project:

P8-project

Project time:

February 2017 - May 2017

Projectgroup:

17gr830

Participants:

Daniel Böhner Andersen
Ignacio Trojaola Bolinaga
Krisztian Mark Balla
Nicolaj Vinkel Christensen
Simon Krogh

Supervisors:

Tom Nørgaard Jensen
Carsten Kallesøe

Circulation: x

Number of pages: x

Appendix: x + CD

Completed xx-xx-2016

Preface

This project comprises of implementing a functional controller system for

Aalborg University, th of May 2017

Daniel Böhner Andersen
dban13@student.aau.dk

Ignacio Trojaola Bolinaga
itroja16@student.aau.dk

Krisztian Mark Balla
kballa16@student.aau.dk

Nicolaj Vinkel Christensen
nvch13@student.aau.dk

Simon Krogh
skrogh13@student.aau.dk

Explanation of notation

Acronyms

PMA	Pressure Management Area
CP	Critical Point
WT	Water Tower
MP	Minimization Problem
OD	Opening degree

Symbols

Symbol	Description	Unit
A	Cross sectional area	$[m^2]$
C_k	The k^{th} component of the distribution network	$[\cdot]$
C	Electric capacitance	$[F]$
C_H	Hydraulic capacitance	$[m^3/(N/m^2)]$
D	Diameter	$[m]$
f	Moody friction factor	$[-]$
F	Force	$[N]$
g	Acceleration due to gravity	$[m/s^2]$
h_f	Pressure given in head	$[m]$
h_m	Form loss	$[?]$
J_k	Water inertia of the k^{th} component	$[kg/m^4]$
k_f	Form loss coefficient	$[-]$
L	Length	$[m]$
m	Mass of body	$[kg]$
M	Linear momentum	$[kgm/s]$
n_i	The i^{th} node of the distribution network	$[\cdot]$
n_{gl}	Valve characteristic curve factor	$[-]$
p_a	Atmospheric pressure	$[Pa]$
Δp_k	The pressure drop across the i^{th} component	$[Pa]$
q_k	Flow through the k^{th} component	$[m^3/h]$
T	Temperature	$[^\circ]$
v	Velocity	$[m/s]$
V_t	Volume of the water in the water tower	$[m^3]$
$\alpha_k(\cdot)$	The pressure boost given by the k^{th} pump	$[Pa]$
ϵ	Average roughness	$[-]$
ζ	Pressure drop from elevation difference across the k^{th} component	$[Pa]$
θ_{max}	Maximum angle of the opening degree	$[^\circ]$
θ_{off}	Minimum angle where the valve closes	$[^\circ]$
θ_{OD}	Angle of opening degree	$[^\circ]$
$\lambda_k(\cdot)$	Function of hydraulic resistance in the k^{th} pipe	$[Pa]$
$\mu_k(\cdot)$	Function of hydraulic resistance in the k^{th} valve	$[Pa]$
ν	Kinematic viscosity	$[kg/ms]$
ρ	Density	$[kg/m^3]$
ω_r	Impeller angular velocity	$[rad/s]$

Contents

Explanation of notation	v
1 Introduction	1
I Analysis	3
2 System description	5
2.1 System overview	5
3 Requirements and constraints	9
4 Modelling	11
4.1 Hydraulic Modeling	11
4.1.1 Pipe Model	11
4.1.1.1 Surface Resistance (h_f)	13
4.1.1.2 Form Resistance (h_m)	14
4.1.1.3 Complete Pipe Model	15
4.1.2 Valve Model	15
4.1.2.1 Valve conductivity function $k_v(OD)$	16
4.1.2.2 Complete valve model	17
4.1.2.3 Unit transformation	17
4.1.3 Pump Model	17
4.1.4 Water Tower	18
4.2 Complete system model	19
4.3 Graph Theory	20
4.3.1 Incidence Matrix	20
II Control Design	21
5 Controller	23
5.1 Control Problem	23
5.2 Pressure Control	24
5.3 Minimization Problem	24
6 Implementation of controller	25
III Conclusion and verification	27
7 Acceptest	29
8 Discussion	31
9 Conclusion	33

IV Appendices	35
Bibliography	41

Water pressure management is a vital part of the water supply infrastructure all over the world. It ensures that a positive water pressure is present such that the consumers are supplied with water at all time. Maintaining a minimum pressure in the network is an important task as it ensures the end user a decent water pressure and also minimizes the risk of contamination in the water system[1].

In the U.S alone 4 % of the national energy consumption is used on moving and treating water/wastewater[2]. With an increasing focus on green energy, more and more renewable energy sources are added to the grid. Nevertheless, the intermittent behavior of renewable energy sources and time-dependent consumer preferences result in fluctuation in the available power. This means that the price for electric power also varies [3]. To minimize the cost of running a water distribution network, potential energy can be used to maintain a minimum pressure. When electric prices are low, water can be pumped to a higher altitude and stored in a water tower (WT), and thereby energy is stored for future use. The potential energy of the water stored in the WT can then be used to maintain a minimum pressure that is required at the end consumer. However when a WT is included in a water distribution network, the pressure in the system is defined by the water level and height of the WT. This means that to control pressure, the water level of the WT should be controlled.

Maximum allowed pressure in water distribution networks should also be considered as the risk of water leakage increases when pressure is increased[4], thus increased water losses due to leakage will lead to a higher energy consumption. In [4] it is stated that the estimated world wide water loss is at 30 %, so the energy used on cleaning the water for filth, bacteria and pressurizing it is lost. Another problem that should be highlighted regarding high pressure is that a high pressure will increase the wear on the pipes in a system[5], this leads to higher maintenance costs as pipes and fittings have to be replaced more frequently. Additionally, maintenance is not always an easy task, since the pipes usually are placed under ground and need to be dug up. Thereby the expense of maintenance is increased, especially in a city, where the operation also can have a negative impact on significant infrastructures. Based on these facts, the maximum pressure in a water distribution network is a vital parameter of the system's profitability. In a system with a WT the maximum allowed pressure will likely be defined by the maximum allowed water level in the WT, as the WT in most situations will be able to provide a dominant pressure compared to the desired network pressure.

Some constraints regarding a solution that implements a WT are still necessary to be taken into account. One of them being the quality of the water in the tower. If stored for too long the quality of the water will start to decrease due to a decreasing oxygen level [6, 7], thus the water should not be stored for too long. The oxygen level of the water also depends on the water temperature and therefore the water should not be too warm. Furthermore it is undesirable that the water remains stagnant in the tower or pipe as it also affects the water quality.

This leads to the following problem statement:

- *How can a water tower, implemented in a water distribution network, be controlled to minimize the cost of running a water distribution network without compromising the water quality.*

Part I

Analysis

System description 2

This section will give an introduction to the available test system, including structure and components overview.

2.1 System overview

To develop and test different control methods for a water distribution system a test setup is required. Such a setup is available at Aalborg university which is based on a real water distribution system, though as a 1:20 downscaled version.




Figure 2.1. The available test setup used to represent a real water distribution system.

The test setup represents a real system, thus the same structure concerning piping, leveling and all the other components. To achieve different elevation levels between system parts, the setup is mounted on a wall. This also allows for a quick overview of the complete setup and eases access to the components. As the system is used for various test scenarios other equipment is also present in the test setup shown in *Figure 2.1*, enabling the test system to mimic a variety of different system types and scenarios. A simplified diagram representing the structure of the test setup that will be used in this project is shown in *Figure 2.2*.




Figure 2.2. Overview of the reduced system that fulfills the scenario of this project.

The system can be split up into different parts, where the main part is a water reservoir placed at ground level, used to supply the system. Two pumps are connected to the reservoir and they supply water to a main water ring formed around the PMA's. A water tower is also connected to the main water ring, and will act both as an additional water reservoir and pressurize the ring due to the elevation of the tower. The direction of water flow with respect to the tower will depend on the pressure in the main ring and the tower can thus be filled by pressurizing the ring or be used to pressurize and supply water to the ring instead of the pumps. From the water ring two PMA's are connected, each via their own pump. In each PMA a measuring point called the critical point (CP) is placed and the pressure at this point shall be kept to accommodate supply demands of the consumers. Furthermore two consumers are placed in each PMA, these are simulated by valves with a variable opening degree where the water flows back to the main reservoir.

As the test setup consist of different components as valves, pumps and pipes, a basic water distribution network is shown in *Figure 2.3* which will be used to illustrate and explain the individual components in the system and their functionality.




Figure 2.3. Basic water distribution network.

Symbol	Name
	Pump
	Manual valve
	Electronic valve
	Pipe segment
	Pressure sensor
	Differential pressure sensor
	Gnd

Table 2.1. Symbol and name for component in the water network.

In the system two different types of Grundfos pumps are used. For supplying the water ring two pumps of the type UPMXL GEO 25-125 are used. Whereas the pumps used in each PMA are of the type UPM2 25-60 which is a smaller pump and typically used at the end-user.

In order to close off parts of the system that will not be used for a specific scenario or to simulate faulty behavior, manual rotary ball valves are placed trough out the system. To simulate a consumer, an electronically controlled belimo valve is used. Thereby is it possible to vary the opening degree of the valve over time according to a specific consumer behavior.

For the pipes there are used two different material types. The pipes used in the main ring and the connections to both the reservoir and the water tower are made of polyethylene grade 80 called PE80. The pipes used to connect the PMA’s to the ring and the internal connections in the PMA’s are made of polyethylene with cross-links called PEX. In addition to the pipes, fittings, bends, and elbows are also present and found in various metals as iron and brass.

The pressure measuring in each PMA is done with a Jumo pressure sensor. The pressure is measured relative to a reference called Gnd, for the test system Gnd is atmospheric pressure. Furthermore both the differential pressure over each pump and the absolute pressure at the pump is measured with a Grundfos direct sensor DPI v.1 and a Danfoss mbs32/33 pressure sensor, respectively.

The main reservoir has a volume of 1000 L and the WT a volume of 200 L. A system diagram of the entire test setup, including pipe dimensions, naming and so on, can be seen in .

add
appendix
reference

Requirements and constraints

3

Adding a WT to an existing water distribution network will introduce constraints and these need to be taken into account.

As mentioned in Section 1: *Introduction*, a minimum pressure must be maintained at the end user. Furthermore the pressure can not exceed a maximum level as this will both increase the possibility of water leakage and wear on the pipes in the system. The system described in Section 2.1: *System overview*, is designed to operate at a pressure around 0.1 bar, relative to the environment [8]. For the purpose of this project the interval for which the pressure should be within, at the end user, is chosen to be $0.08 < p_{cp} < 0.14$ [Bar].

Another important aspect when implementing a WT is water quality. If the water is stored, in the WT, for too long the quality will decrease due to decreasing oxygen level. Because of this a requirement for water quality has to be formulated. As described in Section 2.1: *System overview*, the WT has one combined input/output connection. Therefore a requirement only for flow is hard to formulate as the direction will change dependent on the usage. This could result in a flow based constraint being fulfilled by rapidly changing flow direction without actually replacing any significant water volume in the tower. Instead, a requirement for how often the content of the WT should be exchanged per time unit is proposed. For the purpose of this project the minimum requirement to volume exchange, is chosen to 30% of the maximum volume of the WT, V_T per day. This can be written as $\bar{q}_{wt} > \frac{30 \cdot V_T}{100} [\frac{m^3}{day}]$. As stated in Section 2.1: *System overview* $V_T = 200 L$ so therefore $\bar{q}_{wt} > 60 [\frac{m^3}{day}]$.

This results in the following requirements:

- Pressure at CP, $0.08 < p_{cp} < 0.14$ [bar]
- Minimum water exchange , $\bar{q}_{wt} > 60 [\frac{m^3}{day}]$
- Minimizing the total cost of running the system

4.1 Hydraulic Modeling

Water distribution networks are designed to deliver water to consumers in terms of sufficient pressure and appropriate chemical composition. Distribution systems as such are generally consist of four main components: pipes, pumps, valves and reservoirs. The common property is that they are all two-terminal components, therefore they can be characterized by the dynamic relationship between the pressure drop accross the two endpoints and the flow through the element[9]. *Equation: (4.1)* shows the dual variables which describes one component.

$$\begin{bmatrix} \Delta P \\ q \end{bmatrix} = \begin{bmatrix} P_{in} - P_{out} \\ q \end{bmatrix} \quad (4.1)$$

Where

Δp	is the pressure drop across the two endpoints	$\left[\frac{\text{Pa}}{\text{m}^3} \right]$
q	is the flow through the element.	$\left[\frac{\text{m}^3}{\text{s}} \right]$

In the following chapter the hydraulic model of the system is derived by control volume approach[10]. The relationship between the two variables are introduced for each component in the hydraulic network.

4.1.1 Pipe Model

Pipes are important components of water distribution systems since they are used for carrying pressurized and treated fresh water. A detailed model of pipes has to be derived in order to describe the relationship of pressure and flow for each pipe component. The dynamic model of a pipe can be originated from Newton's second law. *Equation: (4.2)* describes the proportionality between the rate of change of the momentum of the water and the force acting on it.

$$\frac{d}{dt}M = \sum_i F_i \quad (4.2)$$

Where

M	is the linear momentum of the water flow	$\left[\frac{\text{kgm}}{\text{s}} \right]$
F	is the set of forces acting on the water.	$\left[\text{N} \right]$

The dynamic model of a pipe component is derived under the assumption that the flow of the fluid is uniformly distributed along the cross sectional area of the pipe. In other words, all pipes in the system are filled up fully with water all the time. Thus the density of water and the volume of the fluid is constant in time, as is the mass of the water.

Rewriting *Equation: (4.2)*, because of the above-mentioned consideration, the mass of the water can be taken out in front of the derivative.

$$\frac{d}{dt}M = \frac{d(mv)}{dt} = m \frac{dv}{dt} = \sum F \quad (4.3)$$

Where

m	is the mass of the water	$[\text{kg}]$
v	is the value of the velocity of the water at each point of the pipe.	$[\frac{\text{m}}{\text{s}}]$

The sum of the forces acting on the control volume can be seen as input forces, acting on the inlet of the pipe, output forces, acting on the outlet, resistance forces and gravitational force effect. These forces are expressed in terms of pressure in order to obtain the model of the pressure drop in the pipes.

The pipe is assumed to have cylindrical structure. Furthermore, the cross section of the pipe, $A(x)$, is constant for every $x \in [0, L]$, where L is the length of the pipe:

$$A_{in} = A_{out} = \frac{1}{4}\pi D^2 \quad (4.4)$$

Where

A	is the cross sectional area of a pipe	$[\text{m}^2]$
D	is the diameter of the pipe.	$[\text{m}]$

Continuity law in fluid mechanics is applied to analyze the flow in the pipe[10]. A steady and uniform mass flow is assumed in the pipe. Hence, the water flow can be described as:

$$q = A \cdot v \quad (4.5)$$

In *Equation: (4.6)* the forces acting on the pipe are included, the difference between F_{in} and F_{out} which indicates the pressure drop between two endpoints, the resistance forces F_{res} and the gravitational force effect due to change in elevation F_{elev} .

$$m \frac{dv}{dt} = F_{in} - F_{out} - F_{res} - F_{elev} \quad (4.6)$$

In order to obtain an equation consisting of only pressure variables, the relationship between forces and pressures is used.

$$AL\rho \frac{dv}{dt} = Ap_{in} - Ap_{out} - F_{res} - F_{elev} \quad (4.7)$$

Where

A	is the cross sectional area of a pipe	$[\text{m}^2]$
L	is the length of a pipe	$[\text{m}]$
ρ	is the density of water	$[\frac{\text{kg}}{\text{m}^3}]$
p	is the pressure at a point.	$[\text{Pa}]$

The velocity can be written in terms of volumetric water flow and cross sectional area according to the continuity law.

$$AL\rho \frac{d}{dt} \frac{q}{A} = Ap_{in} - Ap_{out} - F_{res} - F_{elev} \quad (4.8)$$

Reducing the cross sectional area to obtain an expression for the pressure:

$$\frac{L\rho}{A} \frac{dq}{dt} = p_{in} - p_{out} - \frac{F_{res}}{A} - \frac{F_{elev}}{A} \quad (4.9)$$

Thus the desired pressure drop between two endpoint is obtained. *Equation: (4.10)* differential equation describes the change in flow as a function of the pressure drops in the system.

$$\frac{L\rho}{A} \frac{dq}{dt} = \Delta p - \frac{F_{res}}{A} - \frac{F_{elev}}{A} \quad (4.10)$$

In *Equation: (4.10)* the term F_{res} is the resistance force acting on the pipe, which consists of two parts: surface resistance(h_f), the friction loss, and the form resistance(h_m) due to the fittings. F_{elev} is the force of gravity due to change of elevation, Δz .

4.1.1.1 Surface Resistance (h_f)

The flow of a liquid through a pipe suffers resistance from the turbulence occurring along the internal walls of the pipe, caused by the roughness of the surface. This surface resistance is given by the Darcy-Weisbach equation [11].

$$h_f = \frac{fLv^2}{2gD} \quad (4.11)$$

Where

f	is the Moody friction factor	$[-]$
h_f	is the pressure given in head	$[m]$
g	is acceleration due to gravity	$\left[\frac{m}{s^2}\right]$
D	is the diameter of the pipe.	$[m]$

Equation: (4.11) is under the assumption that $v > 0$, therefore it is not dependant on $|v|v$ but on v^2 .

Applying the continuity law and assuming that the flow is not unidirectional, the velocity can be substituted by the volumetric flow and pipe area, resulting in:

$$h_f = \frac{8fL}{\pi^2 g D^5} |q|q \quad (4.12)$$

The unknown parameter in 4.12 is the Moody friction factor which is non-dimensional and is a function of the Reynold's number. This friction factor depends on whether the flow is laminar, transient or turbulent, and the roughness of the pipe.

The Reynold's number can be used to determine the regime of the flow. When $Re < 2300$ as laminar, if $2300 < Re < 4000$ as transient and if $Re > 4000$ as turbulent [12].

$$Re = \frac{vD}{\nu} \quad (4.13)$$

Where

ν	is the kinematic viscosity.	$\left[\frac{kg}{ms}\right]$
-------	-----------------------------	------------------------------

The kinematic viscosity in [11] is given by :

$$\nu = 1.792 \cdot 10^{-6} \left[1 + \left(\frac{T}{25} \right)^{1.165} \right]^{-1} \quad (4.14)$$

Where

T is the water temperature $[^{\circ}\text{C}]$

In order to estimate the range of the Reynolds number of a common water distribution, typical values of the temperature, velocity and the radius of the pipes are considered.[13].

- $v = 0.5 - 1.5 \frac{m}{s}$
- $D = 50 - 1500 \text{ mm}$
- $T = 10 - 20 \text{ }^{\circ}\text{C}$

These values result in a Reynold's number between 19000 and 225000, which yields to consider a turbulent fluid flow through the pipes. For turbulent flow the Moody friction factor is given by [11]:

$$f = 1.325 \left(\ln \left(\frac{\epsilon}{3.7D} + \frac{5.74}{Re^{0.9}} \right) \right)^{-2} \quad (4.15)$$

Where

ϵ is the average roughness of the wall inside the pipe. $[\text{m}]$

4.1.1.2 Form Resistance (h_m)

Form resistance losses appear at any time the flow changes direction, due to elbows, bends, or due to enlargers and reducers. It is a particular frictional resistance due to the fittings of a pipe. Form loss can be expressed as:

$$h_m = k_f \frac{v^2}{2g} \quad (4.16)$$

Applying the continuity law:

$$h_m = k_f \frac{8}{\pi^2 g D^4} |q|q \quad (4.17)$$

Where

k_f is the form-loss coefficient. $[-]$

The form-loss coefficient can be split into different loss depending on the fitting of the pipes: pipe bend and elbows.

Pipe bends principally is determined by the bend angle α and bend radius r , it is given by the following expression [11]:

$$k_f = \left[0.0733 + 0.923 \left(\frac{D}{r} \right)^{3.5} \right] \alpha^{0.5} \quad (4.18)$$

Pipe elbows are also used to change the direction of the flow but providing sharp turns in pipelines. The coefficient for the losses in elbows is determined by the angle of an elbow α and is given by:

$$k_f = 0.442 \alpha^{2.17} \quad (4.19)$$

4.1.1.3 Complete Pipe Model

In *Equation: (4.12)* and *Equation: (4.17)*, the head loss of the friction losses are determined. These terms are introduced in *Equation: (4.10)* in terms of pressure. Thus, the friction factors are multiplied by the water density and gravity. Nevertheless, the head loss due to elevation has to be added in the model, yielding the final expression:

$$\frac{L\rho}{A} \frac{dq}{dt} = \Delta p - h_f \rho g - h_m \rho g - \Delta z \rho g \quad (4.20)$$

Substituting the terms h_f and h_m with their respective values:

$$\frac{L\rho}{A} \frac{dq}{dt} = \Delta p - \frac{8fL}{\pi^2 g D^5} \rho g |q|q - k_f \frac{8}{\pi^2 g D^4} \rho g |q|q - \Delta z \rho g \quad (4.21)$$

Equation: (4.21) describes the rate of flow in terms of pressure losses due to pressure change, frictions and elevation. A more compact form can be expressed for the k th component as such:

$$J_k \dot{q}_k = \Delta p_k - \lambda_k(q_k) - \zeta_k \quad (4.22)$$

Where

J_k	is an analogous parameter as inertia for the water
$\lambda_k(q_k)$	is the friction as a function of flow
ζ_k	is the pressure drop due to the elevation.

As can be seen in *Equation: (4.22)*, the flow dynamics of the k th pipe is described by J_k which is an analogous parameter as inertia in mechanical systems. However, it is assumed (prior to the tests carried out on the system) that the presence of the water tower in the system has a slow effect on the flow due to slow integration behaviour. In other words it means that the water tower might have a relatively big time constant compared to the time constant of the pipe. Due to this consideration it would be a fair assumption that the parameter J_k does not influence the flow significantly in the system, therefore it could be neglected. However, the parameter is kept until this assumption is not verified by tests. The complete model of a pipe yields:

$$\Delta p_k = \lambda_k(q_k) + J_k \dot{q}_k + \zeta_k \quad (4.23)$$

4.1.2 Valve Model

Valves in the water distribution system are modelled according to the consideration that the length of each valve, L , and the change in elevation, Δz , are assumed to be zero. Therefore it is assumed that the length of the valve does not influence the flow and the pressure between the endpoints considering the fact that the length of a valve is considerably smaller than the length of a pipe. Another fair assumption is that in case of a valve, elevation is not present.

In the given system, valves are considered as end-user components since they are placed only in the PMAs. These user valves have a variable opening degree (OD) which influences the pressure drop across the endpoints.

In case of valves, manufacturers provide a parameter which indicates the valve capacity. This coefficient is called the k_{v100} -factor that describes the conductivity of the valve at maximum OD. According to the definition of this parameter, it sets the relationship between the capacity through the valve and the pressure drop of $\Delta p = 1[\text{bar}]$ at a fully

open state of the valve. According to [14], the properties of water fulfil the requirements which allows to write up the following expression for flow and pressure:

$$q = k_{v100} \sqrt{\Delta p} \quad (4.24)$$

Equation: (4.24) can be derived in detail using the law of continuity for each endpoint of the valve, however the exact derivations can be found in the datasheet [14]. In the further description and derivations, the coefficients and all the technical considerations are based on this datasheet.

4.1.2.1 Valve conductivity function $k_v(OD)$

Instead of k_{v100} , more generally $k_v(OD)$ can be used which is a function of the opening degree, where $OD \in [0, 1]$. In case of user-operated valves, k_v does not remain constant, it ranges over a compact set of values as the opening degree varies too [9].

All valves in the system share the same characteristics, therefore the following characteristics of k_v are valid for all valves.




Figure 4.1. Valve characteristics - Valve conductivity in the function of OD

According to [15], the following definition can be written up for the conductivity function, $k_v(OD)$:

$$k_v(OD) = \begin{cases} k_{v100} \frac{\theta_{OD}}{\theta_{max}} n_{gl} e^{(1-n_{gl})}, & \text{if } \frac{\theta_{OD}}{\theta_{max}} \leq \frac{1}{n_{gl}}; \\ k_{v100} e^{(n_{gl} (\frac{\theta_{OD}}{\theta_{max}} - 1))}, & \text{if } \frac{\theta_{OD}}{\theta_{max}} \geq \frac{1}{n_{gl}} \end{cases} \quad (4.25)$$

Where

θ_{OD}	is the opening degree	[°]
θ_{max}	is the maximum of the opening degree	[°]
n_{gl}	is the valve characteristic curve factor.	[—]

As can be seen, a new parameter, θ_{max} is introduced which describes the maximum angle where the actuator closes the valve. The same can be stated for a minimum angle. The valve is closed when the position of the actuator $\in [0^\circ, 15^\circ]$. As a consequence, there is an offset in the curve as it is shown in *Figure 4.1*. Introducing the following angle:

$$\gamma = \frac{\theta_{OD} - \theta_{off}}{\theta_{max} - \theta_{off}} \quad (4.26)$$

Where

θ_{off} is the minimum angle where the valve opens. [°]

Equation: (4.25) modifies to:

$$k_v(OD) = \begin{cases} k_{v100} \gamma n_{gl} e^{(1-n_{gl})}, & \text{if } \gamma \leq \frac{1}{n_{gl}}; \\ k_{v100} e^{(n_{gl} \gamma)}, & \text{if } \gamma \geq \frac{1}{n_{gl}} \end{cases} \quad (4.27)$$

As it is shown, the conductivity function of the valve consists of two types of functions:

$$k_v(OD) = \begin{cases} k_v(\theta_{OD}) \sim linear(), & \text{if } \gamma \leq \frac{1}{n_{gl}}; \\ k_v(\theta_{OD}) \sim exponential(), & \text{if } \gamma \geq \frac{1}{n_{gl}} \end{cases} \quad (4.28)$$

Since exponential functions never cross the zero point, it is reasonable to use linear characteristics in the lower range. The transition from linear to exponential part has to be continuously differentiable and predetermined by n_{gl} [9, 15]

4.1.2.2 Complete valve model

Using Equation: (4.24) with the conductivity function $k_v(OD)$ and expressing Δp yields:

$$\Delta p = \frac{1}{k_v(OD)^2} |q| q \quad (4.29)$$

Expressing it in a compact form for the k th valve in the network yields:

$$\Delta p_k = \mu_k(q_k, k_v(OD)) \quad (4.30)$$

4.1.2.3 Unit transformation

4.1.3 Pump Model

In order to move the produced water from the reservoirs to the costumers a pumping equipment is needed. Different types of pumps can be used in a water distribution to guarantee that the water reaches every end-users with the adequate pressure quality.

Centrifugal pumps are ideal to deliver the produced water to the end-users, they generate a positive pressure within they guarantee a constant flow of water at a constant pressure for any given set of conditions. A model describing the pressure drop is derived which was presented in [16], where the head introduced by the pump is given by:

$$\Delta p = -a_{h2} q_i^2 + a_{h1} \omega_r q_i + a_{h0} \omega_r^2 \quad (4.31)$$

Where

Δp is the head produced by the pump
 q_i is the volume flow through the impeller
 ω_r is the impeller speed

The parameters inserted in 4.31 are given by:

We need the model of the power consumption of the pump to minimize the

$$\begin{aligned}
 a_{h2} &= K_s + K_f & a_{h0} &= 2K_s K_d - \sigma_s \left(\frac{r_2^2}{g} - \frac{r_1^2}{g} \right) \\
 a_{h1} &= \sigma_s \left(\frac{r_2}{g A_2} \cot(\beta_2) - \frac{r_1}{g A_1} \cot(\beta_1) \right) - K_s K_d^2
 \end{aligned} \tag{4.32}$$

4.1.4 Water Tower

Water towers are used to maintain the correct pressure level in the system, ensure reliability and to improve the **optimality of the water supply**. The WT plays a determinative role in the flow control, therefore its dynamic model must be derived.

Similarly to the modelling of the other components, the relation between the two dual variables, pressure difference and flow is derived. The structure of the WT is illustrated in *Figure 4.2*.




Figure 4.2. Sketch of the open water tower

In *Figure 4.2*, p_a represents the pressure on the surface of the water, therefore it is the atmospheric pressure at all time. p equals to the pressure value on the bottom of the tank. The rate of change of the fluid volume in the water tower is proportional to the volumetric flow at which water enters or leaves the tank.

$$q = \frac{dV_t}{dt} = A \frac{dh}{dt} \tag{4.33}$$

Where

h	is the height of the fluid in the WT	$[\text{m}]$
V_t	is the volume of the WT	$[\text{m}^3]$
q	is the volumetric flow	$\left[\frac{\text{m}^3}{\text{s}} \right]$

The force on the bottom of the WT is due to the weight of water. According to Newton's second law:

$$F = mg = \rho g V_t \tag{4.34}$$

Where

$$\rho \quad \text{is the density of water.} \quad \left[\frac{\text{kg}}{\text{m}^3} \right]$$

Assuming the side walls of the WT are vertical, *Equation: (4.34)* can be rewritten in terms of pressure such as:

$$\frac{F}{A} = \rho gh = p - p_a = \Delta p \quad (4.35)$$

The total pressure on the bottom of the WT is a result of the pressure difference due to the fluid (p) and the atmospheric pressure (p_a). However, the model is derived in such a way that the atmospheric pressure is set to zero. Therefore, if the water is assumed to be incompressible (density does not change with pressure), *Equation: (4.33)* can be written as:



$$q = \frac{dV}{dt} = \frac{A}{\rho g} \frac{d}{dt} \Delta p = C_H \Delta \dot{p} \quad (4.36)$$

Where

$$C_H \quad \text{is the hydraulic capacitance.} \quad \left[\frac{\text{m}^3}{\text{N/m}^2} \right]$$

This equation shows proportionality between pressure and the volume of water, which is exactly the defining characteristic of a fluid capacitor. When the fluid capacitance is large, corresponding to a tank with a large area, a large increase in volume is accompanied by a small increase in pressure.

An analogy can be made between an electronic circuit and the hydraulic system, where the WT acts as a capacitor. Deriving the relationship between the voltage and the charge of the capacitor:

$$I = C \frac{dU}{dt} \quad (4.37)$$

Where

$$\begin{array}{ll} U & \text{is the voltage} \quad [\text{V}] \\ C & \text{is the capacitance} \quad [\text{F}] \end{array}$$

In the *Equation: (4.36)* the volume flow rate (q) is equivalent to the current (I) in a circuit and the constant term $\left(\frac{A}{\rho g}\right)$ is equivalent to the capacitance of a capacitor (C). The voltage drop is analogous to the pressure drop in the water system.

4.2 Complete system model

Writing up the final expression of each component, a complete system model can be obtained. This model includes pipe, valve and pump components. The water tower is not described in this model but instead by the final expression obtained in Section 4.1.4: *Water Tower*:

$$\Delta \dot{p}_k = \underbrace{\frac{1}{C_H}}_{\text{Water tank}} q_k \quad (4.38)$$

The complete model is based on *Equation: (4.39)* the pipe model, *Equation: (4.30)* the valve model and *Equation: (4.31)* the pump model which are combined as shown:

$$\Delta P_k = \underbrace{\lambda_k(q_k) + \zeta_k}_{\text{Pipe}} + \underbrace{\mu(q_k, k_v)}_{\text{Valve}} - \underbrace{\alpha(u)}_{\text{Pump}} \quad (4.39)$$

The complete system model, *Equation: (4.39)* is used to represent each components except the WT which is described by *Equation: (??)*. In order to describe each component by *Equation: (4.39)* the parameters that correspond to the specific component are chosen accordingly and the remaining are set to zero as they are not used to describe the specific component. The relation seen in *Table: 4.1* shows the parametrization of the system.

Component	λ_k	μ_k	α_k	ζ_k
kth Pipe	λ_k	0	0	ζ_k
kth Valve	0	μ_k	0	0
kth Pump	0	0	α_k	0

Table 4.1. Complete model parametrization.

4.3 Graph Theory

A graph is a formal mathematical way of representation of a network. In general, the structure of the graph is given by mean of engineering approaches e.g., mechanicals systems, electrical circuits or hydraulic networks [17].

In order to make the modelling of the water distribution network the Graph Theory is used. The graph is constructed based on the affinity between both electrical circuits and hydraulic networks. Therefore, an analogy between hydraulic and electrical circuits is done by applying Kirchhoff's law, which represents the interconnection of the elements of an electrical circuit. From the graphical point of view the pressures and flows will be considered as voltage and currents, respectively.

4.3.1 Incidence Matrix

Part II

Control Design

Controller 5

In this chapter the design of the controller is explained. Furthermore the optimization controller is designed and this is implemented in simulink.

5.1 Control Problem

The water distribution system explained in Section 2.1: *System overview* need to be controlled according the Section 3: *Requirements and constraints*. The requirements can be summarized as:

- Minimum pressure at CP, $\rho > x$ [bar]
- Minimum flow through water tower, $q_{wt} > x$ [$\frac{m^3}{h}$]
- Minimizing the total cost of running the system

put in numbers

The pressure at a given CP can be controlled by both the water level in the WT and the rotational speed of the pump connected to the given PMA. To fulfill the requirement of a minimum pressure at a given CP a controller have to be develop that takes both pressure actuators into account.

The flow through the WT is controlled by a pump, . Whenever the pump, , is pumping water into the WT can be seen as a consumer. This mean that the others pumps have to do ensure pressure at all CP. Furthermore the flow rate, q_{WT} , must meet a minimum requirement to insure the water quality. This can be seen as a constrain of the operation area of the system.

name of WT pump

name of WT pump

At the same time the total cost of running the system should be minimized. Therefor a cost function is needed. This cost function purpose is to find the optimal control signal which minimize the cost of running the pumps. Thereby spending the least money on running the total system.

Considering both the cost function and the constrain, this leads to a description of the systems operate area, $C_T(\Delta p_i, q_i)$ wherein the system must operate. By considering the total cost of running, C_t this can be seen as a minimization problem:

$$\begin{aligned} \min_u \quad & C_T(\Delta p_i, q_i) \\ \text{s.t} \quad & p_i \geq x \\ & q_4 \geq x \end{aligned} \tag{5.1}$$

Where

Δp_i is the pressure gain over a pump, [Bar]
and q_i is the flow at a pump. [$m^3 \cdot s^{-1}$]

5.2 Pressure Control

5.3 Minimization Problem

In this section the cost function for the minimization problem and the constraints is explained. Furthermore the optimization controller is designed.

Implementation of controller 6

This chapter will explain how the controller designed in Chapter 5: *Controller* is implemented in MATLAB simulink.

Part III

Conclusion and verification

Accepttest 7

Discussion 8

Conclusion 9


Part IV

Appendices



Number	Assumptions	Section reference
1	The fluid in the network is water.	Section 4.1.1: <i>Pipe Model</i>
2	All pipes in the system are filled up fully with water at all time.	Section 4.1.1: <i>Pipe Model</i>
3	The pipes have a cylindrical structure and the cross section, $A(x)$, is constant for every $x \in [0, L]$.	Section 4.1.1: <i>Pipe Model</i>
4	The flow of water is uniformly distributed along the cross sectional area of the pipe and the flow is turbulent.	Section 4.1.1: <i>Pipe Model</i>
5	Δz , the change in elevation only occurs in pipes.	Section 4.1.2: <i>Valve Model</i>
6	The pumps in the network are centrifugal pumps.	Section 4.31: <i>Pump Model</i>

Table 9.1. List of assumptions



$$H =$$

Bibliography

- [1] N. R. Council *et al.*, *Public Water Supply Distribution Systems: Assessing and Reducing Risks—First Report*. National Academies Press, 2005.
- [2] B. Appelbaum, “Water & sustainability (volume 4): Us electricity consumption for water supply & treatment—the next half century,” 2002.
- [3] Y. X. J.N. Tsitsiklis, “Pricing of fluctuations in electricity markets,” *European Journal of Operational Research*, 2015.
- [4] M. Feldman, “Aspects of energy efficiency in water supply systems,” in *Proceedings of the 5th IWA Water Loss Reduction Specialist Conference, South Africa*, pp. 85–89, 2009.
- [5] Watts, “Water pressure regulators frequently asked questions.” Last visited 14-02-2017, <http://www.watts.com/pages/faq.asp?catId=64&faqId=7>.
- [6] Lenntech, “Why oxygen dissolved in water is important.” Last visited 14-02-2017, http://www.lenntech.com/why_the_oxygen_dissolved_is_important.htm.
- [7] S. Murphy, “General information on dissolved oxygen.” Last visited 14-02-2017, <http://bcn.boulder.co.us/basin/data/NEW/info/D0.html>.
- [8] M. MØlgaard and B. G. Pétursson, *Energy Optimization of Water Distribution Networks*. 2015. Master thesis, Aalborg University.
- [9] C. Kallesøe and C. Persis, “Pressure regulation in nonlinear hydraulic networks by positive controls,” *Proceedings of the European Control Conference Budapest, Hungary*, 2009.
- [10] B. Hunt, *Fluid Mechanics for Civil Engineers*. University of Canterbury, 1995.
- [11] A. K. S. Prabhata K. Swamee, *Design of Water Supply Pipi Networks*. John Wiley & Sons, 2008.
- [12] Y. Nakayama, *Introduction to Fluid Mechanics*. Butterworth Heinemann, 1999.
- [13] N. Trifunovic, *Introduction to uUrban Water Distribution*. Balkema, 2006.
- [14] H. Boysen, *k_v:what,why,how,whence?* Danfoss A/S, 2011.
- [15] U. Keller, *Method for the Hydraulic Compensation and Control of a Heating or Cooling System and Compensation and Control Valve Therefor*. BELIMO Holding AG, Hinwil(CH), 2009.
- [16] C. KallesØe, *Fault Detetecion and Isolation in Centrifugal Pumps*. 2005. Ph.D. thesis, Aalborg University.
- [17] W. Borutzky, *Bond Graph Methodology*. Springer London, 2010.

Rettelser

Todo list

add appendix reference 7

Insert here a free-body diagram - Tom 12

We need the model of the power consumption of the pump to minimize the cost of
power consumed - Tom 17

put in numbers 23

name of WT pump 23

name of WT pump 23