REINFORCEMENT BAR DEVELOPMENT LENGTH (ID) FOR NORMAL WEIGHT CONCRETE														
LOCATION	CONC F'C(PSI)	STEEL GRADE	BAR SIZE											
LUCATION			3	4	5	6	7	8	9	10	11	14	18	
			"IDH"=DEVELOPMENT LENGTH IN INCHES											
TOP	3000	60	16	22	27	35	45	63	80	102	125	170	250	
OTHER	3000	60	13	17	21	27	37	49	62	78	96	131	192	
TOP	4000	60	14	19	23	31	42	55	69	88	108	147	216	
OTHER	4000	60	12	15	18	24	32	42	53	68	83	113	166	
TOP	5000	60	13	17	21	27	37	49	62	79	97	132	193	
OTHER	5000	60	12	13	16	21	29	38	48	61	74	101	149	
TOP	6000	60	12	15	19	25	34	45	57	72	88	120	177	
OTHER	6000	60	12	12	15	19	26	35	44	55	68	92	136	
TOP	7000	60	12	14	18	23	32	42	53	67	82	111	163	
OTHER	7000	60	12	12	14	18	24	32	40	51	63	86	126	

NOTES:

- DEVELOPMENT LENGTHS SHOWN IN THE SCHEDULE ARE CATEGORY 3 LENGTHS
 PER THE 1999 CRSI DESIGN HANDBOOK. THE MINIMUM CONCRETE COVER
 MUST BE GREATER THAN DB AND THE CENTER TO CENTER SPACING MUST
 BE GREATER THAN 3DB. WHERE DB IS THE NOMINAL BAR DIAMETER.
- 2. BARS NOT MEETING CATEGORY 3 REQUIREMENTS SHALL BE PER UBC SECTION 1912. CATEGORY 1 AND 2 DEVELOPMENT LENGTHS MAY BE FOUND IN THE 1999 CRSI DESIGN HANDBOOK.
- 3. TOP BARS ARE HORIZONTAL BARS WITH MORE THAN 12" OF CONCRETE BELOW
- 4. DEVELOPMENT LENGTH SHALL BE INCREASED BY 30% FOR LIGHT WEIGHT CONCRETE.


REINFORCEMENT BAR LAP SPLICE (ID) FOR NORMAL WEIGHT CONCRETE (CLASS "B" SPLICE)												
LOCATION	CONO	BAR SIZE										
	CONC F'C(PSI)	3	4	5	6	7	8	9	10	11		
		"IDH"=DEVELOPMENT LENGTH IN INCHES										
TOP	3000	21	28	35	46	63	82	104	132	162		
OTHER	3000	16	22	27	35	48	63	80	102	125		
TOP	4000	18	24	30	40	54	71	90	114	140		
OTHER	4000	16	19	23	31	42	55	59	88	108		
TOP	5000	18	22	27	36	48	64	81	102	126		
OTHER	5000	16	17	21	27	37	49	62	79	97		
TOP	6000	18	20	25	33	44	58	74	93	115		
OTHER	6000	16	16	19	25	34	45	57	72	88		
TOP	7000	16	18	23	30	41	54	68	86	106		
OTHER	7000	16	16	18	23	32	42	53	67	82		

NOTES:


- 1. LAP LENGTHS SHOWN IN THE SCHEDULE ARE CATEGORY 3
 LAP SPLICES PER THE 1999 CRSI DESIGN HANDBOOK, THE
 MINIMUM CONCRETE COVER MUST BE GREATER THAN DB AND
 THE CENTER TO CENTER SPACING MUST BE GREATER THAN
 3DB. WHERE DB IS THE NOMINAL BAR DIAMETER.
- 2. BARS NOT MEETING CATEGORY 3 REQUIREMENTS SHALL BE PER UBC SECT. 1912. CATEGORY 1 AND 2 LAP SPLICE LENGTHS MAY BE FOUND IN THE 1999 CRSI DESIGN HANDBOOK.
- TOP BARS ARE HORIZONTAL BARS WITH MORE THAN 12" OF CONCRETE BELOW THE BAR.
- THE SMALLER LAP SPLICE LENGTH MAY BE USED WHEN TWO BARS OF DIFFERENT SIZES ARE TO BE LAPPED.
- LAP SPLICE LENGTH SHALL BE INCREASED BY 30% FOR LIGHT WEIGHT CONCRETE.

REINFORCEMENT BAR DEVELOPMENT (IDH) FOR STANDARD HOOKS IN NORMAL WEIGHT CONCRETE GENERAL USE (NOT FOR FRAME JOINTS)													
CONCRETE	STEEL	BAR SIZE											
F'C (PSI)	GRADE	3	4	5	6	7	8	9	10	11	14	18	
	ELOPN	PMENT LENGTH IN INCHES											
3000	60	6	8	10	12	14	16	18	20	22	37	50	
4000	60	6	7	9	10	12	14	15	17	19	32	43	
5000	60	6	7	8	9	11	12	14	15	17	29	39	
6000	60	6	7	7	8	10	11	13	14	16	27	35	
7000	60	6	7	7	8	9	10	12	14	15	25	33	


- $\frac{\text{NOTES}}{\text{1. SIDE}}$ COVER MUST BE GREATER THAN OR EQUAL TO 2 1/2"
- 2. END COVER MUST BE GREATER THAN OR EQUAL TO 2"
 3. HOOK DEVELOPMENT LENGTH SHALL BE INCREASED BY 30% FOR LIGHT WEIGHT CONCRETE





STANDARD WALL & FOOTING INTERTSECTION REINFORCEMENT





STANDARD REINFORCING HOOKS & BENDING DETAILS












VAULT WALL ELEVATION

@ DUCT BANK 2 @ | ref:


> NOTES 1. VERIFY CONDUIT LOCATIONS, ELEVATIONS AND SIZES WITH ELECTRICAL CONTRACTOR PRIOR SLEEVE INSTALLATIONS.

GENERAL NOTES

- 1. FOR STRUCTURAL GENERAL NOTES, SEE SHEET S001.
- 2. ALL STRUCTURAL STEEL SHALL BE HOT-DIPPED GALVANIZED.
- CONTRACTOR SHALL EXERCISE EXTREME CAUTION WHEN WORKING AROUND EXISTING PIPES AND VALVES.



TYPICAL SLEEVE PENETRATION DETAIL scale: NONE



INSTALLATIONS.

© OF DUCT BANK

NOTES

1. VERIFY CONDUIT LOCATIONS, ELEVATIONS AND SIZES WITH ELECTRICAL CONTRACTOR PRIOR SLEEVE

VAULT WALL ELEVATION

@ DUCT BANK

- ADDITIONAL BARS @ FOUR SIDE OF DUCT BANK. MATCH SIZE TO WALL REINFORCEMENT.

- 3"Ø PVC SLEEVE W/ TEMPORARY CONCRETE PLUG, TYPICAL

-5"Ø PVC SLEEVE W/ TEMPORARY CONCRETE PLUG, TYPICAL

CUT BAR AS REQUIRED

TOP OF VAULT -1 1/2"

2'-1 1/2"

2'-6"

OF CONDUIT 4 1/2"

8" CONCRETE WALL. -FOR REINFORCEMENT SEE 3 E 3 S302

> TYPICAL SECTION @ CABLE RACK STANCHION ref: 3:S302

Walnut Creek, CA Seattle, WA Boston, MA PH: (800) 889-WRMS Fax: (925) 933-5167 ALLEN TELESCOPE ARRAY HAT CREEK RADIO OBSERVATORY HAT CREEK, CA STRUCTURAL CABLE VAULT DETAILS & SECTIONS 10/8/03 12-5-03 DK2 RAC One Inch at Full Scale Dwg. No Proj. No.: 02-242 0 .5 1.0 S303 Date Drawn By Appr. By

0 ISSUED FOR CONSTRUCTION

