



1. GROUND CONDUCTOR SHALL BE RUN A MINIMUM OF 18" BELOW GRADE.
2. GROUND CONDUCTOR SHALL BE BARE COPPER, ASTM B-3, STANDARD CLASS B.
3. THE GROUNDING ELECTRODE SHALL BE AN ELECTROLYTIC TYPE. THE ELECTRODE SHALL BE AN L-SHAPED 2.125" O.D. HOLLOW TUBE MADE OF TYPE K COPPER. THE TUBE SHALL BE FILLED WITH NON-HAZARDOUS METALLIC SALTS. THE MANUFACTURER SHALL BE LYNCOLE XIT GROUNDING, MODEL NUMBER K2L-10CS OR APPROVED EQUIV. THE ELECTRODE SHALL BE INSTALLED PER MANUFACTURER'S RECOMMENDATIONS. CONNECTION TO GROUND LOOP SHALL BE AN EXOTHERMIC TYPE (CADWELD).