location for both disconnects, inside unit and condenser

Outside

~8ft

7ft 8in

Condenser

3ft 7in

1ft

Condenser switch   ~1ft   ~6ft   Lieberet main switch

connection pipes

Signal Processing Room

7ft 1in

19ft 6in

door

6ft 2in

Air conditioning unit   2ft 9in

3ft 3in

water drain   window   door

1ft 6in   1ft 10in

4ft 3in

30ft

~8ft

7ft 8in

Outside

Condenser

3ft 7in

Disconnect: inside and condenser

1ft

~1ft

~6ft

conduit inside SPR for supply of AC unit and condenser

3/4 inch for condenser AWG 12

1 1/2 inch for condenser AWG 4

connection pipes

7ft 1in

Signal Processing Room

19ft 6in

door

6ft 2in

3ft 3in

Air conditioning unit

2ft 9in

water drain

window

door

1ft 6in

1ft 10in

4ft 3in

30ft