SCHEDULE OF RCC BEAMS

BEAM NOS.	BEAM TOP LEVEL	SIZE		BOTTOM REINFORCEMENT			TOP REINFORCEMENT			SIDE FACE REINF. ON EACH FACE	STIRRUPS									BEAM TYPE	REMARKS
											LEFT SUP.			CENTRE		RIGHT SUP.				
		B	D	@ LEFT SUPPORT	MID - SPAN	@ RIGHT SUPPORT	@ LEFT SUPPORT	MID - SPAN	@ RIGHT SUPPORT		DIA	@c/c	DIST	DIA	@c/c	DIA	@c/c	DIST		
B1	+36.000	600	550	4-T25 + 6-T32	4-T25 + 6-T32	4-T25 + 6-T32	6-T32 + 4-T25	6-T32 + 4-T25	6-T32 + 4-T25	4-T10	2X2L-T10-100									4	(CAMBER 15MM AT CE BUNDLED STIRRUPS
B2	+36.000	300	550	2-T20 + 3-T25	2-T20 + 3-T25	2-T20 + 3-T25	3-T25 + 2-T20	3-T25 + 2-T20	3-T25 + 2-T20	4-T10	2L-T12-100									4	-
B3	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	3-T25 + 2-T20	3-T25 [LAP] 3-T20	3-T20 + 2-T25	-	2L-T10	100	1200	2L-T10	150	2L-T10	100	1200		4	-
B4,B5	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	3-T20 + 2-T25	3-T20	3-T20 + 2-T25	-	2L-T10	100	1200	2L-T10	150	2L-T10	100	1200		4	-
B6	+36.000	300	550	3-T25	2-T20(0.1L) + 3-T25	3-T25	3-T20 + 2-T25	3-T20	3-T20	-	2L-T10	100	1200	2L-T10	150	2L-T10	100	1200		4	-
B9	+36.000	300	550	3-T16	3-T16	3-T16	3-T25	3-T25	3-T25	-	2L-T8-100									4	CANTILEVER
B13,B14,B24,B255A	+36.300	300	550	3-T12	3-T12	3-T12	3-T12	3-T12	3-T12	-	2L-T8-225									5	-
B15,B320,B321,B341,B347	+36.000	300	550	3-T12	3-T12	3-T12	3-T12	3-T12	3-T12	-	2L-T8-225									5	-
B22	+36.000	300	550	3-T20	3-T16(0.1L) + 3-T20	3-T20	3-T20	3-T20	3-T20 + 2-T32	-	2L-T12-175					2L-T12	125	2000		4	BARS TO BE DEVELOP (20 MM CAMBER AT CEN
B23	+36.000	300	550	3-T32	2-T16(0.1L) + 3-T32	3-T32	3-T32 + 2-T32	3-T32 [LAP] 3-T20	3-T20	-	2L-T12	100	2000	2L-T10-125						4	
B26	+36.000	200	550	2-T16	2-T16	2-T16	2-T12	2-T12	2-T12	-	2L-T8-200									5	-
B28	+36.000	300	550	3-T20	3-T20	3-T20	3-T20 + 3-T20	3-T20 [LAP] 3-T16	3-T16	-	2L-T10	125	2000	2L-T10-200						4	-
B29,B32	+36.000	300	550	3-T16	3-T16	3-T16	3-T25 + 3-T20	3-T25 + 3-T20	3-T25 + 3-T20	-	3L-T10-100									4	CANTILEVER
B30	+36.000	300	575	3-T12	3-T12	3-T12	3-T12	3-T12	3-T12	-	2L-T8-225									5	-
B31,B175	+36.000	300	550	3-T12	3-T12	3-T12	3-T12	3-T12	3-T12	-	2L-T8-225									5	-
B33	+36.000	300	550	3-T20	3-T20	3-T20	3-T16	3-T16 [LAP] 3-T20	3-T20 + 3-T20	-	2L-T10	225	1200	2L-T10	175	2L-T10	150	1200		4	-
B34	+36.000	300	550	3-T25	3-T25	3-T25	3-T20 + 3-T20	3-T20 [LAP] 3-T16	3-T16	-	2L-T10	125	1250	2L-T10	150	2L-T10	200	1200		4	-
B35	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	3-T16	3-T16 [LAP] 3-T20	+ 3-T20 3-T25	-	2L-T10	200	1200	2L-T10	150	2L-T10	100	1200		4	-
B36	+36.000	200	575	2-T12	2-T12	2-T12	2-T12	2-T12	2-T12	-	2L-T8-200									5	-
B37	+36.330	200	575	2-T16	2-T16	2-T16	2-T16	2-T16	2-T16	-	2L-T10	100	1200	2L-T8	150	2L-T10	100	1200		5	-
B38,B39	+36.000	300	550	3-T16	3-T16	3-T16	3-T25 + 2-T16	3-T25 + 2-T16	3-T25 + 2-T16	-	3L-T10-100									4	CANTILEVER
B40	+36.000	200	550	2-T12	2-T12	2-T12	2-T12	2-T12	2-T12	-	2L-T8-250									5	-
B41	+36.000	300	550	3-T20	2-T20(0.1L) + 3-T20	3-T20	3-T20	3-T20 [LAP] 3-T20	3-T20 + 3-T25	-	2L-T10	125	1250	2L-T10	150	2L-T10	125	1250		4	-
B43A	+36.000	300	550	3-T20	2-T12(0.1L) + 3-T20	3-T20	3-T16 + 3-T20	3-T16	3-T16 + 3-T20	-	2L-T10	100	1500	2L-T10	150	2L-T10	100	1500		4	-
B44,B63,B156,B170A,B171, B194,B240,B240A	+36.000	300	550	3-T16	3-T16	3-T16	3-T12	3-T12	3-T12	-	2L-T8-225									5	-
B45	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	3-T16 + 3-T20	3-T16	3-T16 + 3-T20	-	2L-T12	125	1500	2L-T10	150	2L-T12	125	1500		4	-
B46,B46A,B195A	+36.000	300	550	3-T25	3-T25	3-T25	3-T25	3-T25	3-T25	-	2L-T10-100									4	CANTILEVER (U-BAR)
B47	+36.000	300	550	3-T16	3-T16	3-T16	3-T12	3-T12	3-T12	-	2L-T8	150	1200	2L-T8	225	2L-T8	150	1200		5	-
B48	+36.000	300	550	3-T20	3-T16(0.1L) + 3-T20	3-T20	3-T12	3-T12	3-T12	-	2L-T8-100									5	-
B49	+36.000	300	550	3-T20	3-T20	3-T20	3-T12	3-T12	3-T12	-	2L-T10	125	1250	2L-T8	225	2L-T8	200	1200		5	-
B50	+36.000	300	550	3-T20	2-T12(0.1L) + 3-T20	3-T20	3-T16 + 2-T16	3-T16	3-T16 + 2-T16	-	2L-T8	100	1500	2L-T8	150	2L-T8	100	1500		4	-
B51	+36.330	200	575	2-T16	2-T16	2-T16	2-T12	2-T12	2-T12	-	2L-T8-200									5	-
B54	+36.000	300	550	3-T25	2-T20(0.1L) + 3-T25	3-T25	3-T20 + 3-T32	3-T20	3-T20 + 3-T32	-	2L-T12	100	1800	2L-T10	125	2L-T12	100	1800		4	-
B55	+36.000	300	550	3-T25	2-T16(0.1L) + 3-T25	3-T25	3-T16	3-T16	3-T16	-	2L-T10	100	1200	2L-T10	150	2L-T10	100	1200		5	-
B59	+36.000	300	550	3-T25	3-T20(0.1L) + 3-T25	3-T25	3-T20 + 2-T25	3-T20	3-T20 + 2-T25	-	3L-T10	100	2000	3L-T10	175	3L-T10	100	2000		4	-
B65	+36.000	300	550	3-T25	2-T20(0.1L) + 3-T25	3-T25	3-T25 + 3-T25	3-T25	3-T25 + 3-T25	-	2L-T12	100	2000	2L-T10	150	2L-T12	100	2000		4	-
B66	+36.000	300	550	3-T16	3-T16	3-T16	3-T12	3-T12	3-T12	-	2L-T8-100									5	-
B69	+36.000	300	550	3-T20	3-T20(0.1L) + 3-T20	3-T20	3-T25 + 3-T25	3-T25	3-T25 + 3-T25	-	3L-T10	100	1500	3L-T10	150	3L-T10	100	1500		4	-
B72	+36.000	300	575	3-T12	3-T12	3-T12	3-T12	3-T12	3-T12	-	2L-T8-225									5	-
B73	+36.000	200	575	2-T20	2-T12(0.1L) + 2-T20	2-T20	2-T16	2-T16	2-T16	-	2L-T10	90	1260	2L-T8	225	2L-T10	90	1260		5	-
B75,B78	+36.000	200	575	2-T16	2-T16	2-T16	2-T12	2-T12	2-T12	-	2L-T8-100									5	-
B76,B77	+36.330	200	575	2-T16	2-T16	2-T16	2-T16	2-T16	2-T16	-	2L-T10-125									5	-
B79	+36.000	300	550	3-T25	2-T16(0.1L) + 3-T25	3-T25	3-T20	3-T20	3-T20 + 3-T32	-	3L-T12	100	1200	3L-T10	150	3L-T12	100	1200		4	-
B80,B81,B82,B85,B126,B127, B129A	+36.000	300	550	3-T12	3-T12	3-T12	3-T12	3-T12	3-T12	-	2L-T8-225									5	-
B83	+36.000	300	550	3-T12	3-T12	3-T12	3-T12	3-T12	3-T12	-	2L-T8-225									5	-
B84	+36.000	230	575	2-T16	2-T16	2-T16	2-T12	2-T12	2-T12	-	2L-T8-225									5	-
B86	+36.000	400	550	4-T20	4-T16(0.1L) 4-T20	4-T20	4-T12	4-T12	4-T12	-	2L-T8	100	1200	2L-T8	200	2L-T8	100	1200		5	-
B87	+36.000	300	550	3-T16	3-T16	3-T16	3-T16	3-T16 [LAP] 3-T25	+ 3-T25 2-T20	-	2L-T8-225					2L-T8	100	1200		4	-
B88	+36.000	300	550	3-T25	3-T25	3-T25	3-T25 + 2-T20	3-T25 [LAP] 3-T16	3-T16	-	2L-T12	100	1200	2L-T10	150	2L-T10	125	1250		4	-
B89	+36.000	300	550	3-T16	3-T16	3-T16	3-T12	3-T12	3-T12	-	2L-T8-200									5	-
B90,B91,B92	+36.000	300	550	3-T20	3-T20	3-T20	3-T16	3-T16	3-T16	-	2L-T10	125	1250	2L-T8	225	2L-T10	125	1250		5	-
B93	+36.000	300	550	3-T20	3-T20	3-T20	3-T20	3-T20	3-T20	-	2L-T8-100									4	CANTILEVER (U-BAR)
B94	+36.000	400	550	4-T16	2-T12(0.1L) + 4-T16	4-T16	4-T12	4-T12	4-T12	-	2L-T8	100	1200	2L-T8	200	2L-T8	100	1200		5	-
B95	+36.000	400	550	4-T25	4-T25	4-T25	4-T25	4-T25	4-T25	4-T10	4L-T10-90									4	CANTILEVER (U-BAR)

SCHEDULE OF RCC BEAMS

BEAM NOS.	BEAM TOP LEVEL	SIZE		BOTTOM REINFORCEMENT			TOP REINFORCEMENT			SIDE FACE REINF. ON EACH FACE	STIRRUPS									BEAM TYPE	REMARKS
											LEFT SUP.			CENTRE		RIGHT SUP.				
		B	D	@ LEFT SUPPORT	MID - SPAN	@ RIGHT SUPPORT	@ LEFT SUPPORT	MID - SPAN	@ RIGHT SUPPORT		DIA	@c/c	DIST	DIA	@c/c	DIA	@c/c	DIST		
B96	+36.000	300	550	3-T20	2-T20(0.1L) + 3-T20	3-T20	3-T20 + 3-T25	3-T20	3-T20	-	2L-T10	90	1980	2L-T10	125	2L-T10	90	1980	4	-
B97,B98,B99,B100	+36.330	200	575	2-T12	2-T12	2-T12	2-T12	2-T12	2-T12	-	2L-T8-150								5	-
B101	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	3-T12	3-T12	3-T12	-	2L-T8	100	1200	2L-T8	225	2L-T8	150	1200	5	-
B103	+36.000	600	550	5-T16	5-T16	5-T16	5-T12	5-T12	5-T12	-	3L-T8-150								5	-
B104,B105	+36.330	200	575	2-T12	2-T12	2-T12	2-T12	2-T12	2-T12	-	2L-T8-250								5	-
B106	+36.000	600	550	5-T25	5-T25	5-T25	5-T25 + 6-T25	5-T25	5-T25	-	5L-T10	100	2000	5L-T8	200	5L-T8	100	1200	4	BARS TO BE DEVELOP IN COLUMN
B110	+36.000	300	550	3-T16	3-T16	3-T16	3-T25 + 2-T20	+ 3-T25 2-T20	+ 3-T25 2-T20	-	2L-T12-100								4	CANTILEVER
B112	+36.000	300	550	3-T16	3-T16	3-T16	3-T16	3-T16 [LAP] 3-T20	+ 3-T20 3-T25	-	2L-T8	200	1250	2L-T8-100					4	-
B113	+36.000	300	550	3-T25	2-T16(0.1L) + 3-T25	3-T25	+ 3-T20 3-T25	3-T20	3-T20	-	2L-T10	100	1200	2L-T10	150	2L-T10	125	1250	4	-
B115,B128,B128A,B146,B157	+36.000	300	550	3-T16	3-T16	3-T16	3-T25	3-T25	3-T25	-	2L-T12-100								4	CANTILEVER
B116	+36.000	200	550	2-T16	2-T16	2-T16	2-T16	2-T16	2-T16	-	2L-T8-100								4	CANTILEVER (U-BAR)
B117,B118	+36.300	200	550	2-T12	2-T12	2-T12	2-T12	2-T12	2-T12	-	2L-T8-250								5	-
B119	+36.000	300	550	3-T20	2-T12(0.1L) + 3-T20	3-T20	3-T12	3-T12	3-T12	-	2L-T8	125	1250	2L-T8	225	2L-T8	125	1250	5	-
B120,B121	+36.000	600	550	5-T16	5-T16	5-T16	5-T12	5-T12	5-T12	-	2L-T8-125								5	-
B121A	+36.000	600	550	5-T16	5-T16	5-T16	5-T12	5-T12	5-T12	-	2L-T8-125								4	-
B123	+36.000	300	550	3-T20	2-T12(0.1L) + 3-T20	3-T20	3-T12	3-T12	3-T12	-	2L-T8	150	1200	2L-T8	225	2L-T8	150	1200	5	-
B124	+36.000	300	550	3-T20	3-T20	3-T20	+ 3-T16 2-T20	3-T16	3-T16	-	2L-T8	125	1250	2L-T8	100	2L-T8	125	1250	5	-
B125,B129,B138,B158	+36.000	300	550	3-T16	2-T16(0.1L) + 3-T16	3-T16	+ 3-T16 3-T20	3-T16	+ 3-T16 3-T20	-	2L-T10	100	1200	2L-T8	150	2L-T10	100	1200	4	-
B130	+36.000	300	550	3-T25	3-T25	3-T25	+ 3-T16 2-T16	3-T16	+ 3-T16 2-T16	-	2L-T8	100	1200	2L-T8	125	2L-T8	100	1200	4	(CAMBER 25MM AT CENTRE)
B134	+36.000	300	550	3-T25	3-T25	3-T25	3-T16	3-T16	3-T16	-	2L-T10	100	1200	2L-T8	200	2L-T10	125	1250	5	-
B140	+36.000	300	550	3-T25	2-T16(0.1L) + 3-T25	3-T25	3-T16	3-T16	3-T16	-	2L-T10	100	1200	2L-T8	200	2L-T10	100	1200	5	-
B141	+36.000	300	550	3-T16	3-T16(0.1L) + 3-T16	3-T16	+ 3-T20 2-T25	3-T20 [LAP] 3-T16	3-T16	-	2L-T12	100	1500	2L-T10	150	2L-T10	150	1200	4	-
B147,B148	+36.000	200	575	2-T12	2-T12	2-T12	2-T12	2-T12	2-T12	-	2L-T8-250								5	-
B149	+36.000	300	575	3-T12	3-T12	3-T12	3-T12	3-T12	3-T12	-	2L-T8-225								5	-
B154	+36.000	300	550	3-T16	3-T16(0.1L) + 3-T16	3-T16	+ 3-T16 3-T20	3-T16	3-T16	-	2L-T10	125	1250	2L-T10	150	2L-T10	125	1250	4	-
B155	+36.000	300	550	3-T16	3-T16	3-T16	3-T12	3-T12	3-T12	-	2L-T8	150	1200	2L-T8	200	2L-T8	150	1200	5	-
B159	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	+ 3-T20 2-T20	3-T20	+ 3-T20 2-T20	-	2L-T8	100	1200	2L-T8	125	2L-T8	100	1200	4	-
B161	+36.000	300	550	3-T20	2-T20(0.1L) + 3-T20	3-T20	3-T12	3-T12	3-T12	-	2L-T8	100	1200	2L-T8	225	2L-T10	125	1200	5	-
B162	+36.000	200	550	2-T16	2-T16	2-T16	2-T16	2-T16	2-T16	-	2L-T8-150								5	-
B163	+36.000	300	550	3-T25	2-T16(0.1L) + 3-T25	3-T25	3-T16	3-T16	3-T16	-	2L-T10	125	1500	2L-T8	200	2L-T10	125	1500	5	-
B164	+36.000	300	550	3-T25	3-T25	3-T25	3-T16	3-T16	3-T16	-	2L-T8	125	1250	2L-T8	200	2L-T8	125	1250	5	-
B165	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	+ 3-T20 2-T20	3-T20	+ 3-T20 2-T20	-	2L-T10	125	1500	2L-T10	150	2L-T10	125	1500	4	-
B169,B170	+36.000	300	550	3-T16	3-T16	3-T16	3-T12	3-T12	3-T12	-	2L-T8-150								5	-
B171A	+36.000	300	550	3-T16	3-T16	3-T16	3-T16	3-T16	3-T16	-	2L-T8-125								4	-
B172	+36.000	300	550	3-T25	2-T16(0.1L) + 3-T25	3-T25	3-T16	3-T16	3-T16	-	2L-T10	125	1250	2L-T8	200	2L-T10	125	1250	5	-
B173	+36.000	200	550	2-T16	2-T16	2-T16	2-T12	2-T12	2-T12	-	2L-T8-200								5	-
B174	+36.330	200	575	2-T12	2-T12	2-T12	2-T12	2-T12	2-T12	-	2L-T8-250								5	-
B176	+36.000	200	550	2-T20	2-T20	2-T20	2-T20	2-T20	2-T20	-	2L-T8-125								5	-
B178	+36.000	300	550	3-T20	2-T20(0.1L) + 3-T20	3-T20	3-T16	3-T16	3-T16	-	2L-T8	125	1250	2L-T8	225	2L-T8	125	1250	5	-
B179,B180	+36.330	200	575	2-T12	2-T12	2-T12	2-T12	2-T12	2-T12	-	2L-T8-250								5	-
B181	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	+ 3-T16 3-T20	3-T16	+ 3-T16 3-T12	-	2L-T10	125	2250	2L-T8	150	2L-T10	125	2250	4	-
B182	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	+ 3-T20 2-T25	3-T20	+ 3-T20 2-T25	-	2L-T10	100	1200	2L-T10	125	2L-T10	100	1200	4	-
B183	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	3-T12	3-T12	3-T12	-	2L-T8	150	1200	2L-T8	225	2L-T8	150	1200	5	-
B184A	+36.000	300	550	3-T20	3-T20	3-T20	+ 3-T20 2-T16	3-T20	+ 3-T20 2-T16	-	2L-T10	90	1260	2L-T10	200	2L-T10	90	1260	4	-
B185	+36.000	300	550	3-T20	3-T20	3-T20	3-T16	3-T16 [LAP] 3-T20	+ 3-T20 3-T25	-	2L-T8	125	1250	2L-T10	125	2L-T10	100	1200	4	-
B186	+36.000	300	550	3-T20	2-T20(0.1L) + 3-T20	3-T20	+ 3-T20 3-T25	3-T20	3-T20	-	2L-T10	100	2300	2L-T10	150	2L-T10	125	1200	4	-
B187	+36.000	300	550	3-T16	2-T12(0.1L) + 3-T16	3-T16	3-T12	3-T12	3-T12	-	2L-T8-225								5	-
B188	+36.000	300	550	3-T20	2-T16(0.1L) + 3-T20	3-T20	3-T12	3-T12	3-T12	-	2L-T8	125	1250	2L-T8	200	2L-T8	125	1250	5	-
B189	+36.000	300	550	3-T25	3-T25	3-T25	3-T16	3-T16	3-T16	-	2L-T10	100	1200	2L-T8	150	2L-T10	100	1200	5	-
B190	+36.000	300	550	3-T12	3-T12	3-T12	3-T12	3-T12	3-T12	-	2L-T8-225								5	-

NOTE:
NO FLOOR FINISH IS CONSIDERED ON PARKING SLAB, ONLY 2MM PU COATING IS CONSIDERED.

PROVISION :-
LOWER GROUND + GROUND + PD1 TO PD6
+ECO DECK + TERRACE + ROOF

GENERAL NOTES :-
1) READ THIS DRAWING WITH RELEVANT ARCHITECTURAL DRAWINGS
2) IN CASE OF ANY DISCREPANCY KINDLY CONTACT THE DESIGN ENGINEER.
3) REINFORCEMENT GRADE :
FE500 : 8MM & 10MM DIA. BARS
FE550D : 12MM DIA. BARS AND ABOVE
4) CONCRETE GRADE : M40
(ONE GRADE HIGHER TO BE POURED THAN MENTIONED ABOVE)
5) COVER :
BEAMS: 40MM
SLABS (SIMPLY SUPPORTED) = 35MM
SLABS (CONTINOUS) = 30MM
(+5MM EXTRA COVER TO BE ADDED FOR EXPOSED SURFACE AS PER GPL MANDATE)
6) Ldt : FE500 :36 DIA.
: FE550D : 40 DIA.
7) REFER GENERAL DETAIL NOTES & DRAWINGS

KEY PLAN:

GENERAL NOTES:

1. THIS DRAWING IS THE COPYRIGHT OF GODREJ PROPERTIES LTD. AND MUST NOT BE RETAINED, COPIED OR USED WITHOUT THE ABOVE CONSULTANT'S AUTHORITY.
2. DO NOT SCALE FROM THE DRAWINGS.
3. ALL DIMENSIONS ARE IN MILLIMETERS AND LEVELS IN METRES UNLESS NOTED OTHERWISE, ALL DIMENSIONS TO BE VERIFIED ON SITE & APPROVED BY THE ENGINEER.
4. THIS DRAWING SHOULD BE CONFIRMED FROM CONTRACTORS.

DRAWING REVISIONS:

No.	Description	Date
R1	CLOUDED SCHEDULE REVISED	02/03/2026

CLIENT :
GODREJ PROPERTIES LTD | PROPERTIES

ARCHITECTURAL CONSULTANT :
KAPADIA & ASSOCIATED PVT. LTD.

MEPF CONSULTANT :
AEON Integrated Building Design Consultants LLP

LANDSCAPE CONSULTANT:

STRUCTURAL CONSULTANT :
Gokani Consultants and Engineers LLP
801 Quantum Tower, Rambaug Lane,
off S.V.Road, Chincholi, Malad (West),
Mumbai 400 064, India. T: +91 22 2888 4400
ww.gokaniconsultants.com
email : info@gokaniconsultants.com

BIM CONSULTANT :

PROJECT TITLE:
Godrej - Big Bull

NORTH:

DRAWING TITLE:
BEAM SCHEDULE AT 5TH PODIUM FLOOR (NON-TOWER)

PROJECT CODE:	PHASE:	SCALE:	DATE:
GPL_BBL		@A1	17/01/2026

DRAWN BY:	DESIGNED BY:	CHECKED BY:	APPROVED BY:
AV	SG	SB	VG

STAMP, SIGN & DATE:

STRUCTURAL CONSULTANT:	MEPF CONSULTANT :	LANDSCAPE CONSULTANT:	ARCHITECTURAL CONSULTANT:

ISSUED FOR: ☐ CONCEPT ☐ APPROVAL ☐ SD ☐ TENDER ☐ DD ☐ SHOP DRAWING ■ GFC ☐ AS-BUILT

DRAWING NUMBER:
GPL_BBL-NTA-P5-ST-600
GOKANI DRAWING NUMBER:
948-NTA-P5-11-R1

REVISION:
R1