FLOOR	COL. MARK	C1	C2	C2A	C3	C4	C5	C6	C7	C8	C9	C10	C11
6th FLOOR COLUMN	SIZE	330 X 1100	350 X 850	350 X 970	350 X 850	350 X 850	230 X 1330	230 X 1330	230 X 1075	230 X 1100	"L" SHAPE	"L" SHAPE	230 X 1220
	CONC. MIX	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25
	VERT. REINF.	• 4–20 TOR + ○ 12–16 TOR	• 4–20 TOR + ○ 10–16 TOR	• 4–20 TOR + ○ 10–16 TOR	• 14–16 TOR	• 10–20 TOR + ○ 4–16 TOR	• 18–16 TOR	• 4–20 TOR + ○ 14–16 TOR	• 4–20 TOR + ○ 10–16 TOR	• 4–20 TOR + ○ 10–16 TOR	• 13–20 TOR + ○ 14–16 TOR	• 10–25 TOR + ○ 10–20 TOR	• 4–20 TOR + ○ 12–16 TOR
	RING	8 TOR 15 @ 75 + @ 150 + 15 @ 75 C/C 4 SETS + 1 LINK	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 150 + 15 @ 75 C/C 6 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 115 + 15 @ 75 C/C 3 SETS + 4 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 4 LINKS
5th FLOOR COLUMN	SIZE	330 X 1100	350 X 850	350 X 970	350 X 850	350 X 850	230 X 1330	230 X 1330	230 X 1075	230 X 1100	"L" SHAPE	"L" SHAPE	230 X 1220
	CONC. MIX	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25
	VERT. REINF.	• 8–20 TOR + ○ 8–16 TOR	• 6–20 TOR + ○ 8–16 TOR	• 6–20 TOR + ○ 8–16 TOR	• 4–20 TOR + ○ 10–16 TOR	• 10–20 TOR + ○ 4–16 TOR	• 4–20 TOR + ○ 14–16 TOR	• 4–20 TOR + ○ 14–16 TOR	• 8–20 TOR + ○ 6–16 TOR	• 8–20 TOR + ○ 6–16 TOR	• 17–20 TOR + ○ 10–16 TOR	• 14–25 TOR + ○ 6–20 TOR	• 4–20 TOR + ○ 12–16 TOR
	RING	8 TOR 15 @ 75 + @ 150 + 15 @ 75 C/C 4 SETS + 1 LINK	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 150 + 15 @ 75 C/C 6 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 115 + 15 @ 75 C/C 3 SETS + 4 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 4 LINKS
4th FLOOR COLUMN	SIZE	330 X 1100	350 X 850	350 X 970	350 X 850	350 X 850	230 X 1330	230 X 1330	230 X 1075	230 X 1100	"L" SHAPE	"L" SHAPE	230 X 1220
	CONC. MIX	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25
	VERT. REINF.	• 8–20 TOR + ○ 8–16 TOR	• 6–20 TOR + ○ 8–16 TOR	• 6–20 TOR + ○ 8–16 TOR	• 4–20 TOR + ○ 10–16 TOR	• 10–20 TOR + ○ 4–16 TOR	• 4–20 TOR + ○ 14–16 TOR	• 10–20 TOR + ○ 8–16 TOR	• 8–20 TOR + ○ 6–16 TOR	• 8–20 TOR + ○ 6–16 TOR	• 17–20 TOR + ○ 10–16 TOR	• 14–25 TOR + ○ 6–20 TOR	• 6–20 TOR + ○ 10–16 TOR
	RING	8 TOR 15 @ 75 + @ 150 + 15 @ 75 C/C 4 SETS + 1 LINK	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 150 + 15 @ 75 C/C 6 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 115 + 15 @ 75 C/C 3 SETS + 4 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 4 LINKS
3rd FLOOR COLUMN	SIZE	330 X 1100	350 X 850	350 X 970	350 X 850	350 X 850	230 X 1330	230 X 1330	230 X 1075	230 X 1100	"L" SHAPE	"L" SHAPE	230 X 1220
	CONC. MIX	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25
	VERT. REINF.	• 8–20 TOR + ○ 8–16 TOR	• 6–20 TOR + ○ 8–16 TOR	• 6–20 TOR + ○ 8–16 TOR	• 4–20 TOR + ○ 10–16 TOR	• 14–20 TOR	• 4–20 TOR + ○ 14–16 TOR	• 10–20 TOR + ○ 8–16 TOR	• 8–20 TOR + ○ 6–16 TOR	• 8–20 TOR + ○ 6–16 TOR	• 17–20 TOR + ○ 10–16 TOR	• 14–25 TOR + ○ 6–20 TOR	• 6–20 TOR + ○ 10–16 TOR
	RING	8 TOR 15 @ 75 + @ 150 + 15 @ 75 C/C 4 SETS + 1 LINK	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 150 + 15 @ 75 C/C 6 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 115 + 15 @ 75 C/C 3 SETS + 4 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 4 LINKS
2nd FLOOR COLUMN	SIZE	330 X 1100	350 X 850	350 X 970	350 X 850	350 X 850	230 X 1330	230 X 1330	230 X 1075	230 X 1100	"L" SHAPE	"L" SHAPE	230 X 1220
	CONC. MIX	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25
	VERT. REINF.	• 8–20 TOR + ○ 8–16 TOR	• 6–20 TOR + ○ 8–16 TOR	• 6–20 TOR + ○ 8–16 TOR	• 8–20 TOR + ○ 6–16 TOR	• 14–20 TOR	• 6–20 TOR + ○ 12–16 TOR	• 18–20 TOR	• 14–20 TOR	• 8–20 TOR + ○ 6–16 TOR	• 17–20 TOR + ○ 10–16 TOR	• 14–25 TOR + ○ 6–20 TOR	• 6–20 TOR + ○ 10–16 TOR
	RING	8 TOR 15 @ 75 + @ 150 + 15 @ 75 C/C 4 SETS + 1 LINK	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 150 + 15 @ 75 C/C 6 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 115 + 15 @ 75 C/C 3 SETS + 4 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 4 LINKS
1st FLOOR COLUMN	SIZE	330 X 1100	350 X 850	350 X 970	350 X 850	350 X 850	230 X 1330	230 X 1330	230 X 1075	230 X 1100	"L" SHAPE	"L" SHAPE	230 X 1220
	CONC. MIX	M25	M25	M25	M25	M25	M25	M25	M25	M25	M25	M30	M25
	VERT. REINF.	• 10–20 TOR + ○ 6–16 TOR	• 10–20 TOR + ○ 4–16 TOR	• 10–20 TOR + ○ 4–16 TOR	• 8–20 TOR + ○ 6–16 TOR	• 4–25 TOR + ○ 10–20 TOR	• 10–20 TOR + ○ 8–16 TOR	• 4–25 TOR + ○ 14–20 TOR	• 4–25 TOR + ○ 10–20 TOR	• 14–20 TOR	• 27–20 TOR	• 20–25 TOR	• 10–20 TOR + ○ 6–16 TOR
	RING	8 TOR 15 @ 75 + @ 150 + 15 @ 75 C/C 4 SETS + 1 LINK	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 150 + 15 @ 75 C/C 6 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 115 + 15 @ 75 C/C 3 SETS + 4 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 4 LINKS
GROUND FLOOR COLUMN	SIZE	330 X 1100	350 X 850	350 X 970	350 X 850	350 X 850	230 X 1330	230 X 1330	230 X 1075	230 X 1100	"L" SHAPE	"L" SHAPE	230 X 1220
	CONC. MIX	M25	M30	M30	M30	M30	M30	M30	M30	M25	M30	M30	M25
	VERT. REINF.	• 10–20 TOR + ○ 6–16 TOR	• 10–20 TOR + ○ 4–16 TOR	• 10–20 TOR + ○ 4–16 TOR	• 14–20 TOR	• 8–25 TOR + ○ 8–20 TOR	• 18–20 TOR	• 10–25 TOR + ○ 8–20 TOR	• 8–25 TOR + ○ 6–20 TOR	• 14–20 TOR	• 27–20 TOR	• 20–25 TOR	• 16–20 TOR
	RING	8 TOR 15 @ 75 + @ 150 + 15 @ 75 C/C 4 SETS + 1 LINK	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 150 + 15 @ 75 C/C 6 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 115 + 15 @ 75 C/C 3 SETS + 4 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 4 LINKS
BASE. FLOOR COLUMN	SIZE	330 X 1100	350 X 850	350 X 970	350 X 850	350 X 1100	230 X 1330	230 X 1330	230 X 1075	230 X 1100	"L" SHAPE	"L" SHAPE	230 X 1220
	CONC. MIX	M25	M30	M30	M30	M30	M30	M30	M30	M25	M30	M30	M25
	VERT. REINF.	• 16–20 TOR	• 14–20 TOR	• 14–20 TOR	• 4–25 TOR + ○ 10–20 TOR	• 8–25 TOR + ○ 11–20 TOR	• 4–25 TOR + ○ 14–20 TOR	• 18–25 TOR	• 14–25 TOR	• 14–20 TOR	• 27–20 TOR	• 24–25 TOR	• 16–20 TOR
	RING	8 TOR 15 @ 75 + @ 150 + 15 @ 75 C/C 4 SETS + 1 LINK	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 12 @ 75 + @ 150 + 12 @ 75 C/C 4 SETS	8 TOR 15 @ 75 + @ 150 + 15 @ 75 C/C 5 SETS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	8 TOR @ 125 C/C 3 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 150 + 15 @ 75 C/C 6 SETS + 3 LINKS	10 TOR 15 @ 75 +@ 115 + 15 @ 75 C/C 3 SETS + 4 LINKS	10 TOR 15 @ 75 + @ 115 + 15 @ 75 C/C 2 SETS + 4 LINKS
FOOTING	PEDESTAL SIZE 300mm HEIGHT	-----	500 X 1000	-----	950 X 1450	500 X 1250	-----	830 X 1930	-----	-----	790 X 1100	-----	-----
	CONC. MIX.	-----	M25	-----	M25	M25	-----	M25	-----	-----	M25	-----	-----
	HORI. STEEL	-----	-----	-----	10 TOR @ 150 C/C VER. STEEL	-----	-----	10 TOR @ 150 C/C VER. STEEL	-----	-----	8–12 TOR VER. STEEL (EXTRA)	-----	-----
	VERTI. STEEL	-----	-----	-----	10 TOR @ 150 C/C HORI. STEEL	-----	-----	10 TOR @ 150 C/C HORI. STEEL	-----	-----	10 TOR @ 150 C/C HORI. STEEL	-----	-----
	FOOTING SIZE P.C.C. SIZE DEPTH(d TO D) REINF. //B REINF. //L FOOTING MIX.	REFER RAFT FOOTING PLAN OF RAFT–6, RAFT–7, CF–2 CF–3 & DETAIL SECTION	2600 X 3100 2750 X 3250 230 TO 1050 25–10 TOR 21–10 TOR M25	REFER RAFT FOOTING PLAN OF RAFT–1, RAFT–2 RAFT–6, RAFT–5 & DETAIL SECTION	REFER RAFT FOOTING PLAN OF RAFT–5 & DETAIL SECTION	REFER RAFT FOOTING PLAN OF RAFT–2 & DETAIL SECTION	2600 X 3100 2750 X 3250 750 SOLID 31–12 TOR 26–12 TOR M25	REFER RAFT FOOTING PLAN OF RAFT–5 & DETAIL SECTION	REFER COMBINED FOOTING PLAN OF CF–1 & RAFT–3 & DETAIL SECTION	REFER RAFT FOOTING PLAN OF RAFT–3 & DETAIL SECTION	REFER RAFT FOOTING PLAN OF RAFT–5 & DETAIL SECTION	REFER RAFT FOOTING PLAN OF RAFT–5 & DETAIL SECTION	REFER RAFT FOOTING PLAN OF RAFT–3 & DETAIL SECTION	2250 X 3100 2400 X 3250 230 TO 1050 25–10 TOR 18–10 TOR M25
FLOOR	COL. MARK	C1	C2	C2A	C3	C4	C5	C6	C7	C8	C9	C10	C11

GENERAL NOTES:

1 IN CASE OF ANY DISCREPANCY BETWEEN ARCHITECTURAL & STRUCTURAL DRGS, NOTIFY ARCHITECT IMMEDIATELY.
2 THIS BUILDING IS DESIGNED FOR BASEMENT + G.F + 13 UPPER FLOORS.
3 MIN CONC. MIX M25, UNLESS OTHERWISE STATED.
4 ALL CONC. MIX SHALL BE MACHINE MIXED AND MACHINE VIBRATED.
5 CLEAR COVER TO MAIN STEEL: 25 FOR SLAB AND WALL, 40 FOR BEAM & 40 FOR COLUMN, 50 MM FOR FOOTINGS.
6 ALL DIMENSIONS ARE TO BE READ AND NOT TO BE MEASURED
7 TOR INDICATES CORROSION RESISTANT STEEL CRSD,YIELD STRENGTH FY=500 MPA WITH MIN 14.5% ELONGATION.
8 LAP LENGTH = 50 TIMES BAR DIA.
9 S.B.C. AS PER SOIL TEST.
10 ALL FOUNDATION SHALL BE PLACED AT ONE LVL ONLY
11 COLUMN STIRRUPS SHALL BE AT 100 C/C AS PER SETS & DIA SPECIFIDE IN LAPING ZONE.
12 PMC/CLIENTS ENGINEER SHALL CHECK ALL REINFORCEMENTS BEFORE CONCRETING & QUALITY CONCRETE.
13 PROPER SHORING & STRUTTING SHALL BE PROVIDED TO PREVENT ANY SOIL CAVING DURING EXCAVATION & BACKFILLING.
14 FILLING ON BOTH SIDES OF WALL SHALL BE DONE SIMULTANEOUSLY.
15 ALL EXPOSED BRICKWORK IN C.M =1:4.
16 ALL LEVELS AS PER ARCHITECT DRGS.
17 FILLING OF SUNK SHALL BE LIGHT WEIGHT CINDER/AAC FILLING.

KEY PLAN:



FACULTY RESIDENTIAL

ISSUES

DATE	REVISION	DESCRIPTION

1. SHUTTERING DRAWING TO BE PROVIDED TO THE CAMPUS DESIGNER FOR APPROVAL.
2. VENDORS TO PROVIDE SHOP DRAWINGS FOR THE APPROVAL FROM THE CAMPUS DESIGNER

CLIENTS:
INDIAN INSTITUTE OF MANAGEMENT AHMEDABAD
Vikram Sarabhai Marg, Vastrapur,
Ahmedabad - 380015, Gujarat
Phone:-91-(0)47-26214,26217/6,26216

ARCHITECTS:
ARCOP ASSOCIATES PVT. LTD.
A-15, Pamposh Enclave, G.K. 1
New Delhi 110048
Phone : 011 - 26442050

STRUCTURE CONSULTANTS:
N.K.SHAH CONSULTING ENGINEERS LLP
A-1209, MONDEAL HEIGHTS, BESIDES
HOTEL NOVOTEL SG HIGHWAY, AHMEDABAD-15
(TELEFAX :(079)29704898)

FOR EXECUTION

29 APRIL 2019

MEP CONSULTANTS:
PANKAJ DHARKAR & ASSOCIATES, Ahmedabad

Architect's Signature | Client's Signature

Job Title
INDIAN INSTITUTE OF MANAGEMENT AHMEDABAD
FACULTY RESIDENTIAL

Drawing Title
COLUMN FOOTING & COLUMN SCHEDULE

Document Release Type
EXECUTION DRG.

Job No. 2016/04	NORTH
Scale 1:100 ON A1 SHEET	
16 DEC 2017	Drawing No. FR-ST_S-1A
Drawn by B.B.DABHI	
Checked by -----	Revision No. R0

AUTHORITY: