BEAM SCHEDULE

BEAM NUMBERS	SIZE		BOTTOM REINFORCEMENT			TOP REINFORCEMENT			SHEAR STIRRUPS			SFR	REMARKS
	B	D	LEFT	MID SPAN	RIGHT	LEFT	MID SPAN	RIGHT	LEFT	MID SPAN	RIGHT		
B141	400	700	4–T20	4–T20	4–T20	4–T20	4–T20	4–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B142	400	700	4–T20	4–T20	4–T20	4–T20	4–T20	4–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B143	230	700	2–T12	2–T12	2–T12	2–T16	2–T16	2–T16	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	CANTILEVER
B144	230	700	2–T20	2–T20 2–T12	2–T20	2–T16 2–T12	2–T16	2–T16 2–T12	2L–T8@150 C/C	2L–T8@200 C/C	2L–T8@150 C/C	–	–
DP145	150	700	2–T12	2–T12	2–T12	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B146	230	700	2–T16	2–T16	2–T16	2–T16	2–T16	2–T16	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	CANTILEVER
B147	400	700	4–T20	4–T20	4–T20	4–T20	4–T20	4–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B148	400	700	4–T20	4–T20	4–T20	4–T20	4–T20	4–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B149	230	700	2–T16	2–T16	2–T16	2–T16	2–T16	2–T16	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	CANTILEVER
B150	230	700	2–T16	2–T16	2–T16	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B151	230	450	2–T20	2–T20 2–T12	2–T20	2–T16	2–T16	2–T16	2L–T8@150 C/C	2L–T8@200 C/C	2L–T8@150 C/C	–	–
B152	230	700	2–T16	2–T16	2–T16	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B153	230	700	2–T16	2–T16	2–T16	2–T16	2–T16	2–T16	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	CANTILEVER
B154	400	700	4–T20	4–T20	4–T20	4–T20	4–T20	4–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B155	400	700	4–T20	4–T20	4–T20	4–T20	4–T20	4–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
DP156	150	700	2–T12	2–T12	2–T12	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B157	230	700	2–T16	2–T16	2–T16	2–T16	2–T16	2–T16	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	CANTILEVER
B158	230	700	2–T20	2–T20 2–T12	2–T20	2–T16 2–T12	2–T16	2–T16 2–T12	2L–T8@150 C/C	2L–T8@200 C/C	2L–T8@150 C/C	–	–
B159	230	700	2–T12	2–T12	2–T12	2–T16	2–T16	2–T16	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	CANTILEVER
B160	400	700	4–T20	4–T20	4–T20	4–T20	4–T20	4–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B161	400	700	4–T20	4–T20	4–T20	4–T20	4–T20	4–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B162	150	700	2–T12	2–T12	2–T12	2–T10	2–T10	2–T10	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	–
DP163	150	700	2–T12	2–T12	2–T12	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B164	150	700	2–T12	2–T12	2–T12	2–T10	2–T10	2–T10	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	–
B165	400	700	4–T16	4–T16	4–T16	4–T16 1–T12	4–T16 1–T12	4–T16 1–T12	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
DP166	150	700	2–T12	2–T12	2–T12	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B167	230	700	2–T16	2–T16	2–T16	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B168	230	700	2–T16	2–T16	2–T16	2–T10	2–T10	2–T10	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	–
B169	300	700	3–T16	3–T16	3–T16	3–T16	3–T16	3–T16 2–T12	2L–T8@100 C/C	2L–T8@200 C/C	2L–T8@100 C/C	–	@MIDLANDING
B170	450	450	4–T20 4–T20	4–T20 4–T20	4–T20 4–T20	4–T20 3–T20	4–T20	4–T20 3–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B171	400	700	4–T16	4–T16	4–T16	4–T16	4–T16	4–T16	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B172	150	700	2–T12	2–T12	2–T12	2–T10	2–T10	2–T10	2L–T8@100 C/C	2L–T8@100 C/C	2L–T8@100 C/C	–	–
B173	230	700	2–T20	2–T20	2–T20	2–T20	2–T20	2–T20	2L–T10@100 C/C	2L–T10@100 C/C	2L–T10@100 C/C	–	@ MIDLANDING
B174	230	700	2–T20	2–T20 2–T12	2–T20	2–T12	2–T12	2–T12	2L–T8@150 C/C	2L–T8@200 C/C	2L–T8@150 C/C	2–T8EF	–
DP175	150	700	2–T12	2–T12	2–T12	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B176	400	700	4–T16	4–T16	4–T16	4–T16	4–T16	4–T16	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B177	230	700	2–T20	2–T20	2–T20	2–T20	2–T20	2–T20	2L–T10@100 C/C	2L–T10@100 C/C	2L–T10@100 C/C	–	–
B178	230	700	2–T20	2–T20 2–T12	2–T20	2–T20	2–T20	2–T20	2L–T8@100 C/C	2L–T8@200 C/C	2L–T8@100 C/C	–	–
B179	230	450	2–T20	2–T20 2–T16	2–T20	2–T12	2–T12	2–T12	2L–T8@200 C/C	2L–T8@250 C/C	2L–T8@200 C/C	–	–
B180	300	700	3–T16	3–T16	3–T16	3–T16	3–T16	3–T16 2–T10	2L–T10@100 C/C	2L–T10@100 C/C	2L–T10@100 C/C	–	–
B181	400	700	4–T25 4–T25	4–T25 4–T25	4–T25 4–T25	4–T25 4–T25	4–T25 4–T25	4–T25 4–T25	4L–T10@100 C/C	4L–T10@100 C/C	4L–T10@100 C/C	–	–
B182	300	450	3–T16	3–T16	3–T16	3–T12 1–T10	3–T12	3–T12	2L–T8@200 C/C	2L–T8@250 C/C	2L–T8@200 C/C	–	–
B183	230	700	2–T16	2–T16	2–T16	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B184	230	700	2–T25	2–T25	2–T25	2–T20	2–T20	2–T20 2–T12	2L–T12@100 C/C	2L–T12@100 C/C	2L–T12@100 C/C	–	–
B185	500	700	4–T20	4–T20	4–T20	4–T20	4–T20	4–T20	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B186	500	700	4–T20	4–T20	4–T20	4–T20 4–T20	4–T20 4–T20	4–T20 4–T20	4L–T10@100 C/C	4L–T10@100 C/C	4L–T10@100 C/C	–	CANTILEVER
DP187	150	700	2–T12	2–T12	2–T12	2–T10	2–T10	2–T10	2L–T8@200 C/C	2L–T8@200 C/C	2L–T8@200 C/C	–	–
B188	300	700	3–T20	3–T20	3–T20	3–T20	3–T20	3–T20 3–T16	2L–T12@100 C/C	2L–T12@100 C/C	2L–T12@100 C/C	–	–
B189	500	700	4–T20	4–T20	4–T20	4–T20 4–T20	4–T20 4–T20	4–T20 4–T20	4L–T10@100 C/C	4L–T10@100 C/C	4L–T10@100 C/C	–	CANTILEVER
B190	230	700	2–T20	2–T20	2–T20	2–T20	2–T20	2–T20	2L–T12@100 C/C	2L–T12@100 C/C	2L–T12@100 C/C	–	–
B191	300	700	3–T20	3–T20 2–T12	3–T20	3–T16	3–T16	3–T16	2L–T8@100 C/C	2L–T8@200 C/C	2L–T8@100 C/C	–	–
B192	230	700	2–T20	2–T20	2–T20	2–T20	2–T20	2–T20 2–T12	2L–T12@100 C/C	2L–T12@100 C/C	2L–T12@100 C/C	–	–
B193	450	450	4–T20 4–T20	4–T20 4–T20	4–T20 4–T20	4–T20 4–T20	4–T25 4–T16	4–T25 4–T16	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–
B194	450	450	4–T20 4–T20	4–T20 4–T20	4–T20 4–T20	4–T25 4–T16	4–T25 4–T16	4–T25 4–T16	4L–T12@100 C/C	4L–T12@100 C/C	4L–T12@100 C/C	–	–

SCHEDULE OF RCC SLABS

TYPE	THICKNESS	STEEL ALONG SHORT SPAN	STEEL ACROSS SHORT SPAN	REMARKS
S1	125	T8 @ 150 C/C ALT. BENT UP	T8 @ 150 C/C ALT. BENT UP	–
S2	125	T8 @ 125 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	–
S3	125	T8 @ 175 C/C ALT. BENT UP	T8 @ 175 C/C ALT. BENT UP	–
S3A	125	T8 @ 100 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	–
S4	165	T8 @ 150 C/C ALT. BENT UP	T8 @ 200C/C DIST.	–
R1 S5	125	T8 @ 125 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	PROVIDE EOS AS SHOWN
S6	125	T8 @ 200 C/C ALT. BENT UP	T8 @ 200 C/C ALT. BENT UP	–
S7	125	T8 @ 200 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	–
S8	125	T8 @ 150 C/C ALT. BENT UP	T8 @ 150 C/C ALT. BENT UP	–
S9	125	T8 @ 150 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	–
S10	125	T8 @ 150 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	–
S11	125	T8 @ 150 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	–
S12	200	T8 @ 175 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	–
S12A	150	T8 @ 175 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	–
S13	125	T8 @ 200 C/C ALL STR.	T8 @ 200 C/C DIST.	–
R1 S14	125	T8 @ 200 C/C ALT. BENT UP	T8 @ 250 C/C DIST.	@ MIDLANDING
S15	125	T8 @ 200 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	SUNK SLAB–400MM
R2 S16	125	T8 @ 200 C/C ALL STR.	T8 @ 200 C/C DIST.	SERVICE SLAB SUPPORT S16A
S17	125	T8 @ 175 C/C ALT. BENT UP	T8 @ 200 C/C DIST.	–
S18	125	T8 @ 200 C/C ALL STR.	T8 @ 200 C/C DIST.	
CH	125	T8 @ 150 C/C ALL STR AT TOP ;EVERY ALTERNATE BAR BENT BACK ALONG BTM	T8 @ 150 C/C AT TOP & BTM	CANTILEVER SLAB
AST9,AST11	200	T12 @ 100 C/C ALT. BAR BENT UP	T8 @ 200 C/C DIST.	SCISSOR JOINT WITH RESP.UPPER LANDING SUPPORTS AST10 & AST12
AST10,AST12	200	T12 @ 100 C/C ALT. BAR BENT UP	T8 @ 200 C/C DIST.	SCISSOR JOINT WITH RESP.UPPER LANDING RESTING ON AST9 & AST11
BST9,BST11	200	T12 @ 100 C/C ALT. BAR BENT UP	T8 @ 200 C/C DIST.	SCISSOR JOINT WITH RESP.UPPER LANDING SUPPORTS BST10 & BST12
BST10,BST12	200	T12 @ 100 C/C ALT. BAR BENT UP	T8 @ 200 C/C DIST.	SCISSOR JOINT WITH RESP.UPPER LANDING RESTING ON BST9 & BST11
R2 S16A	125	DIST. STEEL OF S16	T8 @ 200 C/C DIST.	SERVICE SLAB RESTING ON S16
R2 S16B	125	DIST. STEEL OF S16A	T8 @ 200 C/C DIST.	SERVICE SLAB RESTING ON S16A

SIGNATURE OF ARCHITECT ON RECORD:–	SIGNATURE & STAMP OF JW CONSULTANTS
	DRAWING IS VALID FOR DESIGN ADEQUACY, PROVIDED IT IS SIGNED & STAMPED BY OUR OFFICE

NOTES:

1. Basic reference codes:
   IS456: 2000, IS1893(Part1): 2016, IS13920: 2016.
2. Due care shall be taken to ascertain that requisite strength of concrete is gained before commencement of deshuttering. It shall comply with provisions of Clause No. 11.3 of IS 456: 2000.
3. Nominal covers

		Mild	Moderate	Severe
I	Footings	50	50	50
II	Columns & walls >200mm width (to links of column)	40	40	45
III	Columns & walls with width of 200mm & below having reinf. of dia. 16mm & above. (to links of column)	40	40	45
IV	Columns & walls with width of 200mm & below having reinf. of dia. 12mm. (to links of column)	25	30	45
V	Slabs	20	30	45
VI	Beams (to stirrups of beam)	20	30	45
VII	Lift walls	40	40	45

   For main reinf. up to 12mm dia. bar for mild exposure the nominal cover may be reduced by 5mm for slabs & beams only.
4. Beams with depth more than 750mm, provide side-face reinforcement.
5. Substratum shall be approved from our office before laying P.C.C.
6. Minimum clear spacing between any two longitudinal bars in beam= 50mm.
7. All laps (Ld) shall be staggered & not more than 50% bars to be lapped at any given section.

GRADE OF REINF.	M20	M25	M30	M35	M40 & ABOVE
Fe415	48 X D	41 X D	38 X D	34 X D	30 X D
Fe500 (TMT)	57 X D	49 X D	46 X D	40 X D	36 X D

   For bundled bars, Ld shall be increased by 10% for 2 bars in contact, 20% for 3 bars in contact and 33% for 4 bars in contact.
8. All buildings shall have tie beams/plinth beams at ground/plinth level.
9. If footings overlap with each other, necessary revision shall be obtained from our office.
10. Design is valid for number of floors as indicated in the drawing.
11. At any level where column size gets reduced in either dimension tie beams/plinth beams are essential.
12. For cantilevers, top bars to be anchored behind from external face of support for - Ld or span of cantilever - whichever is greater.
13. Fire rating considered:- 2 Hour.

Use of this drawing for construction shall explicitly confirm acceptance of following conditions by Owner / Builder / Contractor

1. Our responsibility shall remain limited to safe and sound structural design as transmitted by this drawing.
2. This drawing shall not be used for any construction unless necessary statutory approvals are obtained by the Owner / Builder / Architect from the Regulating Authorities. JW CONSULTANTS LLP are indemnified of any legal consequences in case of unauthorised construction.
3. We shall not remain responsible for -
   a) Safety of old structure during demolition.
   b) Safety of any adjoining building /persons staying in adjoining building/persons and properties on adjoining roads.
   c) Safety of construction worker/any personnel at work site during construction
   d) Correctness/safety of any temporary structure, scaffolding, shuttering, centering erected at site and any injury to any personnel arising out of any accidents.
   e) Accidents occurring due to premature deshuttering, faulty / substandard construction material or workmanship / faulty construction procedure.
   f) Any accident occurring due to construction of elements of buildings not designed by us.
4. Supervision if specifically asked for will be provided to the extent of verification of reinforcement on site but responsibility regarding correct & sound construction shall solely rest with contractor/ builder / owner.
5. All structural concrete should be weigh batched, machine mixed and mechanically vibrated.
6. Any discrepancy between our drawing & Architects' drawing shall be brought to our notice before construction.
7. This drawing is property of JW CONSULTANTS LLP and shall not be reproduced or used without explicit permission of this office.

DRAWING TO BE VALIDATED BY ARCHITECT ON RECORD AFTER CHECKING COMPLIANCE WITH APPROVED PLANS FROM THE REGULATING LOCAL GOVERNMENT AUTHORITY.

NO.	REV. DATE	DESCRIPTION	NO.	REV. DATE	DESCRIPTION
R0	21.12.2021	.	R5	.	.
R1	31.01.2022	.	R6	.	.
R2	17.02.2022	.	R7	.	.
R3	.	.	R8	.	.
R4	.	.	R9	.	.

ENVIRONMENTAL EXPOSURE CONDITION :-	MODERATE	GRADE OF CONCRETE :-	M35
DESIGN LIVE LOAD :- (UNLESS SPECIFIED)	–	GRADE OF STEEL :-	Fe500D
SUPERIMPOSED DEAD LOAD :-	–	S.B.C. :-	–

CHECKED BY	DEALT BY	DRAWN BY	DRG. NO.	BLDG:	JOB NO.
JAYANT	CHANDULAL	VITTHAL	171049–312–3/4	WING–B	171049

DEVELOPER:– SEJAL SHAKTI REALTORS LLP

DESIGN ARCHITECT:– AGRAWAL & AGRAWAL , AMAR TENDULKAR ARCHI

ARCHITECT ON RECORD:– DOT ARCHITECT

PROJECT:– SIDHHA SKY, PROPOSED RESIDENTIAL CONDOMINIU WADALA, MUMBAI

TITLE:– BEAM & SLAB SCHEDULE FOR RCC 1ST FLOOR SLAB

LLP IDENTITY NO.: AAA-2650
PARTNERSHIP WITH LIMITED LIABILITY

JW CONSULTANTS LLP
www.jwconsultants.in
design@jwconsultants.in

PUNE OFFICE
SAI RADHE,OFFICE NO 201,2ND FL.,100
BEHIND HOTEL SHERATON GRAND, PUN
Tel.☎ +91 20 66449100

MUMBAI OFFICE
RUPAREL IRIS, 2ND FLOOR, NEAR MAG
PIPE ROAD, MATUNGA – W , MUMBAI
Tel.☎ +91 22 24397400