

Incident Report INC-2021-009

Incident / Near-miss - Prayag Petro Refinery - Unit 2

Prayag Petro Refinery - Unit 2

Incident ID

INC-2021-009

Date

2021-08-30

Severity

minor

Equipment

FV-112

Description

Feed flow control valve FV-112 stuck partially open; actuator sluggish. Manual intervention required to stabilise flow.