

Incident Report INC-2024-002

Incident / Near-miss - Prayag Petro Refinery - Unit 2

Prayag Petro Refinery - Unit 2

Incident ID

INC-2024-002

Date

2024-03-07

Severity

minor

Equipment

PT-108

Description

Feed header pressure transmitter PT-108 gave abnormal high reading leading to spurious FV-112 movement. Transmitter recalibrated.