

Incident Report INC-2025-003

Incident / Near-miss - Prayag Petro Refinery - Unit 2

Prayag Petro Refinery - Unit 2

Incident ID

INC-2025-003

Date

2025-05-23

Severity

minor

Equipment

P-101A

Description

P-101A seal failure recurred; oil mist observed. Root cause linked to DE bearing degradation and elevated vibration preceding the event.