

SOP-05 Centrifugal Pump Start-up and Shutdown (Rev 2)

Standard Operating Procedure - Prayag Petro Refinery - Unit 2

Prayag Petro Refinery - Unit 2

1. Scope

Feed charge pumps P-101A and P-101B

2. Applicable Equipment

P-101A, P-101B

3. Referenced Standards

OISD-STD-105 clause 5.1

4. Procedure

1. Verify P-101A/P-101B suction from T-401 lined up via L-2001/L-2002.
2. Obtain valid work permit per OISD-STD-105 clause 5.1 before any intrusive job.
3. Confirm mechanical seal flush plan energised.
4. Check bearing lubrication and vibration baseline before start.
5. Start pump, observe discharge pressure at PT-108, ramp FV-112.