

SOP-09 Lock-Out Tag-Out (LOTO) for Rotating Equipment (Rev 4)

Standard Operating Procedure - Prayag Petro Refinery - Unit 2

Prayag Petro Refinery - Unit 2

1. Scope

All rotating equipment in Unit 2 (P-101A/B, C-501)

2. Applicable Equipment

P-101A, P-101B, C-501

3. Referenced Standards

PESA-EL-11 clause 3.2

4. Procedure

1. Identify all energy sources; de-energise and isolate.
2. Apply personal locks and tags per PESA-EL-11 clause 3.2.
3. Verify zero energy before work commences.